

MARTICOT ISLAND, NL, CanadaWMO: **716920**Lat: **47.328N**Lon: **54.585W**Elev: **22**StdP: **101.06**Time Zone: **-3.50 (NAF)**Period: **94-17**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.7	-10.9	-17.6	0.8	-11.8	-15.9	0.9	-10.4	22.8	-3.1	20.3	-2.5	6.2	340	0.794

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.8	19.7	16.8	18.5	16.5	17.7	16.2	17.9	18.6	17.2	17.9	16.7	17.3	4.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.7	18.1	17.0	12.2	17.5	16.4	11.7	17.0	50.7	18.7	48.7	17.9	46.9	17.5	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.7	13.3	DB	-15.2	23.0	2.2	1.0	-16.9	23.7	-18.2	24.3	-19.4	24.8	-21.1	25.5	(4)
(5)			WB	-16.1	19.3	2.2	1.1	-17.7	20.1	-18.9	20.7	-20.2	21.3	-21.7	22.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-2.7	-3.3	-1.7	1.9	5.4	9.4	13.4	16.0	13.3	8.9	4.6	-0.2	(6)	
	DBStd	7.09	3.74	3.71	3.54	2.15	2.06	2.36	2.03	1.70	2.38	2.84	3.17	3.70	(7)	
	HDD10.0	2091	395	373	362	242	143	38	1	0	3	56	162	316	(8)	
	HDD18.3	4696	653	607	620	492	401	268	152	73	151	293	412	574	(9)	
	CDD10.0	439	0	0	0	0	1	20	108	187	103	21	1	0	(10)	
	CDD18.3	2	0	0	0	0	0	0	0	2	1	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.9	7.3	7.0	6.5	5.9	5.0	4.5	4.2	4.8	5.4	6.2	6.7	7.1	(14)	
(15) Precipitation	PrecAvg	1497	135	117	112	114	108	101	106	103	140	163	153	150	(15)	
	PrecMax	1786	218	166	199	259	171	194	175	167	224	291	194	232	(16)	
	PrecMin	1268	66	57	52	45	38	57	55	65	63	91	74	100	(17)	
	PrecStd	126	38	31	41	61	36	37	35	26	45	54	33	39	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	5.2	6.3	9.2	13.6	18.3	20.6	21.6	20.7	16.2	12.4	9.6	(19)	
		MCWB	6.1	5.0	4.4	6.2	8.9	13.7	16.4	17.2	17.5	14.7	11.9	9.2	(20)	
	2%	DB	4.7	4.0	4.4	7.0	11.4	15.6	18.4	20.1	18.6	14.9	11.1	7.9	(21)	
		MCWB	4.5	3.8	3.4	5.2	8.4	12.6	15.7	17.2	16.7	13.7	10.7	7.5	(22)	
	5%	DB	3.5	2.9	3.4	5.8	9.7	13.9	17.2	19.0	17.5	13.8	10.2	6.4	(23)	
		MCWB	3.1	2.6	2.6	4.5	7.4	11.7	15.5	16.9	16.0	12.8	9.8	6.0	(24)	
	10%	DB	2.2	1.6	2.4	4.8	8.4	12.6	16.2	18.1	16.6	12.9	9.1	4.7	(25)	
		MCWB	1.8	1.3	1.7	3.7	6.9	11.1	15.0	16.6	15.4	12.0	8.7	4.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.1	5.1	7.2	10.6	14.9	17.9	19.0	18.5	15.7	12.1	9.3	(27)	
		MCDB	6.3	5.2	5.7	7.9	11.8	16.4	18.9	19.9	19.4	15.9	12.3	9.5	(28)	
	2%	WB	4.6	3.9	3.7	5.7	9.0	13.4	16.7	18.2	17.4	14.3	10.7	7.6	(29)	
		MCDB	4.7	3.9	4.2	6.5	10.3	14.8	17.4	18.9	18.1	14.5	10.8	7.8	(30)	
	5%	WB	3.2	2.7	2.7	4.7	7.9	12.3	16.0	17.6	16.6	13.2	9.8	6.1	(31)	
		MCDB	3.4	2.8	3.1	5.5	9.1	13.4	16.8	18.3	17.2	13.5	10.0	6.5	(32)	
	10%	WB	1.9	1.3	1.9	3.9	7.0	11.4	15.2	17.1	15.7	12.2	8.6	4.3	(33)	
		MCDB	2.2	1.5	2.3	4.7	8.2	12.4	16.0	17.7	16.3	12.7	8.9	4.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.2	4.9	4.3	4.9	4.8	3.8	3.8	4.5	4.2	4.4	4.9	(35)	
		MCDBR	6.5	5.6	5.2	6.0	7.3	7.3	5.8	5.2	5.5	4.7	4.8	6.3	(36)	
	5% WB	MCWBR	7.0	5.8	4.6	4.6	4.9	4.6	3.7	3.4	4.2	4.4	5.4	6.9	(37)	
		MCWBR	6.6	5.6	5.2	5.5	6.3	6.4	4.7	4.0	4.5	4.5	4.7	6.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.319	0.319	0.334	0.368	0.383	0.407	0.436	0.408	0.371	0.350	0.324	0.313	(40)	
		taud	2.347	2.422	2.428	2.359	2.371	2.339	2.301	2.387	2.469	2.477	2.479	2.380	(41)	
	Ebn at Noon		752	848	889	885	882	859	826	837	839	800	752	713	(42)	
		Edh at Noon	73	84	97	114	117	122	125	110	93	79	65	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.04	1.71	2.83	4.18	5.01	5.14	4.92	4.34	3.50	2.18	1.21	0.85	(44)	
	RadStd		0.08	0.18	0.18	0.37	0.37	0.52	0.37	0.26	0.22	0.16	0.15	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page