

POINT ESCUMINAC, NB, Canada

WMO: 717055

Lat: 47.073N

Lon: 64.798W

Elev: 13

StdP: 14.69

Time Zone: -4.00 (NAA)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.9	(c) -3.3	(d) -18.9	(e) 1.9	(f) -6.7	(g) -13.9	(h) 2.6	(i) -2.3	(j) 40.6	(k) 19.0	(l) 36.8	(m) 17.8	(n) 14.6	(o) 270	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 12.9	(c) 82.1	(d) 67.4	(e) 77.0	(f) 65.7	(g) 73.4	(h) 65.5	(i) 70.6	(j) 77.0	(k) 68.9	(l) 73.8	(m) 67.2	(n) 71.5	(o) 12.8	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.5	104.8	72.9	67.1	99.7	71.5	65.4	94.0	70.1	34.5	76.8	33.1	73.8	31.7	71.6	
				</											

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 36.5	(b) 32.1	(c) 28.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(4) 36.5	(5) 32.1	(6) 28.7	(7) -13.2	(8) 74.2	(9) 5.0	(10) 2.2	(11) -16.8	(12) 75.8	(13) -19.7	(14) 77.2	(15) -22.5	(16) 78.4	(17) -26.1	(18) 80.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.6	16.1	16.7	26.4	35.7	47.5	59.8	64.4	65.1	57.8	46.2	36.0	25.4
	DBStd	18.70	10.27	9.70	8.09	5.38	6.95	7.26	5.16	4.55	5.64	6.00	7.05	9.83
	HDD50	4623	1050	933	732	431	134	3	0	0	6	150	421	763
	HDD65	8711	1515	1353	1197	880	542	191	73	53	226	583	870	1228
	CDD50	1547	0	0	0	1	58	298	447	469	241	32	1	0
	CDD65	159	0	0	0	0	1	35	56	57	10	0	0	0
	CDH74	760	0	0	0	0	16	240	226	248	30	0	0	0
	CDH80	201	0	0	0	0	2	73	54	68	4	0	0	0
Wind	WSAvg	13.5	14.1	14.5	14.0	13.2	12.8	11.2	10.6	10.7	12.6	15.0	16.4	16.6
Precipitation	PrecAvg	40.6	3.5	3.0	3.3	2.9	3.4	3.3	3.5	3.4	3.3	4.1	3.6	4.1
	PrecMax	48.3	6.0	5.5	6.7	5.0	6.8	6.1	5.8	6.1	7.0	8.2	6.0	9.4
	PrecMin	30.3	1.0	0.7	1.1	1.5	0.8	1.2	0.9	0.8	1.5	1.0	1.5	1.4
	PrecStd	5.0	1.2	1.3	1.3	1.0	1.3	1.2	1.2	1.4	1.5	1.6	1.1	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.2	45.9	48.0	58.8	75.8	86.9	85.5	87.1	78.1	66.9	56.8	48.7
		MCWB	41.5	40.9	42.8	48.1	59.9	68.6	68.5	69.9	67.1	57.6	51.9	46.2
	2%	DB	38.2	39.2	41.5	50.5	67.4	81.4	80.1	80.7	72.3	61.0	51.0	42.1
		MCWB	36.3	36.6	37.4	43.4	56.9	66.0	68.3	67.3	64.5	55.3	48.1	39.7
	5%	DB	33.9	34.2	38.3	46.2	61.2	74.5	75.5	75.6	69.3	58.2	48.0	38.8
		MCWB	32.7	32.2	35.1	41.2	53.6	64.2	66.7	66.2	63.4	54.1	45.4	37.0
	10%	DB	30.5	31.4	35.6	42.4	57.3	69.5	72.5	72.2	66.4	55.5	45.2	36.5
		MCWB	28.9	29.9	33.3	38.6	52.0	63.5	65.8	65.6	61.7	52.2	42.5	34.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	42.5	44.5	50.3	62.8	71.7	73.5	72.3	70.1	59.8	53.3	47.5
		MCDB	44.0	45.7	46.7	56.3	73.1	83.0	80.0	81.2	74.2	63.3	55.2	49.3
	2%	WB	36.3	36.0	38.7	45.1	57.9	68.3	70.7	70.2	67.3	57.4	48.9	40.4
		MCDB	37.8	38.8	41.4	50.1	64.2	74.5	75.8	76.6	70.3	60.4	50.8	41.5
	5%	WB	32.9	32.5	35.6	41.7	55.0	66.1	68.7	68.8	64.8	54.8	46.2	37.3
		MCDB	34.0	34.0	37.7	45.3	60.4	71.7	73.2	73.7	68.2	57.7	47.8	38.3
	10%	WB	29.3	29.2	33.6	39.2	52.4	64.1	66.8	67.0	62.6	52.3	43.3	35.0
		MCDB	30.4	30.8	35.3	42.1	56.9	69.3	71.3	70.9	65.4	55.1	44.7	36.3
Mean Daily Temperature Range	5% DB	MDBR	15.3	15.3	11.5	9.2	11.2	12.7	11.7	12.9	12.4	11.5	9.9	11.7
		MCDBR	20.5	17.7	15.0	16.6	20.4	22.5	18.3	19.0	17.7	16.8	14.5	13.5
		MCWBR	20.4	16.1	12.6	11.7	12.2	11.4	8.9	9.6	10.9	12.5	13.4	12.6
	5% WB	MCDBR	20.1	17.0	14.1	15.4	19.2	18.4	14.4	15.6	13.4	14.9	13.7	13.1
		MCWBR	20.0	15.8	12.1	11.4	12.0	10.5	8.4	9.5	9.8	12.2	13.1	13.0
Clear-Sky Solar Irradiance	taub	0.286	0.282	0.320	0.352	0.367	0.385	0.413	0.392	0.357	0.330	0.305	0.286	
	taud	2.393	2.335	2.340	2.403	2.426	2.377	2.344	2.395	2.475	2.536	2.541	2.492	
	Ebn at Noon	256	283	286	286	285	279	269	271	271	263	250	245	
	Edh at Noon	22	29	33	35	35	37	38	35	29	24	19	18	
All-Sky Solar Radiation	RadAvg	421	671	1058	1349	1609	1735	1754	1533	1203	754	412	309	
	RadStd	45	73	74	122	159	131	125	100	105	67	51	33	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page