

ST-ANICET, QC, Canada

WMO: 717120

Lat: 45.1208N

Lon: 74.2894W

Elev: 161

StdP: 14.61

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.4	-7.1	-20.3	1.8	-10.9	-15.3	2.4	-6.1	26.1	32.6	22.7	28.2	5.7	240	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	87.3	72.6	84.6	71.2	82.0	69.7	75.7	83.9	73.8	81.5	72.0	79.1	8.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.9	123.0	80.7	71.2	115.9	78.5	69.6	109.5	76.5	39.3	84.1	37.5	81.5	35.9	79.2	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	20.5	17.9	15.8	DB	-21.0	91.5	6.6	2.8	-25.8	93.5	-29.7	95.1	-33.4	96.7	-38.2	98.8
(5)				WB	-21.3	78.9	6.5	2.5	-26.0	80.7	-29.8	82.1	-33.5	83.5	-38.2	85.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.5	16.1	18.2	28.5	43.1	56.2	65.4	69.6	67.3	60.1	48.0	36.2	23.9	
	DBStd	20.92	13.51	11.86	11.15	8.58	7.98	6.76	5.41	5.67	7.54	8.32	9.32	11.60	
	HDD50	4255	1050	889	669	240	27	0	0	0	7	140	422	811	
	HDD65	7894	1515	1309	1132	659	293	76	18	42	184	527	864	1275	
	CDD50	2259	0	0	3	32	220	463	607	536	310	79	8	1	
	CDD65	421	0	0	0	1	20	89	159	113	37	2	0	0	
	CDH74	3936	0	0	2	30	292	826	1404	962	385	35	0	0	
	CDH80	1028	0	0	0	5	82	223	393	228	94	3	0	0	
Wind	WSAvg	6.8	8.2	8.1	7.9	8.0	7.1	6.1	5.5	4.9	5.1	6.3	7.2	7.8	
Precipitation	PrecAvg	39.0	2.9	2.5	2.6	3.3	3.3	3.9	3.7	3.3	3.6	3.7	3.1	3.2	
	PrecMax	46.5	4.6	5.1	4.3	6.3	5.7	7.9	6.2	5.3	6.5	7.5	5.3	6.0	
	PrecMin	31.4	1.3	1.1	1.2	0.4	0.7	1.1	1.9	0.9	1.0	1.2	1.3	1.1	
	PrecStd	4.3	0.9	0.8	0.9	1.6	1.3	1.7	1.3	1.0	1.3	1.8	0.9	1.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	49.4	62.8	78.7	87.3	89.9	91.2	89.4	87.7	78.8	66.3	54.8	
		MCWB	50.3	43.8	53.6	60.3	68.6	74.0	76.1	75.4	72.6	64.8	57.3	49.7	
	2%	DB	44.2	42.6	54.4	70.0	81.6	85.8	87.1	85.3	82.5	72.0	60.8	48.0	
		MCWB	41.4	38.6	46.9	55.3	64.2	70.7	73.7	72.6	70.2	61.8	54.4	45.0	
	5%	DB	38.4	38.3	47.5	63.5	76.5	82.3	84.3	82.3	78.5	66.5	55.1	42.0	
		MCWB	35.8	35.3	41.9	52.0	61.3	68.7	72.0	70.7	68.1	58.4	49.5	39.3	
	10%	DB	34.7	35.2	42.6	58.0	72.0	78.9	81.5	79.6	74.2	61.8	49.8	38.1	
		MCWB	33.0	33.1	38.2	48.5	59.5	66.9	70.5	69.6	65.7	55.6	45.8	35.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	44.8	56.0	63.6	71.6	76.7	79.0	77.2	75.1	67.9	59.3	51.1
			MCDB	53.8	47.6	61.6	75.3	83.8	86.2	88.8	85.7	84.3	75.3	63.6	54.9
2%		WB	41.4	39.0	47.8	57.7	67.8	73.7	76.1	74.7	71.9	63.1	55.3	45.1	
		MCDB	43.6	42.1	53.2	65.7	76.9	81.9	84.1	82.5	79.5	69.5	60.4	47.9	
5%		WB	36.1	35.8	42.4	53.4	64.5	71.4	74.2	72.7	69.5	59.5	50.3	39.7	
		MCDB	38.0	37.7	46.8	61.4	72.3	79.0	81.6	79.8	76.6	65.5	54.1	41.6	
10%		WB	33.0	33.3	38.7	49.7	61.2	69.0	72.4	70.9	66.9	56.2	46.0	36.0	
		MCDB	34.7	35.2	42.1	56.8	69.2	75.9	79.2	77.1	72.8	61.2	49.6	37.7	
Mean Daily Temperature Range	5% DB	MDBR	17.0	17.8	17.0	18.9	21.4	19.9	20.3	21.2	22.1	18.6	15.3	13.9	
		MCDBR	19.9	18.3	22.8	30.1	29.8	24.8	23.4	23.9	26.7	27.3	24.8	17.2	
		MCWBR	18.1	16.0	16.7	18.1	15.0	12.6	12.8	13.2	15.4	16.9	18.8	15.1	
	5% WB	MCDBR	19.4	17.5	21.6	26.3	23.8	20.0	20.4	21.1	23.6	24.2	22.5	16.5	
		MCWBR	17.9	15.7	16.9	17.7	14.3	11.8	12.1	12.5	14.3	16.3	18.1	14.9	
Clear-Sky Solar Irradiance	taub	0.267	0.291	0.327	0.360	0.383	0.440	0.432	0.414	0.374	0.339	0.312	0.288		
	taud	2.382	2.312	2.355	2.371	2.357	2.204	2.231	2.277	2.377	2.479	2.478	2.371		
	Ebn at Noon	272	283	287	286	281	264	265	265	268	264	252	248		
	Edh at Noon	23	30	34	36	38	45	43	39	33	26	22	22		
All-Sky Solar Radiation	RadAvg	443	738	1131	1393	1623	1763	1795	1592	1262	737	455	321		
	RadStd	53	74	98	158	167	140	148	75	105	71	53	28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.67	N/A	N/A	N/A	N/A	+337	+140
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page