

ST-ANICET, QC, Canada

WMO: 717120

Lat: 45.1208N

Lon: 74.2894W

Elev: 49

StdP: 100.74

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.6	-21.7	-29.1	0.3	-23.8	-26.3	0.3	-21.2	11.7	0.4	10.2	-2.1	2.5	240	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	30.7	22.6	29.2	21.8	27.8	21.0	24.3	28.8	23.2	27.5	22.2	26.2	3.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.7	17.6	27.1	21.8	16.6	25.8	20.9	15.6	24.7	73.5	28.9	69.3	27.5	65.6	26.2	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.0	7.1	-29.5	33.0	3.7	1.6	-32.1	34.2	-34.3	35.1	-36.3	36.0	-39.0	37.1		
(5)			-29.6	26.1	3.6	1.4	-32.2	27.0	-34.4	27.8	-36.4	28.6	-39.0	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-8.8	-7.6	-2.0	6.1	13.5	18.6	20.9	19.6	15.6	8.9	2.3	-4.5
	DBStd	11.62	7.51	6.59	6.19	4.76	4.43	3.76	3.01	3.15	4.19	4.62	5.18	6.44
	HDD10.0	2364	583	494	372	133	15	0	0	0	4	78	234	451
	HDD18.3	4386	842	727	629	366	163	42	10	23	102	293	480	708
	CDD10.0	1255	0	0	2	18	122	257	337	298	172	44	4	1
	CDD18.3	234	0	0	0	1	11	49	88	63	21	1	0	0
	CDH23.3	2187	0	0	1	17	162	459	780	534	214	19	0	0
	CDH26.7	571	0	0	0	3	46	124	218	127	52	2	0	0
(14) Wind	WSAvg	3.1	3.6	3.6	3.5	3.6	3.2	2.7	2.5	2.2	2.3	2.8	3.2	3.5
(15) Precipitation	PrecAvg	990	73	63	65	84	83	98	94	84	92	94	78	81
	PrecMax	1180	117	130	108	159	144	200	158	135	166	190	134	153
	PrecMin	798	32	29	31	11	18	29	49	24	25	31	33	27
	PrecStd	109	24	21	23	40	33	44	32	26	32	45	22	28
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	9.7	17.1	26.0	30.7	32.2	32.9	31.9	31.0	26.0	19.0	12.7
		MCWB	10.2	6.6	12.0	15.7	20.3	23.3	24.5	24.1	22.6	18.2	14.1	9.8
	2%	DB	6.8	5.9	12.5	21.1	27.6	29.9	30.6	29.6	28.0	22.2	16.0	8.9
		MCWB	5.2	3.7	8.3	13.0	17.9	21.5	23.2	22.6	21.2	16.6	12.5	7.2
	5%	DB	3.6	3.5	8.6	17.5	24.7	27.9	29.1	27.9	25.8	19.2	12.8	5.5
		MCWB	2.1	1.9	5.5	11.1	16.3	20.4	22.2	21.5	20.0	14.7	9.7	4.1
	10%	DB	1.5	1.8	5.9	14.4	22.2	26.1	27.5	26.4	23.5	16.5	9.9	3.4
		MCWB	0.5	0.6	3.4	9.2	15.3	19.4	21.4	20.9	18.7	13.1	7.7	2.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	7.1	13.3	17.6	22.0	24.8	26.1	25.1	23.9	19.9	15.1	10.6
		MCDB	12.1	8.7	16.4	24.1	28.8	30.1	31.6	29.8	29.0	24.1	17.5	12.7
	2%	WB	5.2	3.9	8.8	14.3	19.9	23.1	24.5	23.7	22.2	17.3	12.9	7.3
		MCDB	6.5	5.6	11.8	18.7	24.9	27.7	28.9	28.1	26.4	20.8	15.8	8.8
	5%	WB	2.3	2.1	5.8	11.9	18.1	21.9	23.5	22.6	20.9	15.3	10.2	4.3
		MCDB	3.3	3.1	8.2	16.3	22.4	26.1	27.6	26.6	24.8	18.6	12.3	5.4
	10%	WB	0.5	0.7	3.7	9.8	16.2	20.6	22.4	21.6	19.4	13.5	7.8	2.2
		MCDB	1.5	1.8	5.6	13.8	20.7	24.4	26.2	25.1	22.7	16.2	9.8	3.2
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	9.9	9.4	10.5	11.9	11.0	11.3	11.8	12.3	10.3	8.5	7.7
		MCDBR	11.1	10.2	12.7	16.7	16.6	13.8	13.0	13.3	14.8	15.2	13.8	9.6
	5% WB	MCWBR	10.1	8.9	9.3	10.1	8.3	7.0	7.1	7.3	8.6	9.4	10.4	8.4
		MCWBR	10.8	9.7	12.0	14.6	13.2	11.1	11.3	11.7	13.1	13.4	12.5	9.2
(40) Clear-Sky Solar Irradiance	taub	taub	0.267	0.291	0.327	0.360	0.383	0.440	0.432	0.414	0.374	0.339	0.312	0.288
		taud	2.382	2.312	2.355	2.371	2.357	2.204	2.231	2.277	2.377	2.479	2.478	2.371
	Ebn at Noon	Ebn at Noon	857	893	906	901	886	833	834	836	844	831	794	783
		Edh at Noon	73	95	106	114	120	141	135	124	104	82	68	68
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.40	2.33	3.56	4.39	5.12	5.56	5.66	5.02	3.98	2.32	1.43	1.01
	RadStd	RadStd	0.17	0.23	0.31	0.50	0.53	0.44	0.47	0.24	0.33	0.22	0.17	0.09

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page