

LA POCATIERE, QC, Canada

WMO: 717130

Lat: 47.354N

Lon: 70.029W

Elev: 31

StdP: 100.95

Time Zone: -5.00 (NAE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.8	-20.5	-28.6	0.3	-22.1	-26.1	0.3	-19.8	16.3	-5.6	15.1	-8.2	5.4	220	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	28.4	21.2	26.7	20.1	25.3	19.4	22.6	26.5	21.5	25.4	20.5	24.2	6.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	15.9	25.2	20.1	14.8	24.3	18.9	13.7	23.1	66.9	26.5	62.8	25.5	59.0	24.6	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.6	11.0	9.7	DB	-26.8	31.2	2.3	1.5	-28.4	32.3	-29.7	33.2	-31.0	34.1	-32.7	35.2
			WB	-27.0	24.7	2.3	1.4	-28.6	25.7	-29.9	26.5	-31.2	27.3	-32.9	28.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-10.2	-8.9	-4.0	3.3	10.6	15.7	18.9	18.1	14.0	7.1	1.0	-6.1	(6)
(7)		DBStd	11.15	6.32	5.65	5.32	3.87	4.15	3.89	3.07	3.19	3.98	4.00	4.53	5.64	(7)
(8)		HDD10.0	2727	627	528	434	205	43	2	0	0	8	111	272	498	(8)
(9)		HDD18.3	4972	885	761	692	453	244	98	30	43	140	349	521	756	(9)
(10)		CDD10.0	913	0	0	0	2	61	174	276	252	127	19	2	0	(10)
(11)		CDD18.3	116	0	0	0	0	3	19	47	37	9	0	0	0	(11)
(12)		CDH23.3	838	0	0	0	1	48	161	319	242	67	0	0	0	(12)
(13)		CDH26.7	148	0	0	0	0	10	29	59	41	9	0	0	0	(13)
(14)	Wind	WSAvg	4.1	5.3	4.9	4.6	4.1	3.9	3.5	3.4	3.3	3.6	4.0	4.3	4.7	(14)
(15)	Precipitation	PrecAvg	963	79	63	72	68	84	83	88	94	92	71	83	93	(15)
(16)		PrecMax	1424	173	142	170	216	191	150	169	222	166	140	170	216	(16)
(17)		PrecMin	773	20	5	20	16	30	31	38	16	21	24	51	24	(17)
(18)		PrecStd	167	35	31	33	39	41	30	36	53	33	28	27	47	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	5.5	10.4	18.9	27.9	29.7	30.6	30.0	27.9	21.1	16.6	7.6	(19)
(20)			MCWB	5.5	3.8	6.6	11.8	17.2	20.6	22.9	21.7	21.4	15.8	13.6	6.4	(20)
(21)		2%	DB	3.3	3.0	6.5	14.7	24.2	27.1	28.3	27.7	25.3	18.3	11.8	4.2	(21)
(22)			MCWB	2.2	1.5	3.7	8.8	15.9	19.6	21.9	21.1	19.9	14.4	9.4	2.9	(22)
(23)		5%	DB	1.3	1.3	4.6	11.9	21.0	25.1	26.5	25.9	23.0	15.9	9.1	2.6	(23)
(24)			MCWB	0.3	0.1	2.3	7.1	14.4	18.7	20.5	20.2	18.4	12.6	6.8	1.2	(24)
(25)		10%	DB	-1.2	-0.3	2.9	9.4	18.4	23.2	25.0	24.4	21.1	13.5	7.0	1.3	(25)
(26)			MCWB	-2.1	-1.3	1.0	5.5	12.6	17.4	19.7	19.1	17.0	10.4	5.0	0.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	4.4	7.2	13.8	20.0	22.8	24.8	23.7	22.7	17.1	14.1	6.6	(27)
(28)			MCDWB	6.1	5.5	8.8	17.7	26.1	27.2	28.9	27.8	26.4	19.7	16.2	7.5	(28)
(29)		2%	WB	2.4	1.7	4.2	9.6	17.5	21.0	22.9	22.2	20.8	14.9	9.8	3.1	(29)
(30)			MCDWB	3.2	2.7	5.9	13.6	21.9	25.2	26.7	26.3	24.3	17.8	11.5	4.1	(30)
(31)		5%	WB	0.4	0.3	2.6	7.6	15.0	19.6	21.7	21.0	19.0	12.9	7.1	1.5	(31)
(32)			MCDWB	1.3	1.2	4.3	11.2	19.5	23.6	25.5	24.9	22.3	15.8	8.7	2.3	(32)
(33)		10%	WB	-2.0	-1.2	1.2	6.0	13.3	18.1	20.6	19.9	17.4	10.8	5.3	0.3	(33)
(34)			MCDWB	-1.3	-0.4	2.7	9.0	17.9	22.2	24.2	23.6	20.8	13.2	6.8	1.1	(34)
(35)	Mean Daily Temperature Range			MDBR	7.7	8.1	7.9	8.2	10.3	9.9	10.3	9.7	7.5	6.0	6.6	(35)
(36)		5% DB	MCDBR	8.7	8.1	9.0	13.2	15.6	13.0	11.7	11.8	12.1	10.6	8.8	6.9	(36)
(37)			MCWBR	8.6	7.4	7.2	8.8	8.8	7.5	6.8	6.7	7.7	7.8	7.5	6.5	(37)
(38)			MCDBR	8.7	7.6	8.3	11.9	13.7	11.2	10.6	10.5	11.4	10.2	8.3	7.0	(38)
(39)		5% WB	MCWBR	8.6	7.1	7.0	8.5	8.7	7.5	6.8	6.7	8.1	8.0	7.4	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.266	0.282	0.320	0.362	0.369	0.393	0.416	0.394	0.372	0.336	0.304	0.279	(40)
(41)		taud		2.342	2.279	2.241	2.298	2.355	2.330	2.289	2.354	2.407	2.494	2.460	2.354	(41)
(42)		Ebn at Noon		826	885	898	890	894	871	843	849	836	818	776	759	(42)
(43)		Edh at Noon		71	94	115	121	119	123	126	114	98	77	65	63	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.36	2.27	3.46	4.45	5.05	5.44	5.35	4.67	3.63	2.13	1.20	0.93	(44)
(45)		RadStd		0.17	0.27	0.27	0.36	0.53	0.36	0.54	0.31	0.28	0.19	0.14	0.09	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page