

MISCOU ISLAND, NB, Canada

WMO: 717190

Lat: 48.0089N

Lon: 64.4942W

Elev: 13

StdP: 14.69

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.8	(c) 0.2	(d) -16.6	(e) 2.2	(f) -2.0	(g) -10.6	(h) 3.1	(i) 1.6	(j) 39.6	(k) 22.0	(l) 36.0	(m) 20.7	(n) 14.0	(o) 280	(p) 0.741

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.3	(c) 79.3	(d) 68.4	(e) 76.1	(f) 66.7	(g) 73.3	(h) 65.1	(i) 70.2	(j) 77.0	(k) 68.3	(l) 74.3	(m) 66.5	(n) 71.6	(o) 13.0	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.6	101.6	74.5	65.9	95.5	71.9	64.3	90.3	70.2	34.3	76.8	32.6	74.4	31.2	71.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 32.4	(b) 28.4	(c) 24.9	(e) -9.1	(f) 86.3	(g) 4.2	(h) 2.8	(i) -12.1	(j) 88.3	(k) -14.6	(l) 89.9	(m) -17.0	(n) 91.4	(o) -20.0	(p) 93.4		
			DB													
			WB													
				(e) -9.5	(f) 74.0	(g) 4.2	(h) 1.7	(i) -12.5	(j) 75.2	(k) -14.9	(l) 76.2	(m) -17.2	(n) 77.1	(o) -20.2	(p) 78.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.9	17.2	17.4	24.6	34.5	45.9	56.5	64.6	64.4	57.1	46.6	35.8	25.2
	DBStd	18.04	9.32	8.89	7.61	5.28	6.41	6.72	4.88	4.50	5.41	5.66	6.82	7.46
	HDD50	4702	1016	914	789	466	166	14	0	0	6	136	427	768
	HDD65	8899	1481	1334	1254	915	594	267	66	66	243	571	875	1233
	CDD50	1398	0	0	0	1	38	210	453	445	219	30	2	0
	CDD65	119	0	0	0	0	0	12	54	47	6	0	0	0
	CDH74	522	0	0	0	0	8	89	235	167	23	0	0	0
	CDH80	74	0	0	0	0	0	15	33	24	2	0	0	0
(14) Wind	WSAvg	12.2	14.4	13.0	13.4	12.0	10.6	10.2	9.8	10.1	11.6	12.9	13.7	14.7
(15) Precipitation	PrecAvg	37.7	2.6	2.4	2.8	2.7	3.4	3.2	3.3	3.1	3.0	4.0	3.4	3.3
	PrecMax	55.5	5.1	5.2	4.7	5.3	6.8	6.9	5.1	5.9	5.9	8.0	6.4	8.5
	PrecMin	23.4	1.0	0.4	0.9	0.6	1.6	1.2	1.5	0.4	0.8	1.5	1.2	0.8
	PrecStd	6.5	1.1	1.2	1.0	1.3	1.5	1.3	1.0	1.4	1.3	1.6	1.1	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.0	38.2	42.8	55.9	73.8	82.1	83.8	83.4	77.2	66.5	56.2	43.9
		MCWB	39.2	36.5	38.4	47.3	60.1	67.5	71.0	71.1	68.5	59.1	54.1	42.8
	2%	DB	36.0	34.9	38.5	47.9	66.6	76.0	79.4	78.2	71.9	61.0	51.3	40.3
		MCWB	34.7	33.6	35.0	42.0	56.3	65.0	69.0	68.4	64.7	55.3	49.1	39.0
	5%	DB	33.3	32.5	36.3	44.0	60.5	71.4	76.4	75.2	68.3	57.6	48.1	37.4
		MCWB	32.1	31.3	33.6	39.3	52.7	62.1	67.2	66.6	62.2	53.3	45.5	35.6
	10%	DB	30.5	30.6	34.3	41.3	56.0	67.5	73.5	72.4	65.6	55.0	45.0	35.1
		MCWB	29.4	29.5	32.2	37.7	50.0	60.0	65.5	65.3	60.5	51.3	42.4	33.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.7	37.4	39.1	48.9	62.8	70.0	73.1	72.5	69.6	60.7	54.5	43.1
		MCDB	40.0	37.9	41.6	54.9	71.4	78.6	81.7	81.0	75.6	65.1	55.7	43.8
	2%	WB	34.9	34.0	35.9	43.2	57.4	66.7	70.5	70.0	66.1	56.7	49.7	39.4
		MCDB	35.8	34.8	37.6	46.6	64.3	73.9	77.4	76.3	70.0	59.9	51.1	40.1
	5%	WB	32.3	31.8	34.0	40.4	53.7	63.7	68.6	68.1	63.4	54.2	46.1	36.0
		MCDB	33.2	32.5	35.9	43.3	59.7	69.4	74.7	73.7	67.3	56.9	47.6	37.0
	10%	WB	29.5	29.7	32.4	38.2	50.3	60.8	66.7	66.4	61.2	51.8	42.8	34.0
		MCDB	30.5	30.7	34.0	40.9	55.4	66.4	72.0	70.9	64.8	54.5	44.5	34.9
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	12.9	11.9	10.5	13.8	15.1	14.3	13.5	12.9	10.3	9.1	9.4
		MCDBR	15.0	12.3	13.7	15.8	23.8	22.9	19.4	18.1	17.1	15.2	12.5	10.7
		MCWBR	14.9	11.8	11.5	11.2	14.8	13.3	10.7	10.4	11.3	12.0	12.0	10.7
	5% WB	MCDBR	15.0	12.0	13.1	14.6	22.5	20.5	17.3	16.1	15.4	13.8	12.1	10.3
		MCWBR	15.6	11.8	11.5	11.3	15.1	12.9	10.5	10.0	11.3	12.1	12.4	10.7
(40) Clear-Sky Solar Irradiance	taub		0.281	0.283	0.318	0.353	0.367	0.385	0.416	0.391	0.360	0.338	0.309	0.289
	taud		2.407	2.305	2.312	2.401	2.428	2.390	2.348	2.409	2.480	2.510	2.509	2.459
	Ebn at Noon		254	279	285	285	284	279	267	270	269	257	243	237
	Edh at Noon		21	29	34	35	35	36	38	34	29	24	19	18
(44) All-Sky Solar Radiation	RadAvg		399	661	1053	1377	1629	1759	1725	1515	1166	724	389	289
	RadStd		41	69	83	115	140	137	138	94	97	57	48	30

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	+2.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page