

NICOLET, QC, Canada

WMO: 717230

Lat: 46.226N

Lon: 72.657W

Elev: 26

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.5	-8.5	-22.7	1.6	-12.2	-17.6	2.1	-7.7	27.3	28.5	23.5	27.2	5.2	0	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	83.8	72.3	81.1	70.5	78.7	68.9	74.5	81.1	72.5	78.7	70.7	76.6	9.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.3	119.8	78.7	70.3	111.8	76.4	68.5	104.9	74.7	38.1	81.0	36.2	78.7	34.7	76.6	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	20.9	17.9	15.5	DB	-20.9	88.4	5.3	2.4	-24.7	90.1	-27.9	91.5	-30.8	92.9	-34.7	94.7
(5)				WB	-21.2	77.6	5.3	2.5	-25.0	79.4	-28.1	80.8	-31.1	82.2	-34.9	84.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.0	12.9	15.8	26.3	41.1	55.4	64.1	68.6	66.7	59.2	47.2	34.8	21.7	(6)
(7)		DBStd	21.26	12.92	11.43	10.13	7.69	6.94	6.20	4.72	4.96	6.87	7.29	8.56	10.99	(7)
(8)		HDD50	4636	1152	959	734	281	25	0	0	0	6	143	458	878	(8)
(9)		HDD65	8368	1617	1379	1199	718	309	91	17	39	198	553	905	1343	(9)
(10)		CDD50	2066	0	0	0	14	191	423	578	518	283	56	3	0	(10)
(11)		CDD65	320	0	0	0	0	9	63	130	93	25	0	0	0	(11)
(12)		CDH74	1978	0	0	0	3	99	421	801	508	144	2	0	0	(12)
(13)		CDH80	345	0	0	0	0	14	86	153	70	22	0	0	0	(13)
(14)	Wind	WSAvg	7.0	7.6	7.4	7.5	7.6	7.3	6.3	6.1	5.6	5.9	7.2	7.7	7.6	(14)
(15)	Precipitation	PrecAvg	39.5	2.9	2.2	2.6	3.1	3.3	3.7	4.1	4.0	3.6	3.7	3.2	3.3	(15)
(16)		PrecMax	45.5	5.1	4.7	4.5	6.2	5.9	6.9	6.9	8.4	7.2	7.2	5.1	5.8	(16)
(17)		PrecMin	31.3	1.3	1.0	1.1	0.9	1.4	1.7	1.8	1.9	1.6	1.3	1.1	0.9	(17)
(18)		PrecStd	4.1	0.9	0.8	0.9	1.3	1.1	1.3	1.3	1.3	1.3	1.5	0.9	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.9	41.8	51.7	69.1	81.8	86.3	87.7	85.4	83.2	72.1	60.7	46.1	(19)
(20)		MCWB	41.5	38.5	43.2	56.1	66.3	72.7	75.2	73.2	71.9	63.3	55.9	44.0	(20)	
(21)		2%	DB	37.8	38.1	45.1	62.6	76.6	82.4	84.0	81.8	78.1	66.7	54.3	40.7	(21)
(22)		MCWB	36.1	35.3	39.3	50.5	62.3	70.9	73.2	71.2	69.3	59.2	50.0	38.9	(22)	
(23)		5%	DB	35.0	35.5	41.5	57.4	72.0	78.8	81.1	79.3	74.3	62.0	50.0	37.7	(23)
(24)		MCWB	33.6	33.4	37.0	48.7	59.7	67.9	71.3	69.8	66.4	56.1	46.4	35.9	(24)	
(25)		10%	DB	31.6	33.2	38.5	53.0	68.1	75.5	78.5	76.7	70.9	58.1	46.2	35.4	(25)
(26)		MCWB	30.4	31.6	35.0	45.2	57.8	65.6	69.5	68.3	64.4	53.5	43.2	33.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.7	39.6	46.0	59.2	69.5	75.7	78.0	76.1	73.5	65.0	56.9	44.5	(27)
(28)		MDCB	42.1	41.0	49.4	66.9	78.2	83.4	84.8	82.5	80.3	70.5	59.3	45.7	(28)	
(29)		2%	WB	36.4	35.5	40.3	52.5	65.7	72.5	75.2	73.2	70.6	60.2	50.8	39.2	(29)
(30)		MDCB	37.3	37.2	44.1	58.8	72.8	80.0	81.4	79.1	76.0	64.8	53.4	40.6	(30)	
(31)		5%	WB	33.5	33.7	37.6	49.2	62.5	69.9	72.9	71.4	68.1	57.1	46.4	36.3	(31)
(32)		MDCB	34.7	35.1	40.5	56.0	69.1	76.6	78.8	77.0	73.2	61.1	49.0	37.5	(32)	
(33)		10%	WB	30.2	31.5	35.6	46.0	59.2	67.7	71.1	69.6	65.4	54.1	43.5	33.9	(33)
(34)		MDCB	31.5	33.2	38.0	51.9	66.0	73.5	77.0	75.1	70.0	57.6	46.1	35.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	15.3	16.7	14.8	15.4	17.7	17.3	16.9	17.3	17.5	13.9	11.4	12.1	(35)	
(36)		5% DB	MCDDBR	15.9	14.5	16.4	23.5	24.1	21.5	20.1	20.0	20.9	20.3	17.1	11.6	(36)
(37)		MCWBR	15.9	13.6	12.0	14.8	13.2	12.3	11.6	11.7	13.1	13.6	14.6	11.4	(37)	
(38)		5% WB	MCDDBR	15.6	14.2	15.0	21.2	20.1	18.8	18.0	17.9	19.3	18.0	15.4	11.7	(38)
(39)		MCWBR	15.7	13.6	11.7	14.6	13.4	12.2	11.5	11.5	13.0	13.4	14.0	11.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.259	0.285	0.317	0.351	0.378	0.416	0.419	0.408	0.375	0.335	0.308	0.279	(40)	
(41)		taud	2.334	2.246	2.289	2.373	2.366	2.257	2.259	2.292	2.375	2.492	2.482	2.346	(41)	
(42)		Ebn at Noon	270	282	288	287	282	270	268	266	266	263	250	246	(42)	
(43)		Edh at Noon	23	31	35	36	37	42	42	39	33	25	21	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	452	738	1146	1417	1627	1782	1765	1549	1215	709	423	307	(44)	
(45)		RadStd	60	82	102	146	167	131	152	72	99	57	54	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page