

BLACKCOMB BASE SLIDING CENTER, BC, Canada

WMO: 717560

Lat: 50.1025N

Lon: 122.9364W

Elev: 3074

StdP: 13.14

Time Zone: -8.00 (NAP)

Period: 07-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.5	9.6	-3.6	5.1	8.5	2.9	7.2	12.8	6.9	34.2	5.5	29.6	1.8	130	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.9	83.1	58.7	79.1	57.9	75.0	56.7	60.8	76.9	59.3	74.6	57.8	71.8	2.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.6	73.9	62.1	54.0	69.6	60.9	52.6	66.1	59.7	28.3	77.2	27.2	74.5	26.2	71.8	64.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.4	4.8	DB	0.2	87.8	5.6	1.7	-3.8	89.0	-7.1	90.0	-10.3	91.0	-14.4	92.2	(4)
(5)			WB	-0.4	62.8	5.7	1.9	-4.5	64.1	-7.8	65.2	-11.0	66.2	-15.2	67.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.2	28.4	29.8	33.1	38.7	47.8	52.4	60.2	60.8	53.7	42.7	32.2	25.4	(6)	
	DBStd	13.97	7.21	6.97	5.54	6.07	7.01	7.09	6.90	7.49	7.98	5.92	6.64	7.55	(7)	
	HDD50	3879	670	565	523	346	132	48	3	4	47	242	535	764	(8)	
	HDD65	8435	1135	985	988	789	535	387	183	176	350	693	985	1229	(9)	
	CDD50	1023	0	0	0	8	62	120	319	340	159	15	0	0	(10)	
	CDD65	104	0	0	0	0	0	9	35	48	12	0	0	0	(11)	
	CDH74	1035	0	0	0	1	10	114	383	429	98	0	0	0	(12)	
	CDH80	241	0	0	0	0	0	28	89	108	16	0	0	0	(13)	
(14) Wind	WSAvg	1.7	1.2	1.4	1.7	1.9	2.0	2.0	2.0	1.9	1.8	1.6	1.4	1.1	(14)	
(15) Precipitation	PrecAvg	49.9	7.0	4.6	4.7	2.7	2.0	2.1	1.5	2.2	2.9	6.3	7.6	7.1	(15)	
	PrecMax	66.3	14.1	10.5	8.9	5.7	4.2	4.2	3.1	9.2	6.4	14.5	17.3	10.6	(16)	
	PrecMin	37.7	3.5	0.4	1.2	0.4	0.5	0.7	0.3	0.4	0.6	0.2	2.2	2.6	(17)	
	PrecStd	7.1	2.3	2.4	2.0	1.3	0.9	0.9	0.8	1.9	1.5	3.4	3.9	2.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	46.3	54.8	67.6	75.3	83.7	86.8	86.9	82.8	64.3	48.9	41.6	(19)	
		MCWB	38.5	37.7	43.0	49.7	53.2	58.8	60.1	59.9	57.8	51.6	47.0	40.4	(20)	
	2%	DB	39.5	42.3	46.8	58.1	70.3	76.8	82.5	83.4	76.7	58.4	45.0	37.9	(21)	
		MCWB	37.6	36.8	39.0	45.1	51.7	57.0	59.1	58.8	55.5	49.4	43.3	36.7	(22)	
	5%	DB	37.3	39.3	43.1	51.9	65.8	70.4	78.3	79.2	71.2	54.1	42.6	35.5	(23)	
		MCWB	35.7	36.3	37.4	42.1	49.7	53.7	57.7	58.2	54.1	48.0	41.5	34.7	(24)	
	10%	DB	35.5	37.1	40.1	47.0	60.1	64.9	74.3	74.3	66.1	50.5	40.2	33.5	(25)	
		MCWB	34.3	35.1	36.2	40.4	48.3	52.0	56.9	57.1	52.8	46.2	39.1	33.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.3	40.7	44.9	50.8	55.8	60.4	62.7	62.4	60.3	54.3	47.8	40.5	(27)	
		MCDB	41.7	42.5	53.1	65.1	69.7	77.4	79.7	78.5	76.0	60.0	48.6	41.4	(28)	
	2%	WB	37.9	38.5	40.9	46.7	53.0	58.0	60.9	60.8	58.1	51.4	43.8	36.9	(29)	
		MCDB	38.8	40.3	45.4	54.8	65.5	74.0	77.3	76.6	70.4	55.4	44.6	37.5	(30)	
	5%	WB	36.1	36.9	38.6	43.7	51.3	55.4	59.3	59.3	55.9	49.1	41.5	34.8	(31)	
		MCDB	37.0	38.7	41.8	50.4	62.2	67.7	74.4	74.7	66.2	53.0	42.4	35.3	(32)	
	10%	WB	34.4	35.2	36.5	41.1	49.3	52.8	57.5	57.9	54.0	46.7	39.2	33.2	(33)	
		MCDB	35.1	36.7	39.1	45.6	57.9	62.2	71.5	71.9	63.9	50.2	40.0	33.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	9.7	10.9	13.3	16.7	15.3	18.3	17.9	15.8	10.6	7.3	7.1	(35)	
		MCDBR	8.4	12.1	16.2	22.4	25.3	25.1	25.0	24.6	23.7	16.5	9.5	7.4	(36)	
	5% WB	MCWBR	6.2	7.7	9.2	11.1	11.1	9.6	9.1	8.6	10.1	9.6	7.6	5.9	(37)	
		MCWBR	7.7	10.1	13.3	19.3	20.9	23.2	22.5	21.5	19.9	14.0	8.9	7.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.265	0.268	0.286	0.328	0.339	0.338	0.333	0.331	0.310	0.307	0.273	0.258	(40)	
		taud	2.279	2.303	2.261	2.156	2.267	2.389	2.432	2.463	2.526	2.500	2.397	2.281	(41)	
	Ebn at Noon		247	280	293	289	291	291	291	287	284	263	245	231	(42)	
		Edh at Noon	22	27	34	43	40	36	34	31	27	23	19	19	(43)	
(44) All-Sky Solar Radiation	RadAvg		271	545	798	1278	1680	1682	1882	1635	1123	626	306	219	(44)	
	RadStd		48	83	126	159	161	209	187	126	100	101	61	37	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (53 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page