

BLACKCOMB BASE SLIDING CENTER, BC, Canada

WMO: 717560

Lat: 50.1025N

Lon: 122.9364W

Elev: 937

StdP: 90.56

Time Zone: -8.00 (NAP)

Period: 07-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-14.7	-12.4	-19.8	0.7	-13.1	-16.1	1.0	-10.7	3.1	1.2	2.4	-1.3	0.8	130	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.9	28.4	14.8	26.2	14.4	23.9	13.7	16.0	25.0	15.2	23.7	14.4	22.1	1.3	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.1	10.6	16.7	12.2	9.9	16.1	11.5	9.4	15.4	48.0	25.1	45.5	23.6	43.1	22.1	17.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2.8	2.4	2.2	-17.6	31.0	3.1	0.9	-19.9	31.7	-21.7	32.2	-23.5	32.8	-25.8	33.4
			-18.0	17.1	3.2	1.0	-20.3	17.8	-22.1	18.4	-23.9	19.0	-26.2	19.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-2.0	-1.2	0.6	3.7	8.8	11.3	15.7	16.0	12.1	5.9	0.1	-3.7	(6)
(7)		DBStd	7.76	4.00	3.87	3.08	3.37	3.89	3.94	3.84	4.16	4.43	3.29	3.69	4.20	(7)
(8)		HDD10.0	2155	372	314	291	192	73	27	2	2	26	134	297	424	(8)
(9)		HDD18.3	4686	631	547	549	438	297	215	102	98	194	385	547	683	(9)
(10)		CDD10.0	568	0	0	0	4	34	67	177	189	88	8	0	0	(10)
(11)		CDD18.3	58	0	0	0	0	0	5	19	27	7	0	0	0	(11)
(12)		CDH23.3	575	0	0	0	1	6	63	213	238	54	0	0	0	(12)
(13)		CDH26.7	134	0	0	0	0	0	16	49	60	9	0	0	0	(13)
(14)	Wind	WSAvg	0.7	0.5	0.6	0.8	0.8	0.9	0.9	0.8	0.8	0.7	0.6	0.5	(14)	
(15)	Precipitation	PrecAvg	1268	178	117	119	68	50	53	37	55	73	161	193	181	(15)
(16)		PrecMax	1684	358	266	225	146	106	106	78	233	162	368	439	268	(16)
(17)		PrecMin	958	90	11	31	10	12	18	7	9	14	5	56	66	(17)
(18)		PrecStd	181	58	60	50	32	23	23	21	48	38	87	98	52	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	7.9	12.7	19.8	24.1	28.7	30.5	30.5	28.2	18.0	9.4	5.3	(19)
(20)			MCWB	3.6	3.2	6.1	9.8	11.8	14.9	15.6	15.5	14.4	10.9	8.3	4.7	(20)
(21)		2%	DB	4.2	5.7	8.2	14.5	21.3	24.9	28.1	28.5	24.8	14.7	7.2	3.3	(21)
(22)			MCWB	3.1	2.7	3.9	7.3	10.9	13.9	15.0	14.9	13.1	9.7	6.3	2.6	(22)
(23)		5%	DB	2.9	4.1	6.2	11.1	18.8	21.3	25.7	26.2	21.8	12.3	5.9	1.9	(23)
(24)			MCWB	2.1	2.4	3.0	5.6	9.8	12.0	14.3	14.6	12.3	8.9	5.3	1.5	(24)
(25)		10%	DB	1.9	2.9	4.5	8.3	15.6	18.3	23.5	23.5	18.9	10.3	4.5	0.8	(25)
(26)			MCWB	1.3	1.7	2.3	4.6	9.1	11.1	13.8	14.0	11.6	7.9	3.9	0.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	4.8	7.2	10.4	13.2	15.8	17.1	16.9	15.7	12.4	8.8	4.7	(27)
(28)			MCDWB	5.4	5.8	11.7	18.4	21.0	25.2	26.5	25.8	24.5	15.6	9.2	5.2	(28)
(29)		2%	WB	3.3	3.6	5.0	8.1	11.6	14.4	16.1	16.0	14.5	10.8	6.6	2.7	(29)
(30)			MCDWB	3.8	4.6	7.4	12.7	18.6	23.3	25.1	24.8	21.3	13.0	7.0	3.1	(30)
(31)		5%	WB	2.3	2.7	3.7	6.5	10.7	13.0	15.1	15.2	13.3	9.5	5.3	1.5	(31)
(32)			MCDWB	2.8	3.7	5.4	10.2	16.8	19.9	23.5	23.7	19.0	11.7	5.8	1.8	(32)
(33)		10%	WB	1.3	1.8	2.5	5.1	9.6	11.6	14.2	14.4	12.2	8.2	4.0	0.6	(33)
(34)			MCDWB	1.7	2.6	4.0	7.6	14.4	16.8	21.9	22.2	17.7	10.1	4.5	0.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	5.4	6.1	7.4	9.3	8.5	10.1	9.9	8.8	5.9	4.0	4.0	(35)
(36)			MCDBR	4.7	6.7	9.0	12.4	14.0	13.9	13.7	13.2	9.2	5.3	4.1	(36)	
(37)			MCWBR	3.4	4.3	5.1	6.2	6.2	5.3	5.0	4.8	5.6	5.3	4.2	3.3	(37)
(38)		5% WB	MCDWR	4.3	5.6	7.4	10.7	11.6	12.9	12.5	12.0	11.1	7.8	4.9	3.9	(38)
(39)			MCWBR	3.3	3.8	4.5	5.8	5.5	5.3	5.0	4.8	5.2	5.0	4.1	3.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.265	0.268	0.286	0.328	0.339	0.338	0.333	0.331	0.310	0.307	0.273	0.258	(40)	
(41)		taud	2.279	2.303	2.261	2.156	2.267	2.389	2.432	2.463	2.526	2.500	2.397	2.281	(41)	
(42)		Ebn at Noon	779	882	923	912	917	918	917	904	894	830	772	729	(42)	
(43)		Edh at Noon	68	86	108	136	127	114	108	99	84	72	61	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.85	1.72	2.52	4.03	5.29	5.30	5.93	5.15	3.54	1.97	0.96	0.69	(44)	
(45)		RadStd	0.15	0.26	0.40	0.50	0.51	0.66	0.59	0.40	0.31	0.32	0.19	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page