

NECHAKO RIVER, BC, Canada

WMO: 717630

Lat: 53.680N

Lon: 124.830W

Elev: 2346

StdP: 13.49

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -30.1	(c) -21.3	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 26.7	(c) 82.0	(d) N/A	(e) 78.0	(f) N/A	(g) 74.3	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.3	11.5	21.5	30.3	38.7	47.2	53.6	57.8	57.1	49.7	37.6	25.5	15.9		
	DBStd	18.07	16.38	11.50	8.89	5.14	6.32	5.56	4.81	5.76	5.80	6.96	9.95	13.99		
	HDD50	5367	1194	797	612	340	132	25	3	8	76	388	734	1058		
	HDD65	10131	1659	1217	1077	789	550	344	228	250	459	851	1184	1523		
	CDD50	722	0	0	0	1	46	132	244	230	67	2	0	0		
	CDD65	11	0	0	0	0	0	1	4	6	0	0	0	0		
	CDH74	880	0	0	0	1	36	138	288	384	33	0	0	0		
	CDH80	202	0	0	0	0	1	28	65	108	0	0	0	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	24.7	2.5	1.5	1.6	1.4	1.7	2.4	2.4	1.9	2.1	2.4	2.7	2.3		
	PrecMax	39.0	9.1	2.8	2.7	2.5	3.6	5.4	5.0	4.1	3.5	4.1	4.0	4.0		
	PrecMin	19.9	1.0	0.3	0.5	0.6	0.7	1.1	0.7	0.6	0.6	0.9	1.0	0.6		
	PrecStd	3.7	1.4	0.6	0.6	0.5	0.6	0.9	1.0	0.8	0.8	0.7	0.8	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.3	48.5	57.6	67.5	78.3	84.2	86.5	87.7	77.8	64.9	45.4	42.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	37.1	42.9	51.9	61.6	73.4	77.8	80.9	83.0	73.7	57.2	41.3	38.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	32.8	39.8	46.8	57.1	68.6	72.8	76.6	78.3	69.8	53.3	38.2	34.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	30.0	35.5	43.6	53.0	64.4	68.3	72.7	73.2	64.8	49.1	35.7	31.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		16.5	21.8	23.2	26.3	28.2	25.6	26.7	28.2	27.7	19.4	12.8	14.9		
	5% DB	MCDBR	17.7	23.5	26.1	34.4	36.9	34.7	36.1	38.4	37.5	26.2	15.2	17.7		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.259	0.272	0.293	0.319	0.339	0.348	0.338	0.343	0.311	0.297	0.284	0.250		
	taud		2.394	2.429	2.452	2.469	2.459	2.452	2.526	2.498	2.591	2.586	2.412	2.369		
	Ebn at Noon		235	269	286	291	289	286	287	279	278	259	220	214		
	Edh at Noon		17	22	27	31	33	33	30	30	24	19	16	14		
(44) All-Sky Solar Radiation	RadAvg		242	539	955	1461	1689	1860	1822	1556	1051	585	276	187		
	RadStd		24	52	62	73	143	142	177	71	90	56	30	17		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+104	N/A

Nomenclature: See separate page