

NECHAKO RIVER, BC, Canada

WMO: 717630

Lat: 53.680N

Lon: 124.830W

Elev: 715

StdP: 93.03

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -34.5	(c) -29.6	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.9	(c) 27.8	(d) N/A	(e) 25.5	(f) N/A	(g) 23.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) N/A	(b) N/A	(c) N/A	(d) WB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.9	-11.4	-5.8	-1.0	3.7	8.5	12.0	14.3	14.0	9.8	3.1	-3.6	-9.0
	DBStd	10.04	9.10	6.39	4.94	2.86	3.51	3.09	2.67	3.20	3.22	3.87	5.53	7.77
	HDD10.0	2982	663	443	340	189	73	14	2	4	42	216	408	588
	HDD18.3	5628	922	676	598	438	306	191	127	139	255	473	658	846
	CDD10.0	401	0	0	0	1	26	73	136	128	37	1	0	0
	CDD18.3	6	0	0	0	0	0	1	2	3	0	0	0	0
	CDH23.3	489	0	0	0	1	20	77	160	213	18	0	0	0
	CDH26.7	112	0	0	0	0	1	16	36	60	0	0	0	0
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(15) Precipitation	PrecAvg	628	63	37	40	35	43	61	60	47	53	62	68	59
	PrecMax	990	231	72	68	63	92	137	126	104	90	105	102	102
	PrecMin	505	26	8	12	15	17	28	19	16	16	22	26	15
	PrecStd	94	35	15	15	13	15	23	25	20	21	19	20	20
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	9.2	14.2	19.7	25.7	29.0	30.3	30.9	25.4	18.3	7.4	5.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	2.8	6.1	11.1	16.5	23.0	25.4	27.2	28.3	23.2	14.0	5.2	3.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	0.4	4.3	8.2	14.0	20.4	22.7	24.8	25.7	21.0	11.8	3.5	1.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-1.1	2.0	6.4	11.7	18.0	20.1	22.6	22.9	18.2	9.5	2.0	-0.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	12.1	12.9	14.6	15.6	14.2	14.9	15.7	15.4	10.8	7.1	8.3
		MCDBR	9.9	13.0	14.5	19.1	20.5	19.3	20.1	21.4	20.8	14.5	8.5	9.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.259	0.272	0.293	0.319	0.339	0.348	0.338	0.343	0.311	0.297	0.284	0.250
	taud		2.394	2.429	2.452	2.469	2.459	2.452	2.526	2.498	2.591	2.586	2.412	2.369
	Ebn at Noon		740	849	902	916	910	901	905	880	876	815	693	674
	Edh at Noon		53	70	86	97	103	105	96	93	75	61	52	44
(44) All-Sky Solar Radiation	RadAvg		0.76	1.70	3.01	4.61	5.32	5.86	5.75	4.90	3.31	1.84	0.87	0.59
	RadStd		0.08	0.16	0.19	0.23	0.45	0.45	0.56	0.22	0.28	0.18	0.09	0.05

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+58	N/A

Nomenclature: See separate page