

LYTTON, BC, Canada

WMO: 717650

Lat: 50.2244N

Lon: 121.5819W

Elev: 738

StdP: 14.31

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.7	9.0	-8.7	3.5	6.9	-2.3	5.0	11.0	31.5	42.5	29.1	41.9	7.3	0	0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.0	95.7	65.0	91.7	64.1	87.7	62.7	66.9	89.6	65.3	87.1	63.8	84.2	12.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.6	78.4	70.1	57.7	73.1	69.9	55.9	68.3	69.3	31.7	90.5	30.5	87.0	29.4	84.3	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.8	28.1	25.7	DB	0.6	102.3	6.7	3.1	-4.2	104.5	-8.1	106.3	-11.8	108.0	-16.6	110.2	
			WB	-0.6	69.5	6.4	2.1	-5.2	71.0	-9.0	72.2	-12.6	73.4	-17.3	74.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	30.2	34.6	42.5	50.5	59.3	65.2	72.5	71.8	62.9	49.7	38.2	30.1
	DBStd	16.72	10.58	7.93	6.98	5.66	6.52	6.35	6.53	6.12	6.45	6.01	8.58	9.57
	HDD50	2406	613	432	242	60	5	0	0	0	1	78	357	618
	HDD65	5839	1078	852	698	435	201	72	14	15	114	474	804	1082
	CDD50	2668	0	0	9	76	294	457	697	676	387	69	3	0
	CDD65	625	0	0	0	0	25	79	245	226	50	0	0	0
	CDH74	7112	0	0	0	37	406	938	2766	2393	568	4	0	0
	CDH80	3213	0	0	0	7	131	398	1362	1118	197	0	0	0
Wind	WSAvg	10.7	7.4	7.7	11.3	12.6	12.9	14.6	14.0	12.5	10.1	9.8	8.4	7.1
Precipitation	PrecAvg	17.9	2.8	1.9	1.3	0.8	0.7	0.7	0.6	0.7	1.1	1.5	2.7	3.0
	PrecMax	25.1	7.6	5.9	3.1	1.7	1.8	3.8	1.7	1.3	2.6	3.7	6.5	6.6
	PrecMin	10.7	0.2	0.5	0.4	0.1	0.1	0.0	0.0	0.0	0.1	0.0	0.2	0.3
	PrecStd	4.4	1.9	1.3	0.7	0.4	0.4	0.8	0.5	0.4	0.7	1.0	1.9	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	54.2	66.5	79.0	89.9	96.9	101.8	99.6	91.3	71.9	57.7	51.0
		MCWB	45.1	45.2	50.5	55.7	61.2	64.6	67.7	66.3	63.4	57.0	50.9	45.1
	2%	DB	48.0	50.2	60.2	71.8	83.8	89.9	96.8	94.9	85.9	66.1	53.6	46.9
		MCWB	43.1	43.6	47.8	52.8	58.9	62.6	65.3	65.0	61.6	53.4	48.4	42.6
	5%	DB	45.0	47.5	56.2	66.1	78.4	84.1	92.3	90.8	80.7	62.0	51.1	44.2
		MCWB	41.1	41.8	45.7	49.9	57.1	60.2	64.6	64.0	60.0	51.9	46.6	40.8
	10%	DB	42.5	44.9	52.9	61.9	73.1	78.7	87.9	86.5	75.7	59.0	48.6	41.9
		MCWB	39.4	40.0	44.2	48.3	55.1	58.8	63.1	62.8	58.3	50.5	44.7	39.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.0	47.1	51.8	57.2	62.6	66.1	70.4	68.4	64.8	58.5	52.6	45.8
		MCDB	50.0	51.6	62.7	76.0	84.5	91.4	93.4	91.5	84.5	66.8	55.9	49.5
	2%	WB	43.5	44.6	49.0	53.9	60.1	63.7	67.6	66.5	63.0	56.0	49.0	43.0
		MCDB	47.4	49.0	58.1	68.4	79.8	85.9	90.0	88.9	80.7	63.7	52.6	46.3
	5%	WB	41.5	42.3	46.8	51.5	58.2	61.7	65.7	65.1	61.3	53.3	47.0	41.0
		MCDB	44.7	46.6	54.4	64.1	74.9	80.5	87.8	86.7	77.4	60.3	50.6	43.9
	10%	WB	39.5	40.4	44.8	49.3	56.4	59.8	64.1	63.7	59.5	51.2	45.1	39.1
		MCDB	42.3	44.7	51.9	60.3	70.8	76.4	84.6	83.8	73.6	57.6	48.4	41.8
Mean Daily Temperature Range	5% DB	MDBR	9.6	13.3	16.8	20.3	22.0	20.7	24.0	24.3	22.2	15.4	10.0	8.8
		MCDBR	12.7	15.7	23.2	30.8	33.3	33.3	34.1	34.3	33.2	20.5	11.8	11.0
	5% WB	MCWBR	9.3	9.9	12.3	14.3	13.0	11.8	10.4	10.9	12.5	10.6	7.8	7.8
		MCWBR	12.3	14.6	20.8	27.2	29.0	29.3	30.5	30.5	28.8	17.7	11.0	10.8
Clear-Sky Solar Irradiance	taub		0.296	0.303	0.332	0.380	0.391	0.380	0.367	0.369	0.354	0.355	0.315	0.287
	taud		2.281	2.312	2.271	2.158	2.264	2.367	2.426	2.439	2.464	2.388	2.380	2.319
	Ebn at Noon		232	265	276	272	275	279	280	274	267	241	225	218
	Edh at Noon		22	28	34	43	41	37	34	32	29	26	20	18
All-Sky Solar Radiation	RadAvg		317	611	979	1428	1724	1844	2042	1741	1212	702	339	243
	RadStd		34	52	80	118	143	170	165	109	101	75	38	28

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+94
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page