

SHERINGHAM POINT, BC, Canada

WMO: 717800

Lat: 48.3767N

Lon: 123.9211W

Elev: 23

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	28.9	32.2	13.1	10.7	33.9	19.2	14.4	35.6	42.2	45.1	35.8	46.7	9.8	90	0.679

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	71.1	61.6	66.7	60.2	63.6	59.2	63.6	68.1	61.6	65.0	60.1	62.9	7.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.8	82.6	65.1	60.2	77.9	62.8	58.8	74.0	61.0	28.9	68.2	27.5	65.1	26.4	63.2	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
31.9	28.2	25.3	DB	25.7	81.0	4.8	4.1	22.3	84.0	19.5	86.4	16.8	88.6	13.4	91.6	
			WB	22.8	66.8	4.8	2.5	19.3	68.6	16.5	70.0	13.8	71.4	10.3	73.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	43.5	43.7	45.4	48.1	51.4	54.5	56.6	57.5	56.3	51.5	46.7	43.0	(6)
(7)		DBStd	6.55	4.94	4.32	3.83	3.48	3.56	3.53	3.51	3.32	3.27	3.37	4.50	4.74	(7)
(8)		HDD50	990	205	179	150	77	23	1	0	0	0	22	115	218	(8)
(9)		HDD65	5527	666	598	608	508	421	317	263	235	262	419	549	681	(9)
(10)		CDD50	947	4	2	6	19	67	136	205	233	190	68	15	2	(10)
(11)		CDD65	8	0	0	0	0	0	2	3	2	1	0	0	0	(11)
(12)		CDH74	57	0	0	0	0	0	15	22	16	4	0	0	0	(12)
(13)		CDH80	7	0	0	0	0	0	2	3	2	0	0	0	0	(13)
(14)	Wind	WSAvg	10.2	9.0	9.0	9.5	10.4	12.1	13.2	14.4	12.3	8.1	7.4	8.2	8.6	(14)
(15)	Precipitation	PrecAvg	76.9	12.3	8.8	7.0	5.0	2.4	1.9	1.3	1.7	3.2	8.5	11.7	12.6	(15)
(16)		PrecMax	94.0	19.1	15.7	11.1	9.0	4.6	4.0	4.4	6.1	7.0	18.5	21.7	18.8	(16)
(17)		PrecMin	48.3	7.2	3.5	2.6	2.2	1.0	0.7	0.5	0.4	0.9	3.4	5.5	6.7	(17)
(18)		PrecStd	10.6	3.2	3.1	2.2	1.7	1.0	0.8	0.8	1.3	1.5	3.5	4.4	2.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.4	55.4	58.1	62.4	68.4	75.6	76.8	75.7	72.7	63.7	59.1	55.6	(19)
(20)			MCWB	51.1	48.0	50.6	53.6	55.2	62.4	65.4	63.9	62.4	57.8	55.9	52.9	(20)
(21)		2%	DB	53.1	52.3	54.3	57.4	62.0	66.5	69.2	69.1	67.6	60.2	55.6	52.0	(21)
(22)			MCWB	50.4	48.2	49.8	52.0	55.2	59.8	62.5	62.0	60.3	54.7	53.6	49.9	(22)
(23)		5%	DB	51.1	50.4	52.0	54.6	58.4	61.1	64.2	65.4	64.0	57.9	53.8	50.1	(23)
(24)			MCWB	48.8	47.5	48.7	50.5	54.3	57.2	60.4	60.6	59.2	54.0	52.2	48.0	(24)
(25)		10%	DB	49.4	48.9	50.3	52.6	55.9	58.6	61.1	62.5	61.5	55.9	52.1	48.6	(25)
(26)			MCWB	47.6	46.8	47.6	49.4	52.9	55.7	58.8	59.6	58.0	53.2	50.6	46.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.7	51.6	53.5	55.0	59.4	63.9	67.0	66.3	65.1	59.4	57.4	53.0	(27)
(28)			MCD B	54.3	52.5	55.0	59.1	62.1	72.5	73.5	71.8	70.6	61.8	58.4	53.7	(28)
(29)		2%	WB	51.1	49.9	51.3	53.0	56.3	60.4	63.4	63.0	62.1	56.9	54.5	50.6	(29)
(30)			MCD B	52.0	51.2	52.9	55.6	59.2	65.2	67.5	66.6	65.6	58.6	55.1	51.3	(30)
(31)		5%	WB	49.5	48.5	49.5	51.4	54.4	57.9	60.6	61.2	60.4	55.2	52.9	48.6	(31)
(32)			MCD B	50.4	49.7	51.0	53.6	57.2	60.6	62.9	64.6	63.1	56.4	53.6	49.3	(32)
(33)		10%	WB	47.8	47.2	48.2	50.1	52.9	56.2	58.7	59.8	58.9	53.8	51.2	47.2	(33)
(34)			MCD B	48.7	48.5	49.7	51.7	55.1	58.1	60.6	62.7	61.2	55.1	52.0	48.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.8	7.4	7.4	7.7	7.9	8.8	9.7	9.8	7.1	6.5	6.2	(35)
(36)			MCDBR	8.1	8.5	9.7	10.9	13.2	13.8	16.0	15.9	15.1	9.5	7.8	7.5	(36)
(37)			MCWBR	6.4	6.4	6.7	6.7	7.7	8.4	9.9	9.6	9.1	6.3	6.5	6.3	(37)
(38)		5% WB	MCDBR	7.6	7.6	8.4	10.0	11.1	12.6	14.0	14.1	13.3	8.4	7.3	7.1	(38)
(39)			MCWBR	6.3	6.2	6.5	6.8	7.5	8.3	9.6	9.5	9.3	6.5	6.8	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.316	0.334	0.363	0.382	0.362	0.351	0.355	0.342	0.334	0.327	0.314	(40)	
(41)		taud	2.510	2.547	2.507	2.414	2.379	2.455	2.526	2.516	2.546	2.554	2.495	2.487	(41)	
(42)		Ebn at Noon	240	270	281	282	279	285	287	281	275	259	233	226	(42)	
(43)		Edh at Noon	20	23	28	34	37	34	31	30	27	23	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	295	576	888	1348	1703	1862	1986	1671	1231	688	354	240	(44)	
(45)		RadStd	40	78	104	123	133	171	133	119	99	81	55	32	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page