

SISTERS ISLAND, BC, Canada

WMO: 717810

Lat: 49.4867N

Lon: 124.4350W

Elev: 66

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	30.3	33.3	16.0	12.4	34.0	21.7	16.3	35.6	51.3	43.9	48.4	44.8	13.8	140	0.696

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	74.5	63.8	72.2	62.8	70.2	62.1	65.6	71.8	64.2	70.1	63.0	68.7	7.3	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	86.0	69.4	61.5	81.8	68.0	60.3	78.2	66.8	30.4	72.3	29.4	70.2	28.5	69.0	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 42.8	38.0	33.8	DB	28.2	79.3	3.5	2.4	25.7	81.1	23.7	82.5	21.7	83.8	19.2	85.6	(4)
(5)			WB	24.5	68.1	4.0	2.4	21.6	69.8	19.3	71.2	17.0	72.5	14.1	74.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	42.3	42.6	45.2	49.4	55.5	60.4	64.7	65.2	59.9	52.2	46.2	42.2		
	DBStd	9.24	4.37	3.76	3.51	3.59	4.52	4.10	3.75	3.32	3.51	3.21	4.29	4.26		
	HDD50	1035	238	209	152	52	6	0	0	0	0	14	123	241		
	HDD65	4770	702	629	614	468	294	151	51	38	159	396	563	705		
	CDD50	1845	1	0	3	34	178	311	455	472	297	83	10	1		
	CDD65	105	0	0	0	0	1	12	41	45	6	0	0	0		
	CDH74	94	0	0	0	0	0	16	47	29	2	0	0	0		
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0		
(14) Wind	WSAvg	14.3	16.4	14.8	15.5	13.9	12.5	13.0	12.2	11.6	12.0	14.9	17.1	17.8		
(15) Precipitation	PrecAvg	42.7	6.7	4.0	3.9	2.4	1.8	1.7	0.9	1.3	1.6	4.6	6.6	6.7		
	PrecMax	53.0	12.6	12.8	8.3	5.1	3.5	3.2	1.7	4.6	5.3	10.2	13.3	9.3		
	PrecMin	30.4	3.4	0.2	0.8	0.7	0.5	0.4	0.1	0.1	0.4	0.7	2.2	3.4		
	PrecStd	6.5	2.4	3.0	1.9	1.3	0.8	0.7	0.5	1.1	1.2	2.3	3.3	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	51.3	55.8	63.5	70.6	76.1	78.6	77.2	72.9	62.4	57.1	53.1		
		MCWB	48.5	47.2	49.1	52.7	56.9	61.4	66.3	63.4	62.7	56.2	52.3	48.8		
	2%	DB	50.3	49.4	52.5	59.0	66.9	71.7	74.7	74.1	69.2	59.5	54.3	50.2		
		MCWB	47.4	45.7	47.8	51.9	56.7	61.2	64.5	64.1	61.5	54.8	51.1	47.2		
	5%	DB	48.6	48.1	50.7	56.3	63.9	68.4	72.2	71.9	66.5	57.7	52.5	48.5		
		MCWB	46.3	44.9	46.8	50.1	55.9	60.0	63.1	63.4	60.1	53.6	50.1	45.9		
	10%	DB	47.4	46.9	49.4	54.2	61.4	65.9	70.0	70.1	64.6	56.2	51.1	47.2		
		MCWB	45.4	44.1	45.8	48.7	54.8	58.8	62.2	62.7	59.1	52.7	49.0	44.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	48.7	50.6	54.8	60.0	64.6	69.5	67.4	64.6	58.0	53.8	50.3		
		MCDB	51.4	50.4	53.5	60.8	66.5	71.4	75.7	73.3	70.6	60.8	55.9	52.3		
	2%	WB	48.1	46.8	49.0	52.8	58.2	62.4	66.0	65.6	62.7	56.1	51.9	47.8		
		MCDB	49.5	48.5	51.5	57.8	63.8	69.0	72.8	71.4	67.7	58.3	53.5	49.3		
	5%	WB	46.8	45.6	47.6	51.0	56.9	60.7	64.3	64.4	61.0	54.6	50.7	46.5		
		MCDB	48.2	47.4	50.1	55.2	62.0	67.0	70.4	69.9	65.3	56.6	52.2	48.2		
	10%	WB	45.6	44.6	46.4	49.4	55.6	59.3	62.9	63.3	59.7	53.4	49.5	45.2		
		MCDB	47.0	46.5	49.1	53.0	60.7	65.0	68.7	68.8	63.7	55.5	51.0	46.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	4.8	5.6	6.8	7.6	7.5	8.3	7.9	6.9	4.9	4.4	4.0		
		MCDBR	5.8	5.9	7.0	9.7	11.2	11.1	11.0	10.4	9.4	6.8	5.8	5.6		
	5% WB	MCWBR	4.1	3.9	4.3	5.4	5.9	6.2	6.3	5.8	5.1	4.3	4.5	4.4		
		MCWBR	5.4	5.1	6.6	9.0	9.5	9.9	9.9	9.4	8.4	6.1	5.4	5.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.311	0.332	0.347	0.369	0.364	0.356	0.357	0.338	0.337	0.318	0.313		
		taud	2.494	2.573	2.521	2.478	2.432	2.464	2.526	2.528	2.574	2.543	2.527	2.466		
	Edn at Noon	Edn at Noon	234	270	280	286	282	284	285	280	275	255	233	219		
		Edh at Noon	19	22	27	32	35	34	31	30	26	23	18	17		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	263	548	813	1265	1647	1777	1955	1675	1174	631	313	205		
	RadStd	RadStd	37	86	108	124	175	200	196	140	102	101	57	30		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-3.65	N/A	N/A	-0.86	N/A	N/A	N/A	N/A
Regional (58 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page