

WEST VANCOUVER, BC, Canada

WMO: 717840

Lat: **49.3470N**Lon: **123.1933W**Elev: **170**StdP: **99.30**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.2	-3.0	-12.2	1.3	-2.3	-8.6	1.8	-1.6	6.1	5.6	5.4	5.5	1.0	10	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.7	27.3	18.0	25.4	17.7	23.8	17.1	19.4	25.2	18.5	23.9	17.7	22.7	0.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	12.5	22.4	16.2	11.8	21.2	15.5	11.2	20.2	55.9	25.3	52.9	24.0	50.3	22.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.6	3.9	3.3	-7.1	31.5	2.8	2.3	-9.1	33.1	-10.7	34.5	-12.2	35.8	-14.2	37.4		
			-7.8	20.5	2.7	1.0	-9.8	21.3	-11.3	21.9	-12.8	22.5	-14.8	23.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	4.3	4.9	6.6	9.2	12.8	15.4	18.2	18.5	15.5	10.5	6.4	3.6
	DBStd	6.01	3.33	2.84	2.70	2.78	3.13	3.09	2.82	2.49	2.92	2.61	3.10	3.26
	HDD10.0	824	178	144	109	47	8	1	0	0	0	26	112	199
	HDD18.3	2938	436	377	363	273	172	99	36	29	95	244	357	457
	CDD10.0	1014	1	1	4	23	96	163	254	262	165	40	5	1
	CDD18.3	87	0	0	0	0	2	12	32	32	9	0	0	0
	CDH23.3	460	0	0	0	2	16	77	176	147	42	0	0	0
	CDH26.7	85	0	0	0	0	2	17	39	22	5	0	0	0
Wind	WSAvg	1.2	1.3	1.2	1.4	1.2	1.1	1.1	1.0	1.0	1.0	1.2	1.4	1.3
Precipitation	PrecAvg	2242	317	207	215	153	105	86	53	72	107	255	347	324
	PrecMax	2835	529	408	401	314	173	168	127	320	234	435	654	469
	PrecMin	1781	177	11	50	56	26	26	12	10	15	41	157	201
	PrecStd	254	83	82	70	58	35	40	30	66	59	93	122	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	13.1	16.4	21.4	25.6	29.1	30.7	29.0	27.1	19.7	14.9	12.5
		MCWB	9.9	8.7	10.6	13.2	15.0	18.0	20.1	18.5	17.0	14.0	11.7	9.7
	2%	DB	10.9	11.1	14.0	18.2	22.4	25.6	27.2	26.6	24.2	17.2	13.0	10.4
		MCWB	9.2	8.0	9.2	11.9	14.9	17.1	18.5	18.2	16.5	12.8	11.1	8.6
	5%	DB	9.7	9.8	12.1	15.6	20.1	22.7	25.1	24.8	22.0	15.6	11.7	8.9
		MCWB	8.4	7.4	8.3	10.4	13.9	16.3	18.0	18.0	16.1	12.2	10.2	7.7
	10%	DB	8.5	8.7	10.6	13.7	18.2	20.7	23.3	23.3	20.1	14.1	10.5	7.8
		MCWB	7.3	6.7	7.8	9.4	13.2	15.3	17.2	17.3	15.0	11.5	9.2	6.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	10.4	11.8	14.7	17.0	19.1	21.2	20.2	18.8	15.5	12.7	10.7
		MCDB	11.7	11.8	14.2	19.5	22.6	26.0	27.8	25.7	24.6	17.8	13.5	11.4
	2%	WB	9.7	8.9	10.3	12.4	15.6	17.8	19.8	19.2	17.5	14.0	11.6	9.0
		MCDB	10.5	10.3	12.6	16.8	20.6	24.1	25.6	24.7	22.4	15.9	12.6	10.0
	5%	WB	8.6	7.9	9.1	11.1	14.5	16.7	18.7	18.4	16.5	12.9	10.5	7.8
		MCDB	9.4	9.3	11.1	14.7	18.9	22.1	23.9	23.6	20.8	14.6	11.7	8.7
	10%	WB	7.5	7.0	8.2	10.0	13.5	15.5	17.7	17.6	15.6	11.9	9.4	6.9
		MCDB	8.3	8.3	10.0	12.8	17.6	20.2	22.5	22.5	19.2	13.7	10.4	7.7
Mean Daily Temperature Range	5% DB	MDBR	4.5	5.9	6.6	7.8	8.4	8.3	8.9	8.7	7.9	6.1	4.9	4.3
		MCDBR	5.7	7.5	8.5	10.7	11.3	11.5	11.4	10.9	10.5	7.9	5.9	5.2
		MCWBR	3.9	4.9	5.1	6.1	6.2	6.1	5.8	5.6	5.6	4.8	4.1	3.8
	5% WB	MCDBR	5.1	6.2	7.6	9.6	10.0	10.8	10.7	10.3	9.4	7.1	5.0	4.8
		MCWBR	3.9	4.3	5.0	5.8	5.9	6.1	6.0	5.7	5.3	4.7	3.8	3.9
Clear-Sky Solar Irradiance	taub	0.311	0.304	0.323	0.355	0.376	0.357	0.354	0.357	0.340	0.330	0.314	0.299	
	taud	2.417	2.481	2.451	2.389	2.375	2.454	2.486	2.493	2.543	2.552	2.505	2.443	
	Ebn at Noon	742	853	892	893	884	902	900	882	865	813	739	707	
	Edh at Noon	64	76	92	109	115	107	103	97	84	71	59	55	
All-Sky Solar Radiation	RadAvg	0.84	1.70	2.52	3.95	5.19	5.55	6.24	5.30	3.65	2.00	0.99	0.67	
	RadStd	0.14	0.27	0.36	0.44	0.46	0.69	0.57	0.43	0.33	0.29	0.19	0.11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.59	N/A	-2.96	N/A	N/A	N/A	N/A	N/A	+152	N/A
(47)	Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page