

WHITE ROCK, BC, Canada

WMO: 717850

Lat: 49.0181N

Lon: 122.7839W

Elev: 43

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.8	26.9	4.2	6.8	29.0	11.4	9.9	30.7	18.3	48.6	15.7	48.8	5.0	70	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	77.0	65.6	74.0	64.3	71.8	63.2	67.3	74.5	65.6	72.3	64.2	70.3	4.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.4	90.5	71.2	62.7	85.4	69.2	61.4	81.5	67.8	31.7	74.8	30.4	72.5	29.3	70.4	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	10.8	8.8	DB	19.0	86.4	4.4	4.0	15.9	89.3	13.3	91.6	10.8	93.8	7.6	96.7	(4)
(5)			WB	16.4	70.1	4.8	1.8	12.9	71.4	10.1	72.5	7.5	73.5	4.0	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	41.1	42.2	45.7	50.1	55.6	60.0	63.9	63.9	59.2	51.6	45.1	40.3
	DBStd	9.64	6.29	5.17	4.66	4.00	4.15	3.75	3.42	3.04	3.67	4.20	5.89	5.97
	HDD50	1194	278	221	147	46	5	0	0	0	0	31	162	304
	HDD65	4951	740	639	600	448	293	157	62	57	176	416	596	767
	CDD50	1782	3	2	12	48	178	301	430	432	277	81	16	2
	CDD65	62	0	0	0	0	1	8	27	23	3	0	0	0
	CDH74	288	0	0	0	1	9	44	122	92	20	0	0	0
	CDH80	50	0	0	0	0	1	6	24	16	3	0	0	0
Wind	WSAvg	3.4	3.8	3.8	4.1	3.6	3.2	3.2	3.1	2.8	2.6	3.1	3.9	4.1
Precipitation	PrecAvg	41.3	5.6	4.0	3.5	2.9	2.4	2.0	1.3	1.6	2.0	4.0	5.9	5.9
	PrecMax	52.7	10.3	9.4	7.0	5.7	5.4	5.4	3.3	5.2	5.3	11.3	10.6	10.5
	PrecMin	29.7	1.1	0.2	0.9	0.7	0.5	0.5	0.0	0.0	0.2	0.5	2.1	1.3
	PrecStd	6.1	2.2	2.0	1.3	1.1	1.1	1.2	0.9	1.4	1.2	2.1	2.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	56.7	62.4	69.5	74.6	79.7	83.0	81.6	76.7	66.7	60.2	55.7
		MCWB	51.7	48.4	51.5	57.7	60.5	65.3	68.0	65.7	63.5	57.1	54.9	52.6
	2%	DB	52.8	53.3	57.6	63.1	69.6	73.8	76.9	76.0	72.0	62.9	56.6	51.8
		MCWB	49.9	47.6	50.1	53.8	59.4	63.6	66.4	65.7	62.5	56.8	53.9	49.0
	5%	DB	50.9	51.1	54.6	60.0	66.2	70.2	73.7	73.3	69.0	60.3	54.6	49.6
		MCWB	48.3	47.0	49.1	52.6	58.3	61.5	64.9	64.6	61.6	55.1	52.5	47.0
	10%	DB	49.0	49.1	52.5	57.3	63.5	67.5	71.5	71.1	66.4	58.2	52.8	47.8
		MCWB	46.9	45.8	48.0	51.0	56.8	59.9	63.5	63.5	60.3	54.2	50.5	45.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.2	51.8	54.1	58.7	63.1	67.3	70.5	68.9	66.3	60.8	56.7	53.4
		MCDB	54.4	53.8	58.4	66.7	70.3	75.8	77.7	76.0	72.8	63.7	58.4	55.4
	2%	WB	50.7	49.4	52.0	55.5	60.7	64.4	67.7	66.9	64.0	58.0	54.6	49.8
		MCDB	52.0	51.7	55.9	60.7	67.0	71.5	75.2	73.8	69.7	60.8	56.1	51.4
	5%	WB	48.7	47.6	50.2	53.7	59.0	62.3	65.7	65.5	62.5	56.3	52.9	47.6
		MCDB	50.2	49.9	53.6	58.4	65.1	68.7	72.5	71.9	67.4	58.9	54.5	49.0
	10%	WB	47.1	46.4	48.6	52.0	57.4	60.6	64.1	64.1	61.0	54.7	50.9	45.9
		MCDB	48.8	48.7	51.8	56.3	62.9	66.7	70.3	69.9	65.3	57.4	52.4	47.5
Mean Daily Temperature Range	5% DB	MDBR	8.9	11.0	11.8	13.0	13.5	13.1	14.2	14.3	13.9	11.5	9.8	8.6
		MCDBR	9.7	13.4	15.1	18.5	19.0	18.1	18.5	18.4	18.7	14.4	10.5	9.4
		MCWBR	7.0	9.0	9.4	11.2	10.8	9.8	9.8	9.9	10.6	9.0	7.5	7.0
	5% WB	MCDBR	8.3	10.8	13.4	16.5	17.2	17.0	18.0	17.3	16.7	12.2	9.1	8.6
		MCWBR	6.6	7.8	9.0	10.6	10.3	9.8	10.3	10.1	10.3	8.5	7.2	7.1
Clear-Sky Solar Irradiance	taub	0.322	0.317	0.331	0.364	0.393	0.365	0.362	0.368	0.350	0.337	0.323	0.312	
	taud	2.472	2.529	2.505	2.397	2.329	2.427	2.455	2.455	2.499	2.526	2.498	2.464	
	Ebn at Noon	235	268	281	280	275	284	283	276	271	255	232	221	
	Edh at Noon	20	23	28	35	38	35	34	32	28	23	19	18	
All-Sky Solar Radiation	RadAvg	278	552	838	1295	1685	1817	2018	1709	1193	655	328	222	
	RadStd	43	81	111	134	142	204	167	128	104	85	58	33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page