

VICTORIA INTL, BC, Canada

WMO: 717990

Lat: 48.650N

Lon: 123.430W

Elev: 64

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.6	28.4	11.9	10.1	32.3	18.2	13.8	33.1	27.5	39.9	24.2	40.8	8.2	50	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	80.3	63.8	76.6	62.4	73.6	61.1	64.6	77.9	63.1	74.8	61.8	72.1	6.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.1	75.0	67.8	57.8	71.6	67.0	56.8	68.8	66.2	29.7	78.3	28.5	75.2	27.6	72.2	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.4	17.3	14.6	DB	21.0	87.8	3.8	3.7	18.3	90.4	16.0	92.6	13.9	94.7	11.1	97.4
			WB	19.5	67.7	3.9	1.5	16.7	68.7	14.4	69.6	12.2	70.4	9.3	71.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	40.5	41.1	44.2	48.4	54.4	59.3	63.1	62.8	58.1	50.3	44.0	39.9	
	DBStd	9.52	5.34	4.64	4.34	4.16	4.48	4.18	3.77	3.46	3.86	4.09	5.31	5.32	
	HDD50	1368	294	251	184	78	12	0	0	0	0	46	190	313	
	HDD65	5324	758	671	644	499	330	181	82	86	210	455	631	777	
	CDD50	1575	1	1	5	29	148	278	407	397	243	56	9	1	
	CDD65	54	0	0	0	0	0	9	24	18	3	0	0	0	
	CDH74	642	0	0	0	1	16	116	258	206	45	0	0	0	
	CDH80	126	0	0	0	0	1	28	58	35	4	0	0	0	
Wind	WSAvg	6.1	6.3	6.5	6.9	6.6	6.1	6.2	5.7	5.3	4.9	5.5	6.3	7.0	
Precipitation	PrecAvg	36.2	5.7	3.6	3.2	1.9	1.4	1.1	0.7	1.1	1.6	4.0	6.1	5.9	
	PrecMax	47.1	9.5	8.9	6.4	4.1	3.0	2.6	1.6	3.5	5.1	12.2	13.3	9.4	
	PrecMin	25.5	2.4	0.7	0.9	0.2	0.2	0.3	0.1	0.1	0.2	0.6	2.3	2.6	
	PrecStd	5.7	1.9	1.7	1.2	0.9	0.7	0.5	0.4	0.9	1.2	2.4	3.0	1.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	54.5	61.0	69.4	76.2	84.1	86.4	84.4	79.0	66.6	58.7	54.6	
		MCWB	50.3	47.9	51.0	55.9	59.7	63.3	66.4	64.9	61.7	54.4	54.1	50.7	
	2%	DB	51.6	51.7	56.3	62.9	71.1	76.8	80.2	79.1	74.1	62.6	55.4	51.1	
		MCWB	48.3	46.9	49.1	52.4	57.8	61.5	64.4	63.9	60.5	54.2	52.2	48.0	
	5%	DB	49.7	49.9	53.6	59.4	67.2	71.8	76.2	75.6	70.5	59.7	53.1	48.9	
		MCWB	47.1	45.8	47.7	50.8	56.4	59.5	62.6	62.7	59.5	53.4	50.2	46.3	
	10%	DB	47.9	48.3	51.5	56.4	63.9	68.2	72.9	72.6	67.2	57.3	51.4	47.2	
		MCWB	45.8	44.9	46.5	49.1	54.8	57.7	61.1	61.4	58.1	52.5	48.9	44.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.5	50.4	52.7	56.7	61.0	64.7	67.5	66.2	63.9	58.5	55.2	51.6
			MCDB	53.4	52.4	57.9	66.9	72.5	79.8	83.9	80.7	73.9	62.2	57.2	53.5
2%		WB	49.2	48.4	50.4	53.8	58.9	62.1	65.0	64.4	61.9	56.1	52.8	48.7	
		MCDB	50.7	50.3	54.5	61.2	69.1	75.4	78.8	77.3	71.3	59.4	54.7	50.5	
5%		WB	47.5	46.7	48.8	51.8	57.1	60.0	63.1	63.1	60.3	54.4	51.0	46.9	
		MCDB	49.1	48.9	52.5	57.5	65.6	70.7	74.8	74.4	68.4	58.0	52.5	48.5	
10%		WB	45.9	45.3	47.4	50.2	55.4	58.3	61.6	61.7	58.8	53.0	49.5	45.2	
		MCDB	47.6	47.6	50.8	55.2	63.0	67.2	71.8	71.6	65.6	56.6	51.0	46.9	
Mean Daily Temperature Range	5% DB	MDBR	9.4	11.6	12.7	14.6	16.0	16.2	18.0	18.0	16.8	13.0	10.7	9.1	
		MCDBR	10.6	13.4	15.4	19.8	22.4	23.5	24.3	24.0	22.8	16.3	11.4	9.2	
		MCWBR	8.1	9.3	9.9	11.5	11.9	11.1	11.2	11.4	11.7	9.9	8.5	7.5	
	5% WB	MCDDBR	9.5	10.7	13.6	17.2	19.5	21.0	22.6	21.9	19.5	13.3	9.9	8.6	
		MCWBR	7.7	8.1	9.4	10.6	10.8	10.5	10.9	11.0	10.9	9.0	7.9	7.3	
Clear-Sky Solar Irradiance	taub	0.319	0.315	0.332	0.361	0.379	0.357	0.349	0.355	0.340	0.333	0.322	0.312		
	taud	2.521	2.558	2.523	2.430	2.397	2.473	2.532	2.515	2.557	2.560	2.522	2.499		
	Ebn at Noon	239	270	282	282	280	286	287	281	276	259	235	225		
	Edh at Noon	19	23	28	33	36	34	31	30	27	23	19	17		
All-Sky Solar Radiation	RadAvg	289	568	882	1344	1728	1882	2064	1742	1233	677	345	232		
	RadStd	40	78	107	129	138	186	151	117	102	78	56	31		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.50	N/A	N/A	N/A	+14
(47)	Regional (75 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page