

VICTORIA INTL, BC, Canada

WMO: 717990

Lat: 48.650N

Lon: 123.430W

Elev: 20

StdP: 101.09

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.6	-2.0	-11.2	1.4	0.2	-7.7	2.0	0.6	12.3	4.4	10.8	4.9	3.7	50	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	26.8	17.7	24.8	16.9	23.1	16.2	18.1	25.5	17.3	23.8	16.5	22.3	2.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.1	10.7	19.9	14.3	10.2	19.5	13.8	9.8	19.0	51.1	25.7	48.5	24.0	46.3	22.4	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.7	6.5	-6.1	31.0	2.1	2.1	-7.6	32.5	-8.9	33.7	-10.1	34.8	-11.6	36.3		
			-6.9	19.8	2.2	0.8	-8.5	20.4	-9.8	20.9	-11.0	21.3	-12.6	21.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	4.7	5.0	6.8	9.1	12.4	15.1	17.3	17.1	14.5	10.2	6.7	4.4
	DBStd	5.29	2.97	2.58	2.41	2.31	2.49	2.32	2.10	1.92	2.14	2.27	2.95	2.96
	HDD10.0	760	163	139	102	43	7	0	0	0	0	26	106	174
	HDD18.3	2958	421	373	358	277	183	101	46	48	117	253	351	432
	CDD10.0	875	1	1	3	16	82	154	226	221	135	31	5	1
	CDD18.3	30	0	0	0	0	0	5	13	10	2	0	0	0
	CDH23.3	357	0	0	0	1	9	64	143	114	25	0	0	0
	CDH26.7	70	0	0	0	0	1	16	32	19	2	0	0	0
Wind	WSAvg	2.7	2.8	2.9	3.1	3.0	2.7	2.8	2.5	2.4	2.2	2.5	2.8	3.1
Precipitation	PrecAvg	920	144	91	82	49	35	29	17	27	40	101	154	150
	PrecMax	1196	242	225	163	105	75	65	41	88	129	309	339	240
	PrecMin	648	61	17	23	6	5	8	2	3	4	15	58	66
	PrecStd	144	48	42	30	24	19	13	10	22	31	60	77	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	12.5	16.1	20.8	24.5	28.9	30.2	29.1	26.1	19.2	14.8	12.5
		MCWB	10.2	8.8	10.5	13.3	15.4	17.4	19.1	18.3	16.5	12.4	12.3	10.4
	2%	DB	10.9	11.0	13.5	17.2	21.7	24.9	26.8	26.2	23.4	17.0	13.0	10.6
		MCWB	9.0	8.3	9.5	11.3	14.3	16.4	18.0	17.7	15.9	12.3	11.2	8.9
	5%	DB	9.8	10.0	12.0	15.2	19.6	22.1	24.5	24.2	21.4	15.4	11.7	9.4
		MCWB	8.4	7.6	8.7	10.4	13.6	15.3	17.0	17.0	15.3	11.9	10.1	8.0
	10%	DB	8.9	9.0	10.8	13.6	17.7	20.1	22.7	22.5	19.6	14.1	10.8	8.5
		MCWB	7.6	7.2	8.1	9.5	12.7	14.3	16.2	16.3	14.5	11.4	9.4	7.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.8	10.2	11.5	13.7	16.1	18.1	19.7	19.0	17.7	14.7	12.9	10.9
		MCDB	11.9	11.4	14.4	19.4	22.5	26.6	28.8	27.1	23.3	16.8	14.0	12.0
	2%	WB	9.5	9.1	10.2	12.1	14.9	16.7	18.3	18.0	16.6	13.4	11.6	9.3
		MCDB	10.4	10.2	12.5	16.2	20.6	24.1	26.0	25.2	21.8	15.2	12.6	10.3
	5%	WB	8.6	8.2	9.3	11.0	13.9	15.6	17.3	17.3	15.7	12.4	10.5	8.3
		MCDB	9.5	9.4	11.4	14.2	18.7	21.5	23.8	23.6	20.2	14.4	11.4	9.2
	10%	WB	7.7	7.4	8.5	10.1	13.0	14.6	16.4	16.5	14.9	11.7	9.7	7.4
		MCDB	8.7	8.7	10.5	12.9	17.2	19.5	22.1	22.0	18.7	13.6	10.6	8.3
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.4	7.0	8.1	8.9	9.0	10.0	9.3	7.2	5.9	5.0	
		MCDBR	5.9	7.4	8.6	11.0	12.4	13.0	13.5	13.4	12.7	9.1	6.3	5.1
		MCWBR	4.5	5.2	5.5	6.4	6.6	6.2	6.2	6.3	6.5	5.5	4.7	4.1
	5% WB	MCDBR	5.3	5.9	7.5	9.5	10.8	11.7	12.5	12.2	10.9	7.4	5.5	4.8
		MCWBR	4.3	4.5	5.2	5.9	6.0	5.8	6.1	6.1	6.1	5.0	4.4	4.0
Clear-Sky Solar Irradiance	taub	0.319	0.315	0.332	0.361	0.379	0.357	0.349	0.355	0.340	0.333	0.322	0.312	
	taud	2.521	2.558	2.523	2.430	2.397	2.473	2.532	2.515	2.557	2.560	2.522	2.499	
	Ebn at Noon	755	851	889	890	882	903	906	886	870	816	741	710	
	Edh at Noon	61	72	87	105	113	106	98	96	84	71	60	55	
All-Sky Solar Radiation	RadAvg	0.91	1.79	2.78	4.24	5.45	5.93	6.51	5.49	3.89	2.13	1.09	0.73	
	RadStd	0.13	0.25	0.34	0.41	0.44	0.59	0.48	0.37	0.32	0.25	0.17	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.28	N/A	N/A	N/A	+8
(47) Regional (75 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page