

CAPE RACE, NL, Canada

WMO: 718000

Lat: 46.6602N

Lon: 53.0755W

Elev: 27

StdP: 101.01

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.7	-10.5	-16.3	0.9	-11.6	-14.2	1.1	-9.8	25.9	-2.5	24.0	-2.2	8.0	320	1.011

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	19.9	17.0	18.4	16.5	17.2	15.9	17.9	19.0	17.0	17.8	16.1	16.8	8.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.5	18.4	16.6	11.8	17.4	15.8	11.2	16.6	50.7	19.1	47.8	17.8	45.3	16.9	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	18.6	16.3	DB	-16.0	24.2	2.4	2.0	-17.8	25.7	-19.2	26.8	-20.6	27.9	-22.4	29.4	(4)
(5)			WB	-16.1	19.7	2.6	2.0	-18.0	21.1	-19.5	22.2	-21.0	23.3	-22.9	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-2.4	-3.1	-1.7	1.3	4.4	8.2	12.7	14.8	12.3	8.3	4.3	0.2	(6)
(7)		DBStd	6.66	3.51	3.66	3.20	2.09	2.12	2.42	2.45	2.02	2.71	3.01	3.20	3.66	(7)
(8)		HDD10.0	2172	384	366	362	259	174	65	4	0	10	69	173	304	(8)
(9)		HDD18.3	4868	643	599	621	509	432	306	174	109	180	311	422	562	(9)
(10)		CDD10.0	347	0	0	0	0	0	10	89	150	80	17	1	0	(10)
(11)		CDD18.3	2	0	0	0	0	0	0	0	1	1	0	0	0	(11)
(12)		CDH23.3	5	0	0	0	0	0	0	2	1	2	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	8.4	10.0	9.9	9.5	8.6	7.9	7.3	7.0	7.1	7.6	8.4	8.7	9.4	(14)
(15)	Precipitation	PrecAvg	1415	122	103	108	111	107	101	112	105	120	145	139	141	(15)
(16)		PrecMax	1586	205	159	184	253	177	186	197	162	256	227	203	220	(16)
(17)		PrecMin	1238	58	50	40	48	44	41	36	44	52	92	63	74	(17)
(18)		PrecStd	97	37	25	32	45	31	38	42	28	45	41	45	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	5.3	5.8	9.2	14.0	17.7	22.2	22.4	21.2	16.3	12.6	8.8	(19)
(20)			MCWB	6.1	5.0	4.1	5.7	9.6	14.0	18.2	18.7	17.8	14.4	12.2	8.6	(20)
(21)		2%	DB	4.7	3.6	4.0	6.5	10.5	14.6	19.2	20.2	18.2	14.6	11.2	7.4	(21)
(22)			MCWB	4.4	3.3	3.0	5.1	8.0	12.3	16.7	17.4	16.2	13.6	10.8	7.1	(22)
(23)		5%	DB	3.4	2.5	3.0	5.3	8.9	13.0	17.5	18.8	17.0	13.6	10.1	6.3	(23)
(24)			MCWB	3.1	2.1	2.3	4.2	7.3	11.2	15.9	17.0	15.5	12.7	9.7	5.9	(24)
(25)		10%	DB	2.3	1.5	2.1	4.3	7.5	11.6	16.1	17.6	16.0	12.6	9.1	5.1	(25)
(26)			MCWB	1.9	1.1	1.5	3.4	6.4	10.3	15.0	16.4	14.9	11.7	8.6	4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.1	4.8	7.1	10.3	15.0	19.4	19.6	18.6	15.2	12.1	8.8	(27)
(28)			MCD B	6.2	5.3	5.3	7.9	12.1	16.7	21.0	21.0	20.2	15.6	12.2	8.9	(28)
(29)		2%	WB	4.4	3.4	3.4	5.7	8.8	13.0	17.4	18.1	17.0	14.1	10.6	7.2	(29)
(30)			MCD B	4.5	3.6	3.9	6.2	9.9	14.1	18.3	19.2	17.7	14.5	10.8	7.3	(30)
(31)		5%	WB	3.0	2.2	2.5	4.6	7.7	11.7	16.1	17.3	15.9	12.9	9.7	5.8	(31)
(32)			MCD B	3.2	2.4	2.9	5.2	8.7	12.6	16.9	18.2	16.6	13.4	9.9	6.1	(32)
(33)		10%	WB	1.9	1.1	1.7	3.6	6.6	10.6	15.0	16.5	15.1	11.9	8.7	4.3	(33)
(34)			MCD B	2.1	1.4	2.1	4.2	7.6	11.4	15.8	17.3	15.7	12.5	9.0	4.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.9	5.6	5.3	4.9	5.4	5.6	5.5	5.2	5.9	5.5	5.3	5.4	(35)
(36)			MCD BR	6.5	5.7	5.6	6.7	8.4	8.4	8.2	7.3	6.9	5.9	5.3	5.7	(36)
(37)			MCWBR	7.0	5.5	5.0	5.3	6.1	6.1	6.1	5.4	5.4	5.0	5.6	6.6	(37)
(38)		5% WB	MCD BR	6.5	5.3	5.4	6.3	7.6	7.6	7.1	6.4	6.2	5.4	5.3	6.1	(38)
(39)			MCWBR	6.9	5.7	5.1	5.4	6.0	6.2	5.8	5.1	5.3	5.0	5.6	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.329	0.344	0.373	0.380	0.410	0.446	0.406	0.375	0.360	0.338	0.322	(40)	
(41)		taud	2.332	2.394	2.405	2.357	2.392	2.335	2.272	2.404	2.455	2.437	2.409	2.359	(41)	
(42)		Ebn at Noon	749	840	881	883	886	857	819	841	838	792	735	711	(42)	
(43)		Edh at Noon	76	87	100	115	115	123	129	109	95	83	71	67	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.96	1.78	2.97	4.08	4.91	5.01	4.82	4.30	3.60	2.25	1.26	0.83	(44)	
(45)		RadStd	0.06	0.11	0.18	0.38	0.37	0.44	0.35	0.31	0.22	0.17	0.17	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.41	N/A	N/A	+1.31	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page