

SAINT-PIERRE, Saint Pierre and Miquelon

WMO: 718050

Lat: 46.7664N

Lon: 56.1792W

Elev: 7

StdP: 101.24

Time Zone: -3.00 (SPM)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.2	-8.8	-14.2	1.1	-8.9	-12.8	1.2	-7.9	22.1	-1.6	20.5	-1.8	9.3	300	0.810

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	21.1	18.1	20.0	17.7	19.0	17.2	19.1	20.2	18.4	19.3	17.6	18.5	5.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.6	19.6	18.0	12.9	18.9	17.2	12.3	18.1	54.4	20.1	52.0	19.4	49.8	18.7	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	15.7	13.9	DB	-12.2	23.9	2.1	1.2	-13.7	24.8	-14.9	25.5	-16.0	26.2	-17.5	27.0	(4)
(5)			WB	-12.7	20.4	2.0	0.7	-14.1	20.9	-15.3	21.3	-16.4	21.7	-17.8	22.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-1.9	-2.7	-1.1	2.2	5.9	9.7	14.4	17.0	14.0	9.5	5.2	0.8
	DBStd	7.04	3.20	3.26	2.91	2.07	2.00	2.24	2.16	1.68	2.46	2.67	2.88	3.22
	HDD10.0	1936	369	356	344	234	127	31	0	0	2	42	144	286
	HDD18.3	4457	628	589	603	484	386	258	122	47	132	273	393	544
	CDD10.0	527	0	0	0	0	1	23	138	217	121	27	1	0
	CDD18.3	7	0	0	0	0	0	0	1	6	1	0	0	0
	CDH23.3	2	0	0	0	0	0	0	1	1	1	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.7	8.6	8.7	7.9	6.7	5.7	5.0	4.5	5.0	6.0	6.7	7.4	8.2
Precipitation	PrecAvg	1305	104	92	95	95	100	96	94	105	120	134	120	113
	PrecMax	1679	182	200	241	244	185	161	179	285	259	260	201	190
	PrecMin	1003	25	13	44	25	40	42	36	34	40	30	28	48
	PrecStd	160	38	48	36	46	34	35	35	50	50	61	40	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.9	6.0	6.0	9.6	14.1	18.9	22.1	22.9	21.2	16.9	12.9	9.6
		MCWB	6.8	5.8	4.4	6.9	9.1	13.9	17.2	18.9	18.5	15.6	12.3	9.4
	2%	DB	5.1	4.1	4.5	7.2	12.0	16.1	20.2	21.6	19.4	15.5	11.4	7.9
		MCWB	4.9	3.7	3.3	5.5	7.9	12.6	16.9	18.6	17.2	14.2	10.9	7.5
	5%	DB	3.7	2.8	3.6	6.2	10.3	14.4	18.8	20.7	18.3	14.5	10.6	6.8
		MCWB	3.3	2.3	2.5	4.9	7.5	11.8	16.4	18.2	16.6	13.5	10.2	6.5
	10%	DB	2.6	1.6	2.6	5.3	9.1	13.2	17.6	19.8	17.5	13.5	9.7	5.6
		MCWB	2.0	1.1	1.6	4.1	7.1	11.3	16.0	17.9	16.0	12.5	9.2	5.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	5.9	5.1	7.6	10.3	15.0	19.1	20.4	19.3	16.1	12.5	9.4
		MCDB	6.8	6.0	5.3	8.6	12.0	17.1	20.5	21.5	20.5	16.4	12.8	9.5
	2%	WB	5.0	3.9	3.7	6.2	9.1	13.5	17.8	19.6	18.1	14.8	11.2	7.6
		MCDB	5.0	4.0	4.2	6.8	10.6	15.0	19.1	20.7	18.9	15.3	11.3	7.7
	5%	WB	3.4	2.4	2.7	5.3	8.2	12.5	17.0	18.9	17.3	13.8	10.3	6.5
		MCDB	3.6	2.6	3.2	5.9	9.6	14.0	18.0	19.9	18.0	14.3	10.5	6.7
	10%	WB	2.1	1.1	1.8	4.4	7.4	11.6	16.3	18.3	16.5	12.7	9.2	5.2
		MCDB	2.4	1.5	2.4	5.0	8.7	12.9	17.2	19.2	17.2	13.3	9.5	5.4
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.6	4.6	5.0	5.6	5.5	4.8	4.8	5.2	4.6	4.4	4.3
		MCDBR	6.1	6.3	5.3	6.2	7.6	7.8	6.8	5.9	5.6	5.3	5.3	5.8
		MCWBR	6.7	6.6	4.7	4.9	4.9	4.9	4.4	3.9	4.4	4.9	5.6	6.3
	5% WB	MCDBR	6.2	6.3	5.2	5.8	6.3	6.6	5.3	4.9	4.9	5.0	5.3	5.7
		MCWBR	6.9	6.8	5.0	5.0	4.7	4.7	3.9	3.7	4.3	5.0	5.8	6.4
Clear-Sky Solar Irradiance	taub	0.323	0.322	0.340	0.367	0.379	0.403	0.433	0.406	0.373	0.356	0.330	0.316	
	taud	2.367	2.442	2.430	2.388	2.406	2.358	2.319	2.400	2.474	2.464	2.461	2.395	
	Ebn at Noon	757	850	886	889	887	863	830	841	840	798	749	721	
	Edh at Noon	73	83	97	111	113	120	123	109	93	81	67	64	
All-Sky Solar Radiation	RadAvg	0.97	1.66	3.00	4.23	5.13	5.20	4.92	4.48	3.69	2.31	1.24	0.80	
	RadStd	0.09	0.15	0.21	0.37	0.43	0.55	0.35	0.31	0.24	0.15	0.16	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page