

WABUSH, NL, Canada

WMO: 718250

Lat: 52.920N

Lon: 66.860W

Elev: 551

StdP: 94.87

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.4	-33.0	-40.2	0.1	-35.1	-37.9	0.1	-32.8	11.2	-18.4	10.1	-17.2	2.2	180	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	25.0	15.9	22.8	14.9	20.9	14.1	17.5	21.9	16.4	20.6	15.4	19.2	5.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	12.2	18.9	14.9	11.3	17.8	13.8	10.5	16.8	51.6	22.0	48.2	20.7	45.2	19.1	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.6	8.0	-39.9	28.6	2.8	1.7	-41.9	29.8	-43.6	30.8	-45.2	31.8	-47.2	33.0		
(5)			-40.0	19.8	2.8	1.1	-42.0	20.6	-43.6	21.2	-45.2	21.9	-47.2	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.2	-20.9	-19.6	-12.8	-4.1	4.5	11.0	14.4	13.4	8.2	1.4	-7.0	-15.7		
	DBStd	13.54	7.39	7.22	7.44	5.69	4.59	4.27	3.03	3.20	3.96	4.21	5.67	7.19		
	HDD10.0	4802	959	830	707	424	181	37	2	7	81	267	510	798		
	HDD18.3	7500	1217	1063	966	674	428	222	128	156	306	524	760	1056		
	CDD10.0	355	0	0	0	0	11	67	138	112	26	2	0	0		
	CDD18.3	12	0	0	0	0	0	3	5	3	1	0	0	0		
	CDH23.3	141	0	0	0	0	9	41	51	32	7	0	0	0		
	CDH26.7	18	0	0	0	0	1	8	6	2	1	0	0	0		
(14) Wind	WSAvg	3.9	3.9	3.8	4.1	4.2	3.8	3.9	3.5	3.5	4.0	4.1	4.1	3.7		
(15) Precipitation	PrecAvg	936	65	49	60	59	64	89	115	95	102	86	80	71		
	PrecMax	1279	103	79	137	151	138	163	197	157	178	154	153	138		
	PrecMin	693	21	11	15	10	27	38	69	46	56	35	35	19		
	PrecStd	136	23	19	27	33	29	30	35	32	32	27	30	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.8	1.2	6.3	12.1	24.6	27.8	27.1	26.6	24.1	15.7	6.7	2.2		
		MCWB	0.3	0.5	2.3	5.2	13.2	16.9	16.7	17.5	16.9	11.2	5.0	1.8		
	2%	DB	-2.4	-1.1	2.5	8.4	20.0	23.8	24.6	23.8	19.4	12.2	3.7	0.2		
		MCWB	-2.8	-1.8	0.5	3.5	11.0	14.9	15.6	16.3	14.3	9.6	3.0	-0.1		
	5%	DB	-5.8	-4.9	0.6	5.9	16.2	21.2	22.7	21.4	16.6	9.8	1.8	-2.3		
		MCWB	-6.4	-5.9	-0.9	2.3	8.9	13.5	15.0	15.1	12.9	7.8	1.1	-2.8		
	10%	DB	-9.0	-8.2	-1.5	3.7	13.0	19.0	20.6	19.4	14.7	7.6	0.6	-5.0		
		MCWB	-9.5	-8.9	-3.0	1.2	7.7	12.3	14.3	14.4	11.6	6.1	0.0	-5.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.5	0.7	2.9	6.0	14.4	18.1	18.8	18.9	17.7	12.6	5.8	1.8		
		MCDB	0.9	0.9	5.0	10.2	21.2	23.8	23.2	23.3	21.4	14.9	6.4	2.1		
	2%	WB	-2.8	-1.9	0.9	4.1	11.8	16.5	17.2	17.5	15.3	10.3	3.1	0.0		
		MCDB	-2.3	-1.1	2.2	7.4	18.2	21.4	21.2	21.8	18.3	11.7	3.5	0.2		
	5%	WB	-6.3	-5.8	-0.9	2.7	9.8	15.0	16.2	16.3	13.8	8.1	1.2	-2.8		
		MCDB	-5.8	-5.0	0.6	5.3	15.0	19.2	20.3	19.7	16.3	9.3	1.6	-2.3		
	10%	WB	-9.5	-8.8	-3.0	1.5	8.0	13.4	15.3	15.0	11.9	6.2	0.1	-5.6		
		MCDB	-9.1	-8.1	-1.6	3.6	12.7	17.6	19.2	18.5	14.1	7.5	0.6	-5.1		
(35) Mean Daily Temperature Range	MDBR		9.9	11.4	12.3	10.4	10.4	10.7	9.6	8.8	8.2	6.1	6.6	8.5		
	5% DB	MCDBR	10.4	10.9	12.0	12.7	17.2	15.3	13.6	12.7	11.9	10.3	6.5	8.6		
		MCWBR	10.2	10.3	10.2	8.8	9.6	7.6	6.4	6.5	7.7	7.8	6.3	8.6		
	5% WB	MCDBR	10.6	10.8	10.7	10.5	14.9	11.9	10.1	10.6	10.9	8.8	6.5	8.6		
		MCWBR	10.4	10.2	9.3	7.7	9.0	6.9	5.8	6.2	8.0	7.4	6.5	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.233	0.250	0.263	0.314	0.339	0.366	0.397	0.359	0.341	0.292	0.252	0.228		
	taud		2.237	2.232	2.228	2.135	2.318	2.389	2.324	2.444	2.469	2.547	2.316	2.207		
	Ebn at Noon		776	873	933	916	909	885	847	866	840	826	743	704		
	Edh at Noon		61	85	106	135	119	113	118	99	86	64	57	52		
(44) All-Sky Solar Radiation	RadAvg		1.11	2.27	3.86	5.16	5.42	5.23	4.73	3.80	2.82	1.57	0.78	0.70		
	RadStd		0.09	0.15	0.27	0.33	0.51	0.37	0.30	0.28	0.27	0.13	0.10	0.09		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page