

PANGNIRTUNG, NU, Canada

WMO: 718260

Lat: 66.143N

Lon: 65.711W

Elev: 74

StdP: 14.66

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.0	-31.5	-43.8	0.4	-34.6	-40.1	0.6	-31.1	32.3	20.6	27.5	13.0	1.8	250	0.956

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	59.1	50.8	55.7	49.0	53.0	47.5	52.0	57.7	49.8	54.4	48.1	52.1	11.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.6	50.7	54.2	46.6	47.2	51.8	45.1	44.5	50.0	21.5	57.9	20.2	54.7	19.3	52.3	62.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	21.0	18.1	-35.3	67.7	4.5	4.5	-38.5	71.0	-41.1	73.7	-43.6	76.2	-46.8	79.5		
(5)			-35.4	56.6	4.5	2.8	-38.7	58.6	-41.3	60.3	-43.8	61.9	-47.0	63.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	-11.0	-13.9	-7.4	8.5	27.1	39.0	46.9	46.1	37.8	26.3	15.4	2.2
	DBStd	23.45	13.71	13.75	14.06	11.46	8.17	4.80	4.74	4.31	4.90	7.10	9.36	13.29
	HDD50	11626	1892	1790	1778	1245	711	332	121	135	368	733	1039	1482
	HDD65	17061	2357	2210	2243	1695	1176	781	561	587	817	1198	1489	1947
	CDD50	39	0	0	0	0	0	1	25	13	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.5	4.6	4.4	4.8	5.8	7.9	8.3	7.9	7.4	7.0	6.8	7.1	5.9
Precipitation	PrecAvg	14.6	0.7	0.5	0.6	0.7	1.1	1.5	1.5	2.0	2.2	1.7	1.2	0.9
	PrecMax	23.7	1.9	1.8	1.8	1.9	2.1	5.0	4.4	4.6	5.8	3.2	3.5	2.5
	PrecMin	6.2	0.1	0.0	0.1	0.0	0.2	0.3	0.4	0.4	0.2	0.5	0.2	0.2
	PrecStd	4.1	0.4	0.4	0.4	0.5	0.5	1.1	0.9	1.1	1.4	0.7	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.7	34.2	37.5	41.1	47.1	57.9	66.9	63.6	52.7	48.2	41.1	38.0
		MCWB	31.9	29.2	33.5	35.8	40.8	47.5	54.7	54.2	44.6	41.0	36.5	33.5
	2%	DB	24.5	22.8	27.2	33.5	42.6	52.4	60.6	58.0	49.0	43.1	36.5	31.6
		MCWB	21.2	20.1	24.4	30.3	37.6	44.8	52.0	50.1	42.6	37.4	32.5	28.1
	5%	DB	16.0	13.0	20.2	29.0	39.7	49.1	56.8	55.2	46.4	38.3	31.8	25.4
		MCWB	13.7	10.9	18.0	26.6	35.7	43.3	50.1	48.8	41.2	34.2	29.1	22.9
	10%	DB	9.4	6.3	12.9	25.0	37.0	46.4	54.1	52.5	44.3	35.5	28.2	20.0
		MCWB	7.8	4.9	11.2	22.8	33.8	41.8	48.5	47.5	40.3	32.5	25.9	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.0	29.5	33.8	36.5	41.2	48.7	56.5	55.0	46.0	42.0	37.3	33.9
		MCDB	37.0	33.8	37.3	40.5	46.2	55.3	65.4	61.8	50.6	47.7	40.7	38.3
	2%	WB	21.2	20.1	24.3	30.6	38.1	45.7	53.2	51.3	43.7	37.9	32.7	28.3
		MCDB	24.3	22.7	26.9	33.2	41.9	51.2	59.0	56.4	47.5	42.2	36.1	31.5
	5%	WB	13.8	10.9	18.1	26.6	35.9	43.6	50.8	49.5	42.2	34.9	29.1	22.9
		MCDB	16.0	12.9	20.1	28.8	39.2	48.4	56.0	53.7	45.3	37.7	31.5	25.1
	10%	WB	7.8	4.9	11.2	22.8	34.1	42.0	48.9	48.0	40.7	32.8	25.8	17.9
		MCDB	9.4	6.3	12.9	25.0	36.5	46.2	53.3	51.7	43.7	35.1	28.2	20.0
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.2	11.1	12.1	9.0	9.1	10.2	8.9	7.0	6.6	7.7	9.3
		MCDBR	17.5	18.2	17.6	13.0	11.3	14.0	15.3	13.7	9.6	8.5	10.6	12.5
		MCWBR	15.5	16.2	15.4	10.9	7.9	9.0	9.3	8.4	6.4	6.3	9.1	10.7
	5% WB	MCDBR	17.4	18.0	17.8	12.9	10.6	13.0	14.6	12.1	8.9	8.1	10.4	12.7
		MCWBR	15.5	16.2	15.8	10.9	7.7	8.8	9.5	8.2	6.2	6.3	9.2	11.1
Clear-Sky Solar Irradiance	taub	0.170	0.221	0.267	0.317	0.342	0.351	0.370	0.352	0.306	0.265	0.178	0.168	
	taud	1.855	2.101	2.129	2.021	2.069	2.233	2.314	2.378	2.366	2.147	1.914	1.883	
	Ebn at Noon	83	210	252	263	269	271	261	254	240	180	75	11	
	Edh at Noon	6	17	28	40	43	38	34	29	23	16	5	1	
All-Sky Solar Radiation	RadAvg	28	230	787	1516	1959	1966	1781	1250	714	280	52	4	
	RadStd	2	16	36	69	127	154	134	110	52	18	5	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	+3.24	+3.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	+2.81	+3.20	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page