

SCHEFFERVILLE, QC, Canada

WMO: 718280

Lat: 54.800N

Lon: 66.800W

Elev: 517

StdP: 95.26

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -36.2	(c) -33.8	(d) -40.9	(e) 0.1	(f) -36.0	(g) -38.6	(h) 0.1	(i) -33.6	(j) 12.8	(k) -20.1	(l) 11.7	(m) -19.5	(n) 2.4	(o) 160	(p) 0.848

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	23.7	15.2	21.6	14.5	19.8	13.9	17.0	21.0	15.9	19.5	15.0	18.1	5.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.9	18.0	14.6	11.1	17.0	13.6	10.3	16.2	50.0	20.6	46.6	19.5	43.8	18.1	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.2	(b) 9.9	(c) 8.9	(e) -41.0	(f) 27.6	(g) 2.3	(h) 1.6	(i) -42.7	(j) 28.8	(k) -44.0	(l) 29.7	(m) -45.3	(n) 30.6	(o) -46.9	(p) 31.8		
(a) 11.2	(b) 9.9	(c) 8.9	(e) -41.0	(f) 19.2	(g) 2.3	(h) 1.5	(i) -42.6	(j) 20.3	(k) -44.0	(l) 21.2	(m) -45.2	(n) 22.1	(o) -46.9	(p) 23.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.7	-22.4	-21.7	-15.1	-6.4	2.6	9.5	13.3	12.5	7.0	0.3	-8.0	-16.8
	DBStd	13.76	7.40	7.12	7.69	6.14	4.91	4.54	3.30	3.57	3.99	4.21	5.44	7.30
	HDD10.0	5263	1004	887	777	493	236	63	8	15	109	300	541	829
	HDD18.3	8039	1262	1121	1036	743	489	268	158	184	342	558	791	1088
	CDD10.0	273	0	0	0	0	6	47	111	92	17	1	0	0
	CDD18.3	8	0	0	0	0	0	2	3	3	1	0	0	0
	CDH23.3	73	0	0	0	0	3	22	27	18	3	0	0	0
	CDH26.7	6	0	0	0	0	0	3	2	1	0	0	0	0
Wind	WSAvg	4.3	4.3	4.2	4.5	4.6	4.1	4.2	3.9	3.9	4.5	4.5	4.5	4.2
Precipitation	PrecAvg	748	42	28	38	47	50	69	99	96	87	80	64	39
	PrecMax	964	156	75	121	141	104	161	165	187	192	152	122	93
	PrecMin	392	3	2	6	7	8	39	35	27	7	21	14	15
	PrecStd	138	31	19	25	30	25	24	34	39	43	35	24	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.5	0.6	4.4	8.6	22.9	26.0	26.3	25.7	22.4	13.9	4.7	1.4
		MCWB	0.1	0.0	1.2	3.2	12.7	15.5	15.8	16.3	16.1	10.3	3.7	0.8
	2%	DB	-3.3	-2.7	1.4	6.1	17.1	22.5	23.5	22.7	18.1	10.6	2.5	-0.4
		MCWB	-3.8	-3.5	-0.3	2.4	9.4	14.1	14.9	15.9	13.7	8.4	1.6	-0.7
	5%	DB	-7.2	-7.0	-0.5	4.1	13.8	20.0	21.4	20.7	15.5	8.3	1.0	-3.4
		MCWB	-7.7	-7.7	-1.8	1.4	7.8	13.0	14.5	14.8	12.4	6.7	0.3	-3.9
	10%	DB	-10.6	-10.4	-2.9	2.6	10.8	17.7	19.5	18.6	13.2	6.4	-0.4	-6.1
		MCWB	-11.1	-11.0	-4.2	0.6	6.4	11.6	14.1	14.0	10.6	4.9	-0.9	-6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.0	0.4	1.9	4.4	13.1	18.2	18.6	18.3	16.7	11.5	4.2	1.0
		MCDB	0.5	0.7	3.6	6.8	21.2	23.5	21.1	21.8	20.8	12.8	4.6	1.2
	2%	WB	-3.8	-3.5	0.0	2.8	10.4	15.7	16.7	17.0	14.7	8.9	1.8	-0.8
		MCDB	-3.4	-2.8	1.2	5.2	15.8	20.1	20.3	20.8	17.4	10.3	2.1	-0.5
	5%	WB	-7.6	-7.7	-1.9	1.8	8.2	14.1	15.8	15.9	12.8	6.8	0.4	-3.9
		MCDB	-7.2	-7.1	-0.4	4.0	12.9	18.1	19.0	19.6	14.9	8.1	0.9	-3.5
	10%	WB	-11.0	-11.0	-4.2	0.7	6.7	12.5	14.9	14.8	10.8	5.0	-1.0	-6.6
		MCDB	-10.6	-10.4	-3.0	2.5	10.5	16.4	18.0	17.6	12.9	6.2	-0.2	-6.1
Mean Daily Temperature Range	5% DB	MDBR	9.0	10.5	12.1	10.6	9.4	10.0	8.8	8.2	7.4	5.5	6.1	7.8
		MCDBR	10.2	10.9	11.1	11.2	15.0	14.1	12.2	11.2	10.6	9.0	6.8	7.8
		MCWBR	10.1	10.4	9.9	8.5	8.9	7.2	5.5	5.5	7.2	7.3	6.6	7.7
	5% WB	MCDBR	10.3	10.8	10.9	10.0	13.3	11.6	9.1	9.5	10.0	8.5	6.5	7.6
		MCWBR	10.2	10.3	9.9	8.0	8.4	7.0	5.4	5.6	8.0	7.4	6.5	7.6
Clear-Sky Solar Irradiance	taub	0.223	0.241	0.259	0.326	0.361	0.357	0.377	0.348	0.335	0.289	0.241	0.221	
	taud	2.224	2.252	2.234	2.086	2.188	2.407	2.369	2.463	2.462	2.490	2.262	2.146	
	Ebn at Noon	751	867	926	893	880	889	861	870	833	804	712	650	
	Edh at Noon	56	79	102	139	134	109	112	96	84	64	53	48	
All-Sky Solar Radiation	RadAvg	0.91	1.99	3.62	5.01	5.36	5.06	4.57	3.70	2.66	1.45	0.69	0.59	
	RadStd	0.08	0.15	0.27	0.35	0.51	0.34	0.36	0.28	0.23	0.11	0.10	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page