

ARMSTRONG, ON, Canada

WMO: 718410

Lat: 50.294N

Lon: 88.905W

Elev: 1063

StdP: 14.14

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.5	-28.5	-41.3	0.5	-32.8	-35.5	0.8	-27.4	17.3	5.4	15.6	5.0	1.2	300	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.8	83.2	65.5	80.0	64.0	77.0	62.5	69.3	78.1	67.1	75.2	65.1	72.7	8.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	101.2	73.3	64.3	93.7	70.9	62.3	87.2	68.8	34.2	78.4	32.3	74.6	30.7	73.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.5	12.9	DB	-42.6	89.3	5.4	2.1	-46.5	90.8	-49.7	92.0	-52.8	93.3	-56.7	94.8	(4)
(5)			WB	-42.5	72.7	5.5	2.3	-46.5	74.4	-49.7	75.8	-52.8	77.1	-56.8	78.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.0	-1.0	2.7	16.9	31.7	45.7	57.1	62.8	59.9	51.5	37.9	22.2	6.7		
	DBStd	24.58	14.27	13.67	14.31	10.04	8.22	6.90	6.30	6.55	8.44	8.30	12.39	14.71		
	HDD50	7332	1580	1325	1027	549	187	17	4	80	388	833	1341			
	HDD65	11772	2045	1745	1492	998	599	249	119	184	410	842	1283	1806		
	CDD50	1130	0	0	0	1	53	230	397	312	126	11	0	0		
	CDD65	96	0	0	0	0	1	12	51	27	5	0	0	0		
	CDH74	1371	0	0	0	1	50	257	637	357	69	0	0	0		
	CDH80	281	0	0	0	0	6	44	151	69	11	0	0	0		
	WSAvg	5.3	4.9	5.1	5.5	5.5	5.8	5.4	5.1	5.0	5.2	5.7	5.5	5.0		
	PrecAvg	29.1	1.3	1.0	1.3	1.7	2.9	3.5	3.8	3.3	3.8	2.7	2.1	1.5		
(15) Precipitation	PrecMax	37.8	2.3	2.2	2.3	2.9	6.1	7.7	5.9	6.0	7.7	4.4	5.0	3.2		
	PrecMin	21.3	0.7	0.3	0.4	0.5	0.9	1.7	2.0	1.7	1.3	0.9	0.9	0.7		
	PrecStd	3.9	0.4	0.5	0.4	0.6	1.2	1.4	1.1	1.1	1.7	0.9	0.8	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	39.7	55.5	65.8	79.6	84.8	89.0	86.3	80.7	68.0	52.9	37.4		
		MCWB	32.2	35.3	45.7	49.8	58.2	63.3	69.8	68.8	65.5	55.9	46.6	33.5		
	2%	DB	31.2	34.5	47.1	58.5	74.1	80.2	83.8	81.7	74.8	62.2	46.7	34.0		
		MCWB	29.9	31.7	39.0	45.1	55.4	61.6	66.8	65.7	62.6	54.1	42.9	32.2		
	5%	DB	27.3	30.8	41.5	53.9	69.1	76.7	80.5	78.1	70.2	57.1	41.9	31.6		
		MCWB	26.0	28.7	35.7	42.8	53.5	60.1	64.7	64.9	60.8	51.9	38.8	30.4		
	10%	DB	21.8	25.5	37.0	49.4	63.8	73.1	77.3	74.4	66.2	52.3	37.9	28.3		
		MCWB	20.7	23.5	32.9	39.2	50.7	59.0	63.3	62.7	58.8	47.6	35.7	27.1		
	0.4%	WB	32.8	36.3	47.1	52.1	62.9	68.9	73.2	71.9	69.1	59.3	47.9	35.0		
		MCDB	33.8	38.7	53.8	62.9	72.4	76.0	83.8	81.4	76.0	64.8	51.0	36.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.1	32.4	39.9	46.7	58.1	65.2	70.0	68.8	65.5	55.3	43.1	32.4		
		MCDB	31.3	34.0	45.7	56.7	68.3	73.1	80.0	77.3	71.0	59.5	46.2	33.6		
	5%	WB	26.1	28.6	36.4	43.2	54.9	62.9	67.4	66.7	62.5	52.0	39.2	30.2		
		MCDB	27.4	30.6	40.7	52.2	65.6	71.0	75.9	74.6	68.0	57.3	41.5	31.6		
	10%	WB	20.7	23.5	33.3	40.1	52.2	60.9	65.4	64.5	59.8	48.1	35.8	27.1		
		MCDB	21.9	25.4	37.0	48.2	62.4	69.5	73.6	71.7	65.0	51.8	37.8	28.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.8	26.0	26.3	23.9	24.7	24.7	23.8	23.8	21.1	16.2	15.4	18.4		
		MCDBR	20.0	23.1	27.1	32.2	34.9	31.2	29.0	28.9	27.3	26.4	18.1	16.2		
		MCWBR	19.0	20.0	19.7	20.5	18.9	15.5	14.3	15.5	17.0	18.3	14.2	14.8		
		MCDBR	20.0	20.5	23.7	28.8	28.1	23.9	24.5	24.0	23.3	23.8	16.4	15.4		
	5% WB	MCWBR	19.2	18.1	17.6	19.5	16.7	13.6	13.5	14.3	15.7	17.7	13.4	14.3		
(40) Clear-Sky Solar Irradiance	taub		0.241	0.258	0.288	0.332	0.350	0.361	0.384	0.369	0.348	0.299	0.277	0.248		
	taud		2.327	2.293	2.326	2.389	2.439	2.437	2.398	2.438	2.493	2.597	2.465	2.334		
	Ebn at Noon		261	283	293	290	288	284	275	274	269	269	245	238		
	Edh at Noon		20	27	32	34	34	35	36	32	28	21	18	17		
(44) All-Sky Solar Radiation	RadAvg		387	784	1205	1572	1646	1764	1742	1471	1052	610	314	259		
	RadStd		48	61	103	135	98	141	137	118	91	91	34	38		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page