

SIOUX LOOKOUT, ON, Canada

WMO: 718420

Lat: 50.121N

Lon: 91.903W

Elev: 383

StdP: 96.81

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.8	-30.2	-37.1	0.1	-32.6	-34.7	0.1	-30.1	8.4	-13.7	7.8	-15.2	1.8	290	0.633

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	28.8	19.9	27.1	18.6	25.6	17.8	21.5	26.9	20.3	25.0	19.2	23.6	4.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	15.1	24.2	18.6	14.1	22.9	17.6	13.2	21.7	64.6	27.2	60.3	24.9	56.6	23.6	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.2	6.3	DB	-37.6	32.2	3.0	2.0	-39.7	33.7	-41.5	34.9	-43.2	36.0	-45.3	37.5	(4)
(5)			WB	-37.7	23.3	3.0	1.1	-39.8	24.1	-41.6	24.7	-43.2	25.3	-45.4	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.3	-17.0	-14.2	-6.3	2.0	9.7	16.2	18.8	17.6	12.7	4.8	-4.2	-13.0	(6)	
	DBStd	13.84	8.05	7.63	7.76	6.01	5.17	4.20	3.35	3.54	4.72	4.90	6.63	7.79	(7)	
	HDD10.0	3682	836	679	506	244	70	4	0	1	26	176	427	713	(8)	
	HDD18.3	5951	1094	912	763	489	269	87	34	56	177	421	677	971	(9)	
	CDD10.0	888	0	0	1	5	62	191	273	237	106	14	0	0	(10)	
	CDD18.3	118	0	0	0	0	3	23	49	34	8	0	0	0	(11)	
	CDH23.3	948	0	0	0	2	42	224	378	249	52	1	0	0	(12)	
	CDH26.7	197	0	0	0	0	5	51	83	51	7	0	0	0	(13)	
(14) Wind	WSAvg	3.2	3.0	3.1	3.2	3.3	3.3	3.0	2.9	3.0	3.2	3.5	3.5	3.1	(14)	
(15) Precipitation	PrecAvg	739	38	28	41	46	65	99	94	91	85	64	51	38	(15)	
	PrecMax	1016	95	57	103	130	134	159	162	200	166	162	94	59	(16)	
	PrecMin	502	10	9	8	4	15	41	30	20	17	24	13	18	(17)	
	PrecStd	129	23	12	20	31	30	32	34	46	41	33	22	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.9	5.2	14.4	20.8	26.9	31.4	31.5	30.5	27.8	21.1	12.6	3.6	(19)	
		MCWB	0.8	2.8	9.1	10.8	16.4	21.3	21.6	20.9	19.1	14.8	9.5	1.4	(20)	
	2%	DB	-0.2	1.9	9.7	16.9	24.2	27.7	28.7	28.0	24.8	17.7	8.9	0.8	(21)	
		MCWB	-0.9	0.1	5.0	8.4	14.1	18.0	20.1	19.9	18.4	13.0	6.2	-0.3	(22)	
	5%	DB	-2.5	0.0	6.5	14.0	21.6	25.9	27.1	26.1	22.4	14.9	6.2	-0.6	(23)	
		MCWB	-3.3	-1.3	3.0	6.9	12.8	17.1	19.0	18.7	16.7	10.9	4.4	-1.3	(24)	
	10%	DB	-5.1	-2.5	3.7	11.5	19.0	23.9	25.4	24.2	20.2	12.2	4.1	-2.2	(25)	
		MCWB	-5.8	-3.7	1.0	5.6	11.6	16.2	18.1	17.8	15.7	9.5	2.5	-3.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.0	3.1	9.9	12.0	18.5	22.3	23.1	22.6	21.0	16.2	9.9	1.7	(27)	
		MCDB	1.9	5.0	14.3	19.1	23.7	28.9	28.6	28.0	25.2	18.9	12.2	3.0	(28)	
	2%	WB	-0.9	0.4	5.8	9.4	16.1	20.3	21.7	21.0	19.2	13.5	6.7	0.0	(29)	
		MCDB	-0.2	1.6	9.2	15.1	21.0	25.4	26.9	26.0	23.0	16.9	8.4	0.7	(30)	
	5%	WB	-3.2	-1.3	3.2	7.6	14.2	18.8	20.5	19.9	17.7	11.5	4.6	-1.3	(31)	
		MCDB	-2.5	0.1	6.0	13.2	19.7	23.2	25.2	24.4	21.4	14.4	6.1	-0.6	(32)	
	10%	WB	-5.8	-3.8	1.1	6.0	12.5	17.4	19.3	18.8	16.3	9.4	2.5	-2.9	(33)	
		MCDB	-5.1	-2.4	3.5	10.9	17.9	22.0	23.7	22.9	19.4	11.8	4.0	-2.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	11.0	11.6	11.4	11.4	10.8	10.3	10.1	9.1	7.1	6.5	7.9	(35)	
		MCDBR	8.3	9.5	11.9	15.2	15.1	13.4	12.2	12.2	12.0	11.7	8.1	7.6	(36)	
	5% WB	MCWBR	7.7	8.2	8.3	9.2	7.5	5.9	5.4	5.7	6.7	7.6	6.0	6.9	(37)	
		MCWBR	8.3	8.5	10.9	13.8	12.2	11.0	10.6	10.5	10.4	10.7	7.7	7.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.250	0.257	0.284	0.321	0.345	0.363	0.384	0.361	0.348	0.297	0.277	0.251	(40)	
		taud	2.306	2.300	2.344	2.420	2.455	2.431	2.399	2.474	2.491	2.602	2.477	2.332	(41)	
	Ebn at Noon	Ebn at Noon	806	896	929	926	912	895	868	874	850	850	776	748	(42)	
		Edh at Noon	66	86	100	105	106	109	112	99	88	65	57	56	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.18	2.40	3.66	4.95	5.28	5.48	5.59	4.71	3.39	1.95	1.02	0.80	(44)	
	RadStd	RadStd	0.15	0.22	0.30	0.40	0.32	0.43	0.44	0.41	0.32	0.27	0.11	0.10	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page