

WINNIPEG INTL, MB, Canada

WMO: 718520

Lat: 49.9158N

Lon: 97.2493W

Elev: 239

StdP: 98.49

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.0	-29.6	-36.6	0.1	-31.8	-34.2	0.2	-29.4	14.3	-13.2	13.2	-12.5	3.3	290	0.721

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	30.4	21.2	28.7	20.3	27.1	19.3	23.1	28.3	21.7	26.9	20.5	25.4	6.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.3	16.5	26.6	19.9	15.1	24.8	18.7	14.0	23.4	70.0	28.4	64.9	27.0	60.4	25.4	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	11.1	9.9	-35.4	33.8	3.1	2.0	-37.7	35.2	-39.5	36.4	-41.2	37.5	-43.5	38.9
			-35.6	25.4	3.1	1.3	-37.8	26.3	-39.6	27.1	-41.3	27.8	-43.5	28.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-16.3	-14.1	-5.9	3.9	11.1	17.2	19.7	18.8	13.7	5.6	-4.0	-12.6	(6)
(7)		DBStd	14.14	8.27	7.79	7.98	6.30	5.17	3.96	3.27	3.56	4.72	4.98	6.69	7.80	(7)
(8)		HDD10.0	3525	814	674	495	198	50	2	0	0	18	154	421	700	(8)
(9)		HDD18.3	5697	1073	907	752	433	229	66	24	38	151	394	671	958	(9)
(10)		CDD10.0	1039	0	0	1	14	84	218	301	273	129	18	0	0	(10)
(11)		CDD18.3	168	0	0	0	0	6	32	66	52	12	1	0	0	(11)
(12)		CDH23.3	1688	0	0	0	4	93	313	614	535	123	7	0	0	(12)
(13)		CDH26.7	438	0	0	0	0	22	76	158	156	25	1	0	0	(13)
(14)	Wind	WSAvg	4.9	5.0	5.0	5.2	5.2	4.6	4.1	4.3	4.8	5.2	5.1	4.9	(14)	
(15)	Precipitation	PrecAvg	523	19	15	25	36	61	83	77	50	35	23	20	(15)	
(16)		PrecMax	777	52	49	68	99	181	232	193	222	151	129	62	42	(16)
(17)		PrecMin	237	3	0	1	0	8	6	20	6	10	2	1	3	(17)
(18)		PrecStd	111	12	12	15	26	45	47	46	50	30	28	16	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.8	4.2	15.5	23.5	29.6	31.8	32.2	32.7	29.7	23.6	13.4	3.8	(19)
MCWB			1.1	2.8	10.3	12.7	16.9	22.4	23.1	21.8	19.7	15.7	8.9	1.6	(20)	
2%		DB	0.7	2.0	9.6	20.0	25.9	28.7	30.0	30.2	26.6	19.4	9.7	1.3	(21)	
		MCWB	-0.3	1.0	6.4	11.0	14.9	19.5	21.9	21.1	18.4	13.2	6.5	0.1	(22)	
5%		DB	-1.7	0.4	6.3	17.3	23.1	26.7	28.4	28.3	24.3	16.3	7.1	-0.3	(23)	
		MCWB	-2.6	-0.4	4.0	9.7	14.0	18.6	21.0	20.2	17.4	11.4	4.7	-1.1	(24)	
10%		DB	-4.2	-2.4	3.6	14.1	20.3	24.9	26.9	26.4	21.8	13.5	4.4	-2.0	(25)	
		MCWB	-4.9	-3.3	2.0	8.1	12.6	17.7	20.1	19.1	16.1	9.9	2.6	-2.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.6	2.7	11.3	14.1	19.0	24.2	25.1	24.3	22.0	16.7	9.6	1.9	(27)
MCDWB			2.6	4.0	15.1	21.6	24.5	29.8	30.4	29.5	27.0	22.6	12.2	3.3	(28)	
2%		WB	-0.3	1.1	6.6	11.6	16.6	21.5	23.5	22.4	19.8	14.1	7.0	0.3	(29)	
		MCDWB	0.7	1.8	9.5	18.6	22.1	26.3	28.2	28.1	24.2	18.2	9.3	1.2	(30)	
5%		WB	-2.5	-0.4	4.1	10.0	15.2	19.9	22.2	21.1	18.2	12.0	4.7	-1.2	(31)	
		MCDWB	-1.7	0.5	6.2	15.8	20.5	24.8	27.2	26.6	22.6	15.3	6.8	-0.3	(32)	
10%		WB	-4.9	-3.3	2.2	8.5	13.9	18.6	20.8	20.0	16.7	10.0	2.7	-2.8	(33)	
		MCDWB	-4.2	-2.4	3.5	13.9	19.2	23.2	25.5	25.0	21.0	13.2	4.4	-2.0	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.0	9.6	9.6	11.5	12.5	11.3	11.7	12.4	11.6	9.5	8.1	8.2	(35)
MCDBR			9.1	8.1	10.7	16.1	16.3	13.8	13.1	14.6	14.9	13.9	11.3	8.9	(36)	
MCWBR			8.5	7.3	7.9	9.3	8.4	7.1	7.0	7.2	8.2	8.6	8.3	8.0	(37)	
5% WB		MCDBR	9.0	7.9	10.2	14.5	12.8	11.5	11.6	12.6	12.5	12.6	10.4	8.6	(38)	
		MCWBR	8.5	7.2	7.7	8.9	7.6	6.8	7.0	7.7	7.7	8.3	7.9	7.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.265	0.301	0.309	0.356	0.373	0.385	0.392	0.380	0.347	0.306	0.274	0.250	(40)	
taud		2.253	2.140	2.293	2.333	2.352	2.342	2.338	2.368	2.455	2.536	2.463	2.333	(41)		
Ebn at Noon		779	824	898	888	885	873	860	854	850	836	782	755	(42)		
Edh at Noon		70	102	106	115	118	120	119	110	91	70	58	56	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1.35	2.56	3.83	5.01	5.45	5.83	6.14	5.06	3.65	2.15	1.19	0.96	(44)	
(45)		RadStd	0.14	0.18	0.32	0.37	0.45	0.45	0.26	0.34	0.28	0.29	0.17	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	-0.56	-0.80	N/A	N/A	N/A	N/A

Nomenclature: See separate page