

BLUE RIVER, BC, Canada

WMO: 718830

Lat: 52.1290N

Lon: 119.2898W

Elev: 683

StdP: 93.39

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-27.3	-22.7	-30.8	0.2	-26.9	-26.0	0.4	-21.2	8.1	-10.5	6.6	-9.6	0.2	0	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	30.8	16.4	28.4	15.9	26.1	15.1	18.0	26.6	17.0	25.3	16.1	23.6	2.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	11.9	19.4	14.4	11.1	18.2	13.5	10.5	17.3	53.4	26.6	50.2	25.4	47.3	23.6	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	4.9	3.8	DB	-32.2	33.8	5.1	1.8	-35.9	35.1	-38.9	36.2	-41.8	37.2	-45.6	38.6	(4)
(5)			WB	-32.4	20.8	5.1	1.7	-36.0	22.0	-39.0	23.0	-41.9	24.0	-45.6	25.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.7	-6.5	-5.0	0.1	4.7	10.0	13.8	16.7	15.8	11.0	4.4	-1.6	-7.1	(6)	
	DBStd	9.45	7.16	6.01	4.11	2.94	3.37	2.81	3.05	3.01	3.30	3.17	4.58	6.46	(7)	
	HDD10.0	2523	512	419	307	162	42	2	0	1	26	176	348	530	(8)	
	HDD18.3	4989	770	652	565	410	257	140	69	87	220	432	598	788	(9)	
	CDD10.0	608	0	0	0	2	43	115	208	182	56	2	0	0	(10)	
	CDD18.3	32	0	0	0	0	0	3	18	10	1	0	0	0	(11)	
	CDH23.3	1166	0	0	0	2	61	161	511	377	54	0	0	0	(12)	
	CDH26.7	398	0	0	0	0	8	46	201	131	12	0	0	0	(13)	
(14) Wind	WSAvg	0.8	0.5	0.7	0.8	0.9	1.1	1.0	0.9	0.8	0.6	0.5	0.6	0.5	(14)	
(15) Precipitation	PrecAvg	1032	99	71	73	50	69	95	88	83	81	90	105	116	(15)	
	PrecMax	1212	187	118	169	83	113	148	211	164	200	224	164	235	(16)	
	PrecMin	657	33	21	34	25	35	27	4	13	6	25	28	41	(17)	
	PrecStd	139	52	28	29	18	22	34	47	46	43	51	38	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	6.5	13.9	22.0	27.8	30.9	33.7	32.9	28.3	17.5	8.6	3.4	(19)	
		MCWB	2.6	2.8	6.1	10.8	13.7	16.0	17.6	17.4	15.9	11.6	6.6	1.6	(20)	
	2%	DB	2.0	4.2	10.1	17.7	25.1	27.5	31.4	30.2	24.6	13.4	6.0	1.3	(21)	
		MCWB	1.2	1.7	4.4	8.5	12.6	14.7	16.8	16.4	15.2	9.3	5.1	0.6	(22)	
	5%	DB	1.0	2.7	7.5	14.6	22.3	24.7	29.1	27.6	21.1	11.1	4.5	0.5	(23)	
		MCWB	0.6	1.0	3.3	6.9	11.5	13.8	16.3	16.0	13.7	8.5	3.7	0.2	(24)	
	10%	DB	0.3	1.4	5.5	11.8	19.5	22.1	26.2	25.0	18.0	9.2	3.0	0.0	(25)	
		MCWB	0.1	0.4	2.5	5.7	10.5	13.0	15.5	15.3	12.5	7.3	2.3	-0.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.8	3.6	6.8	11.5	14.7	17.5	19.6	19.7	17.3	12.3	7.1	2.1	(27)	
		MCDB	3.7	5.3	12.0	19.4	24.1	26.4	28.7	27.6	24.7	15.5	7.8	2.9	(28)	
	2%	WB	1.4	2.3	5.1	9.4	13.5	15.9	18.2	18.0	15.7	10.6	5.3	0.7	(29)	
		MCDB	1.7	3.5	8.9	16.3	22.1	24.2	27.1	26.3	22.8	12.3	5.8	1.1	(30)	
	5%	WB	0.7	1.3	3.9	7.7	12.4	14.8	17.2	16.9	14.4	9.0	3.8	0.2	(31)	
		MCDB	0.9	2.2	6.7	13.0	20.1	22.0	25.8	24.8	19.9	10.6	4.5	0.4	(32)	
	10%	WB	0.2	0.5	2.8	6.4	11.3	13.9	16.2	16.0	13.1	7.4	2.4	-0.1	(33)	
		MCDB	0.3	1.2	5.0	10.8	17.8	20.0	23.9	23.2	17.2	8.9	2.8	0.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	9.8	10.5	13.2	15.2	13.8	15.5	16.1	13.7	8.7	5.1	6.3	(35)	
		MCDBR	4.8	9.2	14.0	19.6	22.5	21.0	22.7	22.8	20.8	12.9	6.0	4.4	(36)	
	5% WB	MCWBR	4.1	7.0	8.9	10.8	10.9	9.6	10.0	10.8	11.8	8.6	4.8	4.0	(37)	
		MCWBR	4.5	7.2	11.8	16.9	18.6	17.0	19.3	19.6	18.6	11.3	5.5	4.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.260	0.265	0.295	0.342	0.373	0.384	0.354	0.354	0.332	0.306	0.268	0.252	(40)	
		taud	2.269	2.297	2.232	2.133	2.256	2.323	2.454	2.453	2.506	2.523	2.369	2.245	(41)	
	Ebn at Noon		749	865	899	888	877	869	893	874	856	813	741	688	(42)	
		Edh at Noon	63	82	108	136	128	121	104	99	84	67	57	54	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.73	1.61	2.54	4.15	5.06	4.99	5.43	4.74	3.17	1.67	0.75	0.58	(44)	
	RadStd		0.10	0.22	0.35	0.42	0.62	0.47	0.56	0.28	0.36	0.26	0.13	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page