

ESTEVAN POINT, BC, Canada

WMO: 718940

Lat: 49.3833N

Lon: 126.5431W

Elev: 19

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	28.9	31.0	20.4	15.3	32.7	25.2	19.3	33.8	43.2	45.6	39.1	45.8	7.3	60	0.695

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.0	67.6	61.5	65.4	60.4	63.7	59.4	62.6	66.3	61.2	64.4	60.2	62.9	10.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.0	80.1	63.9	59.9	77.0	62.5	58.9	74.3	61.3	28.1	66.5	27.2	64.6	26.5	63.1	68.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.2	30.1	26.5	DB	25.2	74.1	2.9	3.8	23.1	76.9	21.4	79.1	19.7	81.2	17.6	84.0	(4)
(5)			WB	23.4	64.7	3.2	1.5	21.1	65.8	19.3	66.7	17.5	67.6	15.2	68.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.6	42.7	42.4	43.7	46.8	51.5	55.1	58.2	58.6	56.5	50.8	45.7	42.2		
	DBStd	7.10	4.63	4.04	3.67	3.33	3.38	2.74	2.58	2.39	2.99	3.38	4.70	4.63		
	HDD50	1179	226	212	195	106	24	1	0	0	0	31	141	243		
	HDD65	5638	690	631	659	547	420	297	212	199	255	441	580	707		
	CDD50	1017	1	0	1	9	69	154	254	266	196	55	11	1		
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH74	5	0	0	0	0	0	1	2	1	1	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	11.4	11.8	11.4	11.9	12.0	11.6	11.5	11.2	9.6	9.9	10.8	12.5	12.4		
	PrecAvg	129.0	16.5	14.0	13.0	10.2	6.4	5.4	3.2	4.1	6.7	15.2	17.6	16.5		
(15) Precipitation	PrecMax	158.9	27.8	28.9	22.0	19.9	14.6	11.3	13.7	10.9	14.7	31.3	29.0	30.9		
	PrecMin	90.7	3.8	5.3	2.0	3.9	2.0	0.7	0.2	0.2	0.6	3.3	6.2	8.1		
	PrecStd	16.9	6.8	5.6	4.3	4.3	3.4	2.9	2.9	2.9	3.5	6.9	5.2	5.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.8	53.2	56.5	60.1	66.1	70.0	71.1	70.1	69.6	61.6	56.8	53.9		
		MCWB	47.3	48.7	49.5	54.5	56.8	60.9	63.3	62.7	62.9	56.0	54.0	48.6		
	2%	DB	51.0	51.1	52.9	56.6	61.3	63.8	66.6	67.1	65.7	59.2	54.8	51.4		
		MCWB	49.2	48.3	48.4	51.3	55.9	58.5	61.0	61.8	60.8	56.0	52.5	49.2		
	5%	DB	49.9	49.8	51.1	54.4	58.9	61.7	64.7	65.0	63.4	57.3	53.5	50.1		
		MCWB	48.7	47.5	48.2	50.0	54.4	57.2	60.0	60.8	59.5	55.1	51.8	48.5		
	10%	DB	48.8	48.4	49.5	52.6	57.0	60.0	63.0	63.2	61.5	55.9	52.3	48.8		
		MCWB	47.8	46.7	47.2	49.0	53.1	56.2	59.0	59.8	58.5	54.1	50.9	47.5		
	0.4%	WB	51.1	51.2	51.9	55.2	58.4	61.6	64.3	63.9	64.0	59.1	55.7	51.7		
		MCDB	51.3	51.8	53.5	59.6	63.0	68.7	69.8	67.6	67.7	59.9	56.2	52.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	50.1	49.8	50.4	52.8	56.6	59.3	62.0	62.5	61.8	57.1	53.6	50.1		
		MCDB	50.5	50.6	52.0	55.7	60.6	63.8	65.4	66.1	64.6	57.9	54.3	50.6		
	5%	WB	49.1	48.5	49.1	51.2	55.1	58.0	60.7	61.4	60.1	55.7	52.2	48.6		
		MCDB	49.6	49.4	50.6	53.2	58.4	61.3	63.7	64.4	62.4	56.6	52.9	49.3		
	10%	WB	48.2	47.3	47.9	49.8	53.8	56.7	59.5	60.3	59.0	54.6	51.0	47.6		
		MCDB	48.7	48.4	49.4	51.8	56.5	59.3	62.2	62.9	60.9	55.6	51.8	48.5		
	5% DB	MDBR	7.6	9.1	9.4	10.2	9.8	8.8	8.8	9.0	9.4	8.9	8.6	7.8		
		MCDBR	7.1	10.3	11.8	13.4	12.7	12.0	11.6	11.9	12.5	10.5	8.6	7.7		
		MCWBR	5.4	7.6	8.5	9.2	8.6	7.7	7.1	7.6	8.5	7.5	7.3	6.4		
		MCWBR	5.4	7.6	9.3	11.3	11.9	11.0	10.8	11.0	11.0	8.1	7.6	6.8		
(35) Mean Daily Temperature Range	5% WB	MCWBR	5.0	6.4	7.2	8.3	8.3	7.3	7.0	7.3	7.8	6.6	6.8	6.5		
	Clear-Sky Solar Irradiance	taub	0.323	0.325	0.349	0.371	0.384	0.363	0.352	0.356	0.349	0.351	0.330	0.311		
		taud	2.455	2.509	2.453	2.387	2.377	2.467	2.544	2.542	2.545	2.479	2.454	2.466		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	232	263	274	278	278	284	286	280	271	248	226	220		
		Edh at Noon	20	24	30	35	36	34	31	30	27	24	20	17		
(44) All-Sky Solar Radiation	RadStd		262	555	857	1344	1708	1844	1882	1637	1188	647	318	215		
			33	85	101	118	167	170	179	150	93	84	54	30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	-1.71	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page