

PRINCE GEORGE, BC, Canada

WMO: 718960

Lat: 53.8890N

Lon: 122.6719W

Elev: 2267

StdP: 13.53

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.4	-12.2	-27.0	1.3	-18.8	-19.6	2.0	-11.5	25.4	35.4	22.9	34.7	2.4	0	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.7	82.2	61.1	78.5	59.8	75.0	58.1	63.0	77.9	61.1	74.9	59.5	72.1	6.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	76.6	66.5	55.8	72.0	64.6	54.1	67.8	63.2	29.6	78.5	28.2	75.1	27.0	72.5	68.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.5	18.7	16.5	-26.1	87.6	8.5	3.7	-32.2	90.2	-37.2	92.4	-42.0	94.5	-48.2	97.2		
(5)			-26.4	66.1	8.4	1.7	-32.5	67.3	-37.4	68.3	-42.1	69.3	-48.2	70.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.8	18.7	22.1	30.8	40.6	50.2	56.6	60.5	59.0	50.7	39.9	28.2	19.6		
	DBStd	17.66	15.42	12.64	10.47	6.44	6.44	5.25	5.11	5.42	6.21	6.97	10.55	13.32		
	HDD50	4706	970	781	597	289	78	6	0	2	67	319	654	943		
	HDD65	9221	1435	1201	1062	732	459	257	158	197	431	777	1104	1408		
	CDD50	998	0	0	0	7	85	204	326	282	87	7	0	0		
	CDD65	36	0	0	0	0	0	5	19	12	0	0	0	0		
	CDH74	954	0	0	0	1	40	144	420	314	35	0	0	0		
	CDH80	205	0	0	0	0	3	23	113	63	3	0	0	0		
(14) Wind	WSAvg	6.3	6.8	6.3	7.3	6.9	6.3	5.7	5.2	4.9	5.3	6.7	7.4	7.2		
(15) Precipitation	PrecAvg	25.9	2.4	1.4	1.5	1.2	2.2	2.7	2.6	2.6	2.4	2.5	2.2	2.3		
	PrecMax	35.5	6.3	3.3	2.7	2.6	4.4	5.8	5.3	5.3	5.4	5.0	4.1	5.4		
	PrecMin	18.5	0.6	0.3	0.4	0.5	0.3	0.6	0.8	0.4	0.4	0.8	0.1	0.8		
	PrecStd	4.1	1.3	0.7	0.6	0.5	0.9	1.4	1.3	1.2	1.1	1.2	0.9	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.0	46.1	56.0	69.6	78.7	83.4	88.5	85.3	78.2	64.8	54.1	44.6		
		MCWB	39.0	37.8	43.5	51.6	56.6	60.7	63.4	62.7	59.5	52.7	44.8	37.1		
	2%	DB	42.0	42.4	50.3	62.4	73.6	77.9	83.1	81.5	73.0	59.0	47.7	41.1		
		MCWB	37.0	36.2	40.3	47.5	54.0	58.6	61.6	61.4	57.7	49.2	42.0	35.5		
	5%	DB	39.3	39.4	47.1	57.4	69.4	74.2	78.7	77.4	68.0	54.2	43.1	38.1		
		MCWB	35.4	34.4	38.7	44.3	52.3	56.8	60.2	60.2	55.6	46.5	38.9	34.5		
	10%	DB	36.3	36.9	43.9	53.2	65.4	70.0	74.5	73.4	63.2	50.9	40.3	35.4		
		MCWB	33.8	33.2	36.9	42.0	50.8	55.0	58.7	58.4	52.9	44.6	36.9	32.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.7	39.3	44.5	51.9	58.3	62.7	65.4	65.4	61.0	53.9	45.8	39.1		
		MCDB	43.5	43.5	53.1	66.7	75.4	77.3	83.0	80.1	74.0	61.2	51.6	42.1		
	2%	WB	37.5	37.1	41.5	48.4	55.7	60.1	63.3	63.0	58.6	50.7	42.6	36.2		
		MCDB	41.3	41.3	48.2	60.2	69.3	74.4	79.2	77.4	71.0	56.8	46.9	39.5		
	5%	WB	35.6	35.1	39.5	45.5	53.7	58.1	61.3	61.1	56.4	47.6	39.7	34.8		
		MCDB	38.5	38.6	45.8	55.4	66.5	70.7	75.2	74.5	66.0	52.8	42.6	37.8		
	10%	WB	33.9	33.5	37.5	43.1	51.9	56.2	59.6	59.2	54.1	45.2	37.3	32.9		
		MCDB	36.2	36.3	43.3	51.3	63.6	67.5	72.0	71.3	61.7	49.9	39.6	35.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	15.6	17.9	20.5	23.1	21.9	22.7	23.9	21.8	16.3	11.3	12.0		
		MCDBR	12.0	15.6	21.1	28.2	31.7	30.1	32.1	31.7	30.4	22.5	14.0	12.4		
		MCWBR	8.8	11.0	13.1	15.7	15.5	13.8	14.1	14.6	16.6	14.2	9.9	9.3		
		MCDBR	10.8	14.2	19.3	25.1	27.4	25.8	28.1	28.9	28.0	20.4	13.5	11.6		
	5% WB	MCWBR	8.4	10.3	12.6	14.6	13.9	12.4	13.2	14.2	15.7	13.5	10.1	9.0		
(40) Clear-Sky Solar Irradiance	taub		0.259	0.272	0.287	0.319	0.347	0.353	0.345	0.349	0.310	0.294	0.278	0.248		
	taud		2.317	2.342	2.386	2.439	2.421	2.420	2.482	2.462	2.582	2.594	2.438	2.312		
	Ebn at Noon		229	266	287	290	285	284	285	277	278	259	223	210		
	Edh at Noon		18	24	29	31	34	34	32	31	24	19	16	14		
(44) All-Sky Solar Radiation	RadAvg		234	528	971	1467	1724	1880	1822	1559	1035	569	251	175		
	RadStd		25	65	82	91	122	144	174	75	84	55	30	20		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+104	N/A

Nomenclature: See separate page