

MCINNES ISLAND, BC, Canada

WMO: 718970

Lat: 52.262N

Lon: 128.719W

Elev: 26

StdP: 101.01

Time Zone: -8.00 (NAP)

Period: 82-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -4.2	(c) -1.8	(d) -12.5	(e) 1.3	(f) -3.1	(g) -8.6	(h) 1.8	(i) -0.9	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.7	(c) 17.7	(d) 15.1	(e) 16.9	(f) 14.5	(g) 16.1	(h) 14.1	(i) 15.6	(j) 17.0	(k) 15.0	(l) 16.3	(m) 14.5	(n) 15.7	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	10.5	16.1	14.2	10.2	15.6	13.8	9.9	15.2	43.5	17.2	41.8	16.4	40.6	15.8	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	4.8	4.9	6.0	7.0	9.5	12.2	13.7	14.2	12.7	9.7	5.9	4.1
	DBStd	4.07	2.46	2.30	1.92	1.50	1.53	1.41	1.46	1.19	1.40	1.97	2.45	2.75
	HDD10.0	879	161	144	125	89	28	0	1	0	1	25	123	183
	HDD18.3	3498	419	377	383	338	274	184	143	129	168	267	373	442
	CDD10.0	423	0	0	0	1	12	66	116	129	82	17	1	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	2773	337	247	236	199	156	128	105	143	213	356	337	295
	PrecMax	3615	698	479	503	380	308	262	223	492	325	554	543	498
	PrecMin	2362	118	40	29	68	51	12	13	21	53	179	107	140
	PrecStd	319	139	97	89	85	72	64	61	106	72	95	115	91
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	9.2	11.5	13.7	15.8	19.6	18.6	19.0	17.9	14.7	11.9	9.6
		MCWB	8.6	7.1	8.3	8.2	12.1	13.4	15.7	16.2	14.8	11.7	10.4	8.5
	2%	DB	8.7	8.4	9.9	11.2	13.8	16.5	17.5	17.7	16.4	13.3	10.7	8.5
		MCWB	8.0	6.9	7.7	8.5	11.3	13.6	15.1	15.4	13.9	11.6	9.8	7.6
	5%	DB	8.1	7.9	9.0	10.1	12.8	15.3	16.7	16.8	15.4	12.6	9.9	7.8
		MCWB	7.4	6.7	7.2	7.8	10.7	13.2	14.5	14.8	13.5	11.3	9.0	7.0
	10%	DB	7.5	7.4	8.2	9.2	11.9	14.5	15.9	16.1	14.7	11.9	9.2	7.2
		MCWB	6.8	6.3	6.7	7.3	10.0	12.5	14.1	14.4	13.2	10.8	8.2	6.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	8.1	9.0	10.0	12.8	14.8	16.2	16.8	15.6	13.2	11.0	8.9
		MCDB	9.0	8.5	10.1	11.3	14.6	16.5	18.2	18.2	17.4	13.7	11.3	9.4
	2%	WB	8.2	7.5	8.2	9.0	11.6	14.1	15.3	15.7	14.6	12.3	10.0	7.9
		MCDB	8.4	8.0	9.2	10.5	13.2	15.7	17.0	17.0	15.8	12.8	10.6	8.3
	5%	WB	7.6	7.1	7.6	8.2	10.9	13.5	14.8	15.1	14.1	11.6	9.1	7.2
		MCDB	7.9	7.6	8.5	9.5	12.4	15.0	16.2	16.3	15.0	12.2	9.8	7.6
	10%	WB	6.9	6.6	7.1	7.7	10.3	12.7	14.3	14.6	13.6	11.0	8.3	6.5
		MCDB	7.3	7.2	7.9	8.8	11.7	14.1	15.6	15.8	14.4	11.7	9.1	7.1
Mean Daily Temperature Range	5% DB	MDBR	2.6	2.8	3.3	3.5	3.8	3.6	3.9	3.7	3.1	2.8	2.7	2.7
		MCDBR	2.7	3.1	4.5	5.0	5.4	5.1	4.9	4.7	4.0	3.8	3.0	3.3
		MCWBR	2.6	2.6	3.3	3.5	3.9	3.4	3.0	3.3	2.9	2.9	2.8	3.2
	5% WB	MCDBR	2.6	2.8	3.8	4.3	4.8	4.5	4.2	4.3	3.6	3.4	2.9	3.2
		MCWBR	2.7	2.5	3.0	3.3	3.7	3.3	2.8	3.3	3.0	3.1	2.9	3.2
Clear-Sky Solar Irradiance	taub	0.314	0.319	0.347	0.372	0.378	0.371	0.362	0.365	0.356	0.340	0.319	0.304	
	taud	2.424	2.514	2.436	2.371	2.398	2.459	2.525	2.528	2.531	2.504	2.419	2.387	
	Ebn at Noon	691	810	848	864	875	883	885	865	830	768	672	629	
	Edh at Noon	58	70	91	109	111	105	97	92	82	70	57	50	
All-Sky Solar Radiation	RadAvg	0.61	1.47	2.44	3.88	5.00	5.25	5.05	4.33	2.99	1.65	0.77	0.51	
	RadStd	0.08	0.27	0.35	0.27	0.52	0.50	0.65	0.49	0.33	0.26	0.12	0.09	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	+0.42	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page