

KUUIJUAQ, QC, Canada

WMO: 719060

Lat: 58.0987N

Lon: 68.4175W

Elev: 131

StdP: 14.63

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.3	-28.9	-40.8	0.5	-31.7	-38.0	0.6	-28.5	33.6	9.1	28.4	2.3	4.8	220	0.842

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	75.6	61.0	71.3	59.1	67.3	57.2	63.5	72.0	60.9	68.9	58.4	66.0	9.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.2	78.2	67.0	57.1	70.0	64.4	54.3	63.1	62.2	29.0	72.2	27.2	69.0	25.4	66.2	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	21.0	18.4	-38.1	83.5	3.4	3.2	-40.6	85.9	-42.6	87.8	-44.5	89.6	-46.9	91.9
			-38.3	67.5	3.4	2.4	-40.7	69.3	-42.7	70.7	-44.6	72.1	-47.0	73.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	-9.4	-8.6	2.2	18.2	34.8	46.6	54.6	53.5	44.3	34.0	19.9	3.8
	DBStd	24.59	13.24	12.13	13.57	11.62	8.98	7.74	6.80	6.57	6.47	6.56	8.94	13.65
	HDD50	9649	1841	1642	1483	955	478	156	28	36	197	498	902	1433
	HDD65	14734	2306	2062	1948	1405	936	553	329	362	621	962	1352	1898
	CDD50	405	0	0	0	0	8	54	172	144	26	1	0	0
	CDD65	15	0	0	0	0	0	2	8	5	0	0	0	0
	CDH74	193	0	0	0	0	3	31	102	56	1	0	0	0
	CDH80	30	0	0	0	0	0	6	17	7	0	0	0	0
Wind	WSAvg	8.5	8.5	8.7	9.4	9.5	8.6	8.7	7.6	7.3	8.3	8.7	8.9	8.4
Precipitation	PrecAvg	22.6	1.2	1.1	1.2	1.1	1.1	2.1	2.8	3.0	3.3	2.3	1.9	1.4
	PrecMax	29.4	2.2	3.5	3.0	2.2	2.4	4.0	5.3	5.7	5.9	3.9	3.2	4.4
	PrecMin	17.5	0.4	0.2	0.2	0.2	0.1	0.5	0.7	1.2	1.0	0.9	0.8	0.5
	PrecStd	3.0	0.5	0.9	0.6	0.5	0.6	0.8	1.1	1.1	1.3	0.7	0.7	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.4	38.4	50.7	70.1	77.9	82.4	80.1	69.5	57.4	40.4	37.6
		MCWB	29.5	30.0	34.1	41.9	54.0	60.6	63.7	64.1	58.9	52.3	37.8	35.2
	2%	DB	24.1	23.8	32.7	43.8	61.6	71.2	76.5	73.9	63.7	50.2	36.8	32.9
		MCWB	23.0	22.6	30.2	38.1	49.3	56.9	61.7	61.6	56.5	46.2	34.7	31.3
	5%	DB	18.5	15.8	28.4	39.4	54.8	66.0	72.2	69.6	58.7	45.9	34.4	28.1
		MCWB	17.6	14.6	26.3	35.1	45.7	54.4	59.4	59.6	53.0	42.3	32.6	26.5
	10%	DB	12.4	10.3	23.5	35.6	48.6	61.1	67.7	65.4	54.7	42.8	31.7	23.3
		MCWB	11.4	9.1	21.7	32.4	42.0	51.9	57.6	57.6	49.9	39.9	30.0	22.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.9	29.8	34.5	42.2	54.6	64.4	66.2	66.2	61.8	52.4	38.3	35.7
		MCDB	31.8	31.0	37.6	48.5	69.1	70.8	76.7	75.1	67.0	56.9	39.7	37.4
	2%	WB	23.0	22.7	30.6	38.4	50.0	59.0	63.5	63.5	57.0	46.9	35.1	31.4
		MCDB	24.0	23.9	32.8	43.0	60.4	68.5	72.8	71.8	61.4	49.7	36.4	33.0
	5%	WB	17.6	14.6	26.3	35.5	46.1	55.4	61.0	60.9	53.7	42.7	32.7	26.6
		MCDB	18.5	15.6	28.3	39.1	54.1	65.3	70.4	67.7	58.4	45.2	34.1	28.0
	10%	WB	11.4	9.2	21.6	32.6	42.5	51.9	58.5	58.2	50.1	40.1	30.0	22.1
		MCDB	12.4	10.2	23.3	35.7	48.5	60.5	66.8	64.9	54.2	42.5	31.6	23.3
Mean Daily Temperature Range	5% DB	MDBR	14.4	16.4	18.1	16.6	14.6	18.0	18.1	16.5	12.8	9.4	10.5	12.9
		MCDBR	17.1	19.2	20.2	19.9	27.2	27.8	26.2	23.6	19.5	14.0	10.6	12.0
		MCWBR	17.0	18.9	18.4	15.5	16.6	16.3	13.8	13.4	13.2	11.1	10.2	11.5
	5% WB	MCDBR	17.2	18.9	19.8	18.8	25.9	25.1	22.9	21.1	17.7	13.4	10.7	11.9
		MCWBR	17.1	18.6	18.2	15.1	16.3	16.4	13.7	13.2	13.1	11.4	10.6	11.5
Clear-Sky Solar Irradiance	taub	0.216	0.244	0.269	0.358	0.359	0.347	0.364	0.354	0.329	0.290	0.248	0.206	
	taud	2.156	2.232	2.209	1.983	2.193	2.432	2.418	2.460	2.501	2.493	2.173	2.054	
	Ebn at Noon	210	258	281	266	276	282	274	269	260	241	188	169	
	Edh at Noon	15	23	31	47	41	33	33	30	24	18	15	12	
All-Sky Solar Radiation	RadAvg	200	521	1051	1571	1710	1641	1513	1202	736	374	163	115	
	RadStd	16	39	93	143	199	153	123	101	60	29	22	9	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+1.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page