

INUKJUAK, QC, Canada

WMO: 719070

Lat: 58.4672N

Lon: 78.0786W

Elev: 24

StdP: 101.03

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.7	-33.5	-40.2	0.1	-35.6	-37.9	0.1	-33.3	15.8	-19.1	14.1	-16.9	2.0	50	1.006

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	21.6	14.6	19.3	13.5	17.2	12.5	15.7	19.9	14.3	18.1	12.9	16.4	5.4	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.9	10.0	17.3	12.4	9.0	15.7	11.1	8.2	14.1	44.2	20.2	40.3	18.1	36.6	16.5	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.9	13.2	11.8	-38.7	25.4	2.4	1.9	-40.4	26.8	-41.8	27.9	-43.1	29.0	-44.9	30.4		
(5)			-38.8	17.8	2.4	1.3	-40.5	18.8	-41.9	19.5	-43.2	20.3	-44.9	21.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.1	-22.9	-24.3	-19.1	-10.1	-1.0	6.0	11.2	10.6	6.2	1.0	-6.1	-14.4
	DBStd	13.32	6.34	5.91	7.16	6.18	4.82	4.41	3.68	2.99	2.74	3.38	4.92	7.23
	HDD10.0	5661	1021	962	903	604	342	137	29	27	117	280	483	757
	HDD18.3	8570	1279	1195	1161	854	598	370	222	241	363	538	733	1015
	CDD10.0	134	0	0	0	0	2	17	66	46	4	0	0	0
	CDD18.3	2	0	0	0	0	0	0	2	1	0	0	0	0
	CDH23.3	21	0	0	0	0	1	2	13	4	1	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	5.8	5.5	5.3	5.8	6.0	5.9	5.7	5.5	5.7	6.3	6.2	6.0	6.2
Precipitation	PrecAvg	500	21	21	38	22	28	37	43	59	81	57	48	38
	PrecMax	775	71	49	229	48	74	67	120	128	157	119	105	88
	PrecMin	293	0	2	0	1	4	12	3	9	23	18	15	11
	PrecStd	101	17	14	51	13	18	15	25	24	32	22	16	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.7	-5.3	0.9	4.5	18.7	23.0	25.2	23.5	16.3	10.7	3.9	0.5
		MCWB	-4.1	-5.6	0.4	2.8	11.5	14.9	16.0	16.3	12.4	8.9	3.4	-0.1
	2%	DB	-7.4	-9.5	-2.8	2.1	12.3	19.7	22.3	20.0	13.2	7.8	2.0	-1.2
		MCWB	-7.9	-9.8	-3.5	1.1	8.2	12.3	14.7	14.9	10.4	6.6	1.5	-1.7
	5%	DB	-10.1	-12.2	-5.5	0.8	8.2	17.0	20.0	17.7	11.5	6.3	1.0	-2.6
		MCWB	-10.4	-12.6	-6.0	0.0	5.7	11.2	13.7	13.6	9.5	5.4	0.5	-3.2
	10%	DB	-13.2	-15.0	-8.4	-0.8	5.1	14.2	17.9	15.5	10.1	5.1	0.2	-4.1
		MCWB	-13.5	-15.4	-8.9	-1.5	3.3	9.8	13.0	12.3	8.7	4.3	-0.5	-4.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.9	-5.6	0.5	3.1	12.3	16.3	17.4	17.5	13.6	9.4	3.4	0.0
		MCDB	-3.6	-5.3	1.3	4.2	18.4	21.1	23.0	20.9	15.3	10.4	3.7	0.3
	2%	WB	-7.9	-9.9	-3.4	1.3	8.3	13.4	15.6	15.9	11.0	6.9	1.6	-1.7
		MCDB	-7.5	-9.7	-3.0	2.0	11.7	18.2	20.3	19.4	12.2	7.5	1.9	-1.3
	5%	WB	-10.4	-12.6	-6.0	0.1	5.7	11.5	14.5	14.2	9.8	5.5	0.6	-3.2
		MCDB	-10.1	-12.3	-5.4	0.7	8.2	16.6	18.8	17.0	11.0	6.2	0.9	-2.7
	10%	WB	-13.5	-15.4	-8.9	-1.5	3.4	9.7	13.2	12.6	8.9	4.4	-0.4	-4.6
		MCDB	-13.2	-15.1	-8.4	-0.8	4.9	14.1	17.2	15.0	10.0	5.0	0.2	-4.1
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.6	8.4	7.8	6.0	8.3	8.0	6.2	4.8	4.0	5.6	6.7
		MCDBR	8.9	9.5	9.5	7.5	11.2	13.7	12.0	10.3	7.0	5.3	4.0	5.8
		MCWBR	8.9	9.5	9.4	7.1	7.6	7.7	6.0	5.6	4.7	4.6	4.2	5.9
	5% WB	MCDBR	9.0	9.5	9.5	7.3	10.9	13.0	10.7	9.1	5.8	5.0	4.0	5.9
		MCWBR	9.0	9.4	9.4	7.0	7.6	7.8	6.2	5.6	4.5	4.5	4.2	6.1
Clear-Sky Solar Irradiance	taub	0.220	0.250	0.295	0.342	0.342	0.351	0.368	0.355	0.347	0.305	0.254	0.196	
	taud	2.083	2.140	2.080	1.991	2.175	2.401	2.431	2.474	2.441	2.474	2.195	2.086	
	Ebn at Noon	627	786	840	853	886	885	860	847	792	731	573	546	
	Edh at Noon	49	78	112	147	132	107	102	91	81	58	45	34	
All-Sky Solar Radiation	RadAvg	0.57	1.54	3.09	4.62	5.29	5.73	5.17	3.88	2.41	1.15	0.39	0.25	
	RadStd	0.05	0.12	0.32	0.56	0.60	0.50	0.47	0.27	0.20	0.12	0.05	0.04	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page