

GILLAM, MB, Canada

WMO: 719120

Lat: 56.360N

Lon: 94.710W

Elev: 145

StdP: 99.59

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.9	-34.9	-41.2	0.1	-36.7	-39.4	0.1	-34.7	10.9	-19.8	9.5	-20.2	3.5	270	0.790

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	27.3	17.8	25.4	16.9	23.6	16.2	19.5	24.7	18.2	23.1	17.2	22.0	4.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	12.9	21.7	16.3	11.8	20.4	15.1	10.9	19.5	56.5	24.7	52.3	23.1	48.9	22.2	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.7	9.4	8.4	-39.9	31.7	2.2	2.0	-41.6	33.2	-42.9	34.3	-44.1	35.5	-45.7	37.0
			-40.0	22.3	2.2	1.9	-41.6	23.7	-42.9	24.8	-44.1	25.9	-45.7	27.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.1	-23.8	-21.4	-14.3	-4.4	3.9	12.2	16.2	14.6	8.8	0.7	-11.0	-20.0	(6)	(7)
	DBStd	15.32	7.27	6.91	7.92	7.41	5.76	4.82	3.62	3.64	4.41	4.45	7.02	7.94	(7)	(8)
	HDD10.0	5279	1048	879	753	434	204	31	2	4	74	289	629	931	(8)	(9)
	HDD18.3	7863	1306	1113	1012	683	448	191	84	126	286	546	879	1189	(9)	(10)
	CDD10.0	496	0	0	0	1	16	97	195	147	39	1	0	0	(10)	(11)
	CDD18.3	39	0	0	0	0	1	7	19	11	1	0	0	0	(11)	(12)
	CDH23.3	455	0	0	0	0	12	110	210	109	13	1	0	0	(12)	(13)
	CDH26.7	88	0	0	0	0	1	22	42	22	2	0	0	0	(13)	(14)
	WSAvg	4.1	3.8	3.9	3.9	4.0	4.2	4.0	3.9	4.2	4.5	4.7	4.2	3.8	(14)	(15)
(15) Precipitation	PrecAvg	518	21	17	23	31	48	56	86	77	57	41	35	25	(15)	(16)
	PrecMax	719	39	36	41	70	136	128	163	127	94	105	81	46	(16)	(17)
	PrecMin	352	6	6	4	5	6	14	31	19	32	8	12	8	(17)	(18)
	PrecStd	108	10	7	10	16	30	28	39	34	20	24	20	12	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.0	0.7	7.1	18.0	25.3	29.3	30.6	29.4	25.1	15.4	4.5	-0.8	(19)	(20)
		MCWB	-2.5	-0.3	3.2	9.8	14.7	18.5	20.6	19.6	17.2	9.6	2.6	-1.4	(20)	(21)
	2%	DB	-6.0	-3.5	4.0	12.4	20.8	26.4	27.5	26.1	21.6	11.8	1.8	-3.7	(21)	(22)
		MCWB	-6.5	-4.6	1.1	6.1	12.2	16.2	18.0	18.0	15.4	8.5	0.7	-4.2	(22)	(23)
	5%	DB	-9.0	-7.2	1.1	9.1	17.1	24.0	25.6	24.0	18.5	9.0	0.2	-6.0	(23)	(24)
		MCWB	-9.5	-8.0	-0.6	4.3	10.3	15.2	17.3	17.1	13.8	6.8	-0.4	-6.4	(24)	(25)
	10%	DB	-12.4	-10.5	-1.8	6.1	13.9	21.6	23.8	21.6	15.8	6.8	-1.3	-8.0	(25)	(26)
		MCWB	-12.8	-11.2	-3.3	2.4	8.4	14.3	16.7	16.0	12.3	5.1	-1.9	-8.4	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.5	-0.1	3.4	10.2	15.2	21.3	21.8	20.8	18.4	11.1	2.9	-1.4	(27)	(28)
		MCDB	-2.0	0.8	6.5	17.7	22.4	26.5	28.3	26.5	22.9	14.1	4.1	-1.0	(28)	(29)
	2%	WB	-6.5	-4.6	1.3	6.7	12.9	18.0	19.6	19.2	16.1	8.8	0.9	-4.1	(29)	(30)
		MCDB	-6.0	-3.5	3.6	11.6	19.7	23.5	24.8	24.2	20.7	11.4	1.7	-3.7	(30)	(31)
	5%	WB	-9.4	-8.1	-0.6	4.5	10.8	16.3	18.4	18.0	14.2	6.9	-0.4	-6.4	(31)	(32)
		MCDB	-9.0	-7.2	1.1	8.7	16.2	22.2	23.4	22.5	17.9	8.9	0.2	-6.0	(32)	(33)
	10%	WB	-12.8	-11.2	-3.4	2.5	8.8	14.8	17.4	16.7	12.7	5.2	-1.8	-8.3	(33)	(34)
		MCDB	-12.4	-10.4	-1.9	5.8	13.6	20.5	22.4	20.7	15.6	6.6	-1.3	-7.9	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	10.4	12.2	12.1	11.2	12.2	11.2	9.9	8.6	6.0	7.0	7.6	(35)	(36)
		MCDBR	9.1	12.1	12.7	14.5	17.0	15.7	14.3	13.8	13.4	10.5	6.4	8.0	(36)	(37)
	5% WB	MCWBR	9.0	11.3	10.3	9.4	9.8	7.7	7.0	7.4	7.9	7.4	5.8	7.9	(37)	(38)
		MCWBR	9.2	11.8	11.8	13.9	15.6	13.7	12.1	11.9	11.8	9.7	6.3	7.9	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.230	0.262	0.271	0.333	0.340	0.354	0.403	0.358	0.326	0.285	0.259	0.212	(39)	(40)
		taud	2.208	2.218	2.271	2.221	2.400	2.407	2.322	2.442	2.514	2.545	2.246	2.159	(40)	(41)
	Ebn at Noon		696	809	902	882	900	888	831	852	836	795	639	618	(41)	(42)
		Edh at Noon	52	78	96	120	107	108	116	96	78	58	50	41	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		0.81	1.91	3.55	5.26	5.56	5.82	5.40	4.23	2.82	1.44	0.69	0.51	(43)	(44)
	RadStd		0.06	0.14	0.28	0.44	0.46	0.56	0.35	0.40	0.27	0.19	0.07	0.06	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page