

SATURNA CAPMON, BC, Canada

WMO: 719140

Lat: 48.7753N

Lon: 123.1281W

Elev: 178

StdP: 99.20

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.6	-2.9	-13.8	1.2	-1.9	-10.7	1.5	-1.1	5.2	4.3	4.5	3.7	1.8	60	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	26.7	16.8	24.8	16.0	23.1	15.5	17.9	23.5	17.0	22.7	16.2	21.6	1.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.4	20.0	14.7	10.7	18.6	14.0	10.2	17.7	51.0	23.8	48.2	22.9	46.0	21.7	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.9	3.2	2.5	DB	-6.5	30.1	1.9	2.3	-7.9	31.8	-9.0	33.1	-10.0	34.4	-11.4	36.0	(4)
(5)			WB	-8.3	18.8	2.1	1.9	-9.8	20.2	-11.0	21.3	-12.2	22.3	-13.7	23.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	4.1	4.2	6.1	8.4	12.2	14.3	17.4	17.6	14.9	10.1	6.2	3.3	(6)
(7)		DBStd	5.82	2.81	3.13	2.64	2.61	3.08	3.07	3.03	2.84	2.98	2.32	3.07	3.08	(7)
(8)		HDD10.0	898	184	161	124	62	11	1	0	0	1	27	118	209	(8)
(9)		HDD18.3	3142	442	394	380	298	193	129	56	49	112	257	364	467	(9)
(10)		CDD10.0	868	0	0	3	13	78	130	229	237	146	29	4	0	(10)
(11)		CDD18.3	72	0	0	0	0	2	9	26	28	8	0	0	0	(11)
(12)		CDH23.3	344	0	0	0	1	7	47	144	117	28	0	0	0	(12)
(13)		CDH26.7	54	0	0	0	0	0	7	32	14	2	0	0	0	(13)
(14)	Wind	WSAvg	1.0	1.0	1.0	1.0	0.9	0.9	1.0	1.1	0.9	0.9	1.1	1.1	(14)	
(15)	Precipitation	PrecAvg	837	121	73	77	51	42	35	22	27	46	94	125	122	(15)
(16)		PrecMax	1036	193	154	149	116	75	68	51	107	138	258	217	206	(16)
(17)		PrecMin	588	60	13	24	2	0	3	0	3	4	10	46	46	(17)
(18)		PrecStd	116	36	31	30	26	20	17	13	23	32	51	48	41	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	11.2	15.5	20.0	24.4	27.7	30.1	28.5	26.4	18.0	14.0	11.5	(19)
(20)			MCWB	9.6	8.5	9.1	11.6	14.3	16.9	18.8	16.7	16.0	13.2	11.8	10.3	(20)
(21)		2%	DB	9.8	10.0	12.7	16.2	21.6	24.4	26.8	26.2	23.6	16.0	12.5	9.6	(21)
(22)			MCWB	8.7	7.9	8.3	9.9	13.6	15.4	17.4	16.4	15.1	11.9	11.3	8.5	(22)
(23)		5%	DB	8.8	9.0	11.0	14.0	19.6	21.7	24.6	24.4	21.5	14.5	11.2	8.2	(23)
(24)			MCWB	7.7	7.3	7.7	9.2	12.9	14.7	16.6	15.9	14.9	11.5	10.1	7.1	(24)
(25)		10%	DB	7.7	8.0	9.7	12.2	17.5	19.4	22.6	22.7	19.6	13.2	10.1	7.2	(25)
(26)			MCWB	6.7	6.5	7.3	8.2	12.0	13.8	15.9	15.7	14.0	10.7	9.1	6.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	9.9	10.6	12.4	15.6	18.2	21.1	18.6	17.5	14.4	12.7	10.9	(27)
(28)			MCDWB	10.6	10.6	13.5	18.3	21.4	23.9	27.0	24.5	22.8	15.9	13.2	11.3	(28)
(29)		2%	WB	9.2	8.6	9.2	10.9	14.5	16.3	18.6	17.5	16.5	13.3	11.5	8.8	(29)
(30)			MCDWB	9.6	9.4	11.3	14.9	19.8	22.5	24.4	23.2	21.4	14.9	12.1	9.6	(30)
(31)		5%	WB	7.8	7.6	8.4	9.7	13.4	15.1	17.1	16.8	15.6	12.1	10.2	7.3	(31)
(32)			MCDWB	8.5	8.5	10.2	12.8	18.2	20.3	22.8	22.5	19.8	13.6	11.0	8.1	(32)
(33)		10%	WB	6.9	6.7	7.6	8.8	12.4	14.1	16.2	16.1	14.9	11.2	9.3	6.3	(33)
(34)			MCDWB	7.6	7.7	9.3	11.5	16.6	18.9	21.7	21.5	18.3	12.7	10.1	7.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.4	4.1	5.4	6.2	7.4	7.5	8.3	7.9	6.5	4.6	3.8	3.1	(35)
(36)			MCDBR	4.3	5.2	6.9	8.6	10.2	9.9	10.4	9.8	9.0	6.2	4.4	3.7	(36)
(37)			MCWBR	3.3	3.4	4.0	4.4	4.8	4.5	4.2	3.9	3.7	3.7	3.4	3.3	(37)
(38)		5% WB	MCDWB	4.0	4.4	6.1	7.3	9.1	8.9	9.5	8.9	7.7	5.2	4.1	3.8	(38)
(39)			MCWBR	3.4	3.4	3.9	4.4	5.0	4.6	4.5	4.2	3.7	3.7	3.6	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.307	0.323	0.350	0.370	0.347	0.343	0.349	0.333	0.325	0.313	0.305	(40)	
(41)		taud	2.536	2.575	2.544	2.459	2.419	2.497	2.542	2.524	2.567	2.575	2.545	2.517	(41)	
(42)		Ebn at Noon	763	861	899	901	891	913	912	892	876	826	754	720	(42)	
(43)		Edh at Noon	60	71	85	102	111	103	97	95	83	70	58	54	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.90	1.77	2.73	4.19	5.40	5.86	6.46	5.46	3.84	2.11	1.07	0.72	(44)	
(45)		RadStd	0.13	0.25	0.34	0.41	0.44	0.61	0.49	0.38	0.32	0.26	0.18	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page