

BACCARO POINT, NS, Canada

WMO: 719200

Lat: **43.4508N**Lon: **65.4717W**Elev: **15**StdP: **14.69**Time Zone: **-4.00 (NAA)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.7	13.7	3.5	6.6	13.1	7.1	7.9	16.5	49.0	31.6	43.4	31.0	16.8	340	0.805

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	68.1	63.9	66.0	62.9	64.2	61.8	65.4	66.7	63.8	65.1	62.5	63.7	11.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	92.2	65.9	63.3	87.2	64.4	61.9	82.9	63.1	30.3	67.0	29.2	65.4	28.1	63.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
41.2	35.8	31.1	DB	4.3	74.8	4.4	2.4	1.1	76.5	-1.5	77.9	-3.9	79.2	-7.1	80.9	
			WB	5.0	69.9	3.9	2.2	2.2	71.4	-0.1	72.7	-2.3	74.0	-5.1	75.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.8	29.9	29.6	33.4	40.0	46.2	53.0	56.9	58.6	57.7	51.8	43.7	35.7	
	DBStd	11.82	8.65	7.26	5.84	3.98	3.38	3.56	3.09	3.50	3.95	5.56	6.66	7.56	
	HDD50	2841	623	572	515	301	126	11	0	0	1	46	203	443	
	HDD65	7380	1088	992	980	750	583	360	253	199	220	409	639	907	
	CDD50	939	0	0	0	0	8	101	213	268	232	103	13	1	
	CDD65	3	0	0	0	0	0	0	0	2	1	0	0	0	
	CDH74	4	0	0	0	0	0	1	0	3	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	14.8	18.4	17.9	17.5	15.8	13.5	11.9	10.4	10.4	12.2	15.6	16.5	17.6	
Precipitation	PrecAvg	53.7	5.2	3.8	5.0	4.6	3.9	3.4	3.5	4.7	5.2	5.5	5.6		
	PrecMax	66.4	9.4	6.1	12.0	7.2	8.3	5.4	7.1	6.6	13.3	12.7	9.9	8.8	
	PrecMin	40.7	2.2	2.1	1.7	1.7	1.3	1.0	0.8	1.0	1.7	1.9	2.4	3.0	
	PrecStd	7.3	1.7	1.3	2.6	1.5	1.9	1.3	1.7	1.7	2.6	2.5	2.0	1.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.1	46.1	47.8	53.3	60.2	69.5	70.1	71.8	69.8	65.3	59.2	53.4	
		MCWB	48.9	45.1	44.1	47.4	52.5	58.6	64.2	66.1	65.2	61.4	58.0	52.8	
	2%	DB	46.1	43.1	44.6	49.1	55.5	63.4	66.0	67.8	67.4	62.8	56.3	50.9	
		MCWB	45.3	42.3	42.9	45.3	51.3	57.9	62.8	64.7	64.3	61.3	54.9	50.2	
	5%	DB	44.0	40.9	42.6	46.9	52.9	60.0	63.6	65.8	65.4	61.2	54.4	48.7	
		MCWB	43.2	39.8	41.0	44.6	49.8	56.8	61.3	63.3	63.0	59.7	53.0	47.9	
	10%	DB	41.7	39.0	40.8	45.3	51.0	57.8	61.8	64.0	63.6	59.6	52.7	46.5	
		MCWB	40.6	37.9	39.5	43.3	48.8	55.5	60.1	62.0	61.5	57.8	51.3	45.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.6	45.4	46.2	49.5	55.0	62.0	66.0	68.6	67.5	63.7	58.4	52.7
			MCDB	47.7	45.6	47.1	50.5	57.6	65.4	67.8	70.5	67.9	64.1	58.8	52.9
2%		WB	44.9	42.4	43.6	46.8	52.4	59.2	63.6	65.9	65.0	62.1	55.4	50.3	
		MCDB	45.4	42.7	44.3	47.7	54.3	61.7	65.1	67.2	66.0	62.7	55.9	50.7	
5%		WB	42.8	40.1	41.5	45.5	50.9	57.5	62.0	64.0	63.6	60.6	53.3	48.3	
		MCDB	43.2	40.5	42.3	46.7	52.5	59.7	63.2	65.3	64.6	61.3	53.9	48.8	
10%		WB	40.1	38.1	39.7	43.9	49.4	56.0	60.5	62.6	61.9	58.9	51.6	45.9	
		MCDB	40.9	38.8	40.6	45.3	51.0	57.9	61.6	63.8	63.0	59.9	52.5	46.7	
Mean Daily Temperature Range		5% DB	MDBR	11.4	10.4	9.2	7.7	7.7	8.7	8.9	9.1	9.0	9.3	9.6	10.8
			MCDBR	13.1	11.4	10.7	10.7	11.6	13.8	12.6	11.7	10.7	10.3	9.8	11.0
	MCWBR		14.1	11.6	10.1	8.2	8.3	9.4	9.3	8.1	8.9	8.6	10.2	11.7	
	5% WB	MCDBR	13.1	11.3	10.5	9.2	10.5	12.5	11.3	10.2	9.5	8.6	9.8	10.8	
		MCWBR	14.2	12.1	10.3	8.1	8.2	9.3	9.4	8.1	8.1	8.3	10.5	11.7	
Clear-Sky Solar Irradiance	taub	0.317	0.316	0.340	0.362	0.387	0.414	0.427	0.409	0.369	0.351	0.334	0.318		
	taud	2.435	2.468	2.436	2.410	2.386	2.338	2.331	2.375	2.445	2.501	2.503	2.474		
	Ebn at Noon	257	280	286	286	281	272	267	269	272	264	250	246		
	Edh at Noon	24	27	32	35	37	39	39	36	31	26	23	21		
All-Sky Solar Radiation	RadAvg	427	718	1133	1422	1603	1776	1724	1601	1356	878	499	356		
	RadStd	38	71	78	130	198	179	120	92	71	95	58	36		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-212	N/A	N/A
Regional (11 neighbors)		N/A	N/A	+1.51	N/A	+0.76	+0.86	N/A	N/A	+117	+9

Nomenclature: See separate page