

ENNADAI LAKE, NU, Canada

WMO: 719230

Lat: 61.132N

Lon: 100.884W

Elev: 353

StdP: 97.15

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -40.1	(c) -38.3	(d) -44.2	(e) 0.1	(f) -40.1	(g) -42.2	(h) 0.1	(i) -38.2	(j) 18.6	(k) -24.7	(l) 16.8	(m) -23.9	(n) 5.8	(o) 320	(p) 1.034

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	24.1	15.5	21.8	14.4	19.8	13.7	16.6	21.5	15.4	20.1	14.4	18.6	5.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	10.8	18.5	13.5	10.1	17.2	12.4	9.3	16.0	48.0	21.8	44.3	20.3	41.4	18.7	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	14.5	13.0	-41.9	27.7	1.7	1.6	-43.1	28.9	-44.1	29.8	-45.0	30.7	-46.2	31.9
			-41.4	18.6	2.2	1.5	-43.0	19.7	-44.3	20.5	-45.5	21.3	-47.2	22.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.6	-27.6	-25.6	-21.0	-12.1	-2.5	9.0	14.1	11.9	5.6	-3.9	-16.0	-24.5
	DBStd	16.05	7.38	7.02	8.20	7.71	6.27	5.06	3.65	3.51	4.45	5.24	6.58	7.50
	HDD10.0	6708	1167	998	962	663	389	78	6	20	143	431	781	1068
	HDD18.3	9488	1426	1231	1221	913	647	282	138	202	382	689	1031	1327
	CDD10.0	272	0	0	0	0	1	48	133	78	11	0	0	0
	CDD18.3	11	0	0	0	0	0	2	7	2	0	0	0	0
	CDH23.3	88	0	0	0	0	1	24	55	9	0	0	0	0
	CDH26.7	7	0	0	0	0	0	2	4	1	0	0	0	0
Wind	WSAvg	6.5	6.5	6.7	6.8	6.8	6.4	6.0	5.8	6.3	7.2	7.1	6.3	5.8
Precipitation	PrecAvg	326	10	5	10	14	22	38	59	46	52	39	15	11
	PrecMax	471	44	14	42	29	74	71	120	91	178	104	29	21
	PrecMin	222	3	0	1	3	2	8	18	20	12	9	4	2
	PrecStd	61	9	4	11	8	17	16	31	18	37	23	7	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.1	-4.4	1.5	5.5	16.8	26.1	27.4	24.5	18.6	10.6	0.0	-5.1
		MCWB	-6.5	-4.8	0.0	3.4	9.3	15.0	16.8	16.3	13.2	7.6	-0.3	-5.5
	2%	DB	-10.2	-8.8	-1.9	2.9	12.5	23.1	25.0	21.6	16.1	6.8	-2.4	-7.8
		MCWB	-10.5	-9.3	-2.9	1.4	7.7	13.6	16.2	15.0	11.7	5.3	-2.6	-8.0
	5%	DB	-13.0	-12.1	-5.3	1.4	8.7	20.2	22.7	19.6	13.9	4.7	-4.4	-10.4
		MCWB	-13.2	-12.4	-5.9	0.3	5.5	12.8	14.9	14.1	10.5	3.8	-4.6	-10.6
	10%	DB	-16.8	-14.9	-8.6	-0.6	5.8	17.5	20.8	17.6	11.9	2.7	-6.5	-13.0
		MCWB	-17.0	-15.1	-9.1	-1.5	3.5	11.4	14.2	13.2	9.6	2.0	-6.8	-13.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-6.6	-4.7	0.0	3.5	10.8	17.3	19.0	17.8	13.9	8.2	-0.3	-5.4
		MCDB	-6.4	-4.3	1.3	5.2	14.7	22.0	24.7	23.1	17.3	10.2	0.0	-5.0
	2%	WB	-10.3	-9.1	-2.8	1.6	7.8	15.0	17.1	15.9	12.3	5.5	-2.6	-8.1
		MCDB	-10.2	-8.7	-2.0	2.8	12.2	21.1	22.2	19.8	15.1	6.8	-2.4	-7.9
	5%	WB	-13.3	-12.4	-5.9	0.4	5.6	13.2	15.9	14.7	11.0	3.7	-4.6	-10.7
		MCDB	-13.0	-12.1	-5.3	1.4	8.7	19.0	21.0	18.3	13.3	4.5	-4.4	-10.5
	10%	WB	-17.1	-15.1	-9.0	-1.5	3.5	11.7	14.9	13.7	9.8	2.0	-6.7	-13.3
		MCDB	-16.9	-14.9	-8.6	-0.6	5.8	17.0	19.5	16.8	11.7	2.6	-6.5	-13.1
Mean Daily Temperature Range		MDBR	7.3	7.7	8.8	9.5	8.0	9.7	8.7	7.3	6.2	4.9	6.6	7.0
	5% DB	MCDBR	12.2	11.0	10.6	9.6	12.3	13.7	11.8	10.4	9.4	6.7	8.0	11.5
		MCWBR	11.7	10.9	9.8	8.4	8.2	6.6	4.9	5.2	5.8	5.4	7.6	10.9
		MCDBR	12.1	11.1	10.6	9.4	11.7	12.4	10.2	9.1	8.7	6.4	7.7	11.0
	5% WB	MCWBR	11.7	11.0	9.9	8.3	8.1	6.9	5.1	5.4	5.9	5.3	7.6	10.8
Clear-Sky Solar Irradiance	taub	0.191	0.239	0.253	0.307	0.317	0.345	0.357	0.341	0.306	0.262	0.192	0.152	
	taud	2.080	2.200	2.260	2.155	2.320	2.411	2.408	2.449	2.538	2.409	2.102	1.948	
	Ebn at Noon	586	767	886	884	905	883	860	848	825	739	570	466	
	Edh at Noon	37	65	87	120	111	104	102	90	69	53	35	24	
All-Sky Solar Radiation	RadAvg	0.36	1.25	3.05	5.13	5.98	5.84	5.28	3.94	2.40	0.98	0.42	0.18	
	RadStd	0.03	0.07	0.21	0.33	0.40	0.60	0.35	0.30	0.27	0.13	0.05	0.02	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page