

BAKER LAKE AP, NU, Canada

WMO: 719260

Lat: 64.299N

Lon: 96.078W

Elev: 61

StdP: 14.66

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.9	-39.4	-48.2	0.3	-40.8	-46.5	0.4	-39.1	41.3	-21.8	38.6	-20.5	9.1	320	1.036

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	72.1	58.2	67.0	55.9	62.8	53.9	59.5	68.9	57.1	65.1	54.8	61.8	12.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.4	65.4	62.5	52.9	59.6	60.3	50.6	54.8	58.1	26.2	69.1	24.5	65.0	23.1	62.1	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.6	30.9	27.7	-44.6	80.5	3.5	4.2	-47.1	83.5	-49.1	85.9	-51.0	88.3	-53.5	91.3		
			-44.5	64.0	3.4	2.7	-47.0	65.9	-49.0	67.5	-50.9	69.0	-53.3	70.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	-22.8	-23.0	-14.2	2.5	21.8	42.0	53.9	51.0	38.9	21.9	-0.2	-13.7
	DBStd	29.24	11.56	10.41	12.52	11.50	9.52	7.32	6.00	5.59	6.93	9.08	12.43	12.18
	HDD50	13621	2258	2043	1991	1424	876	258	28	53	338	872	1506	1974
	HDD65	18844	2723	2463	2456	1874	1341	691	346	434	784	1337	1956	2439
	CDD50	256	0	0	0	0	0	17	149	85	5	0	0	0
	CDD65	3	0	0	0	0	0	0	2	1	0	0	0	0
	CDH74	86	0	0	0	0	0	12	60	14	0	0	0	0
	CDH80	9	0	0	0	0	0	2	6	1	0	0	0	0
Wind	WSAvg	12.6	14.0	14.0	12.9	13.4	12.5	10.1	10.0	11.3	12.2	13.4	13.5	13.9
Precipitation	PrecAvg	10.5	0.4	0.3	0.5	0.6	0.6	0.9	1.5	1.7	1.7	1.3	0.7	0.4
	PrecMax	15.2	1.1	1.1	1.5	1.6	1.7	2.3	3.9	3.7	3.7	3.4	2.4	1.3
	PrecMin	6.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.3	0.2	0.0	0.0
	PrecStd	2.3	0.3	0.2	0.3	0.4	0.4	0.6	1.0	1.0	0.8	0.7	0.5	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	7.9	21.3	33.8	43.7	74.1	79.9	75.5	62.8	42.3	30.4	23.8
		MCWB	12.7	6.7	20.5	32.8	39.3	58.3	61.9	61.3	53.5	40.3	29.5	23.2
	2%	DB	4.1	2.9	14.9	28.9	38.6	63.3	74.8	68.4	56.3	37.7	26.1	14.9
		MCWB	3.1	1.9	14.1	27.7	35.8	52.4	59.0	56.7	50.1	36.2	25.4	14.2
	5%	DB	0.1	-1.3	10.0	24.4	36.0	58.1	69.9	63.9	51.8	35.3	23.2	9.6
		MCWB	-0.7	-2.2	9.1	23.3	34.0	49.3	57.0	54.8	47.5	34.1	22.3	8.9
	10%	DB	-4.9	-6.3	5.4	20.3	33.9	53.5	65.4	60.6	48.9	33.6	19.4	5.1
		MCWB	-5.6	-7.0	4.6	19.3	32.4	46.6	55.0	53.5	45.7	32.5	18.6	4.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	7.3	20.5	33.0	39.7	58.7	63.5	62.2	55.0	40.6	30.0	23.5
		MCDB	13.2	8.1	21.1	33.8	43.1	72.4	76.7	72.1	61.6	42.1	30.5	23.9
	2%	WB	3.2	2.0	14.1	28.0	36.0	53.2	60.6	58.6	51.0	36.5	25.5	14.2
		MCDB	3.9	2.9	14.8	29.0	38.1	62.0	71.2	65.3	55.0	37.4	25.9	14.7
	5%	WB	-0.7	-2.1	9.3	23.4	34.2	49.7	58.3	56.3	48.3	34.2	22.4	8.9
		MCDB	0.1	-1.3	10.1	24.4	35.6	57.3	67.5	62.0	51.3	35.1	23.2	9.6
	10%	WB	-5.7	-7.0	4.6	19.4	32.7	46.8	56.0	54.0	45.9	32.7	18.6	4.2
		MCDB	-5.0	-6.4	5.3	20.3	34.0	52.9	64.4	59.2	48.6	33.6	19.4	4.9
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.4	13.4	14.6	10.9	14.6	17.5	14.4	11.0	9.3	12.0	12.0
		MCDBR	16.8	17.6	16.7	16.0	11.2	24.5	25.2	21.2	17.4	8.9	12.7	17.1
		MCWBR	16.7	17.3	16.5	15.4	9.2	15.3	13.1	12.1	12.1	8.4	12.8	16.8
	5% WB	MCDBR	16.9	17.6	17.1	15.9	10.7	23.7	22.9	18.9	16.4	8.8	13.0	16.9
		MCWBR	16.8	17.3	16.9	15.5	8.9	15.4	13.2	12.1	12.0	8.4	13.0	16.8
Clear-Sky Solar Irradiance	taub	0.161	0.231	0.256	0.323	0.349	0.332	0.349	0.334	0.305	0.261	0.166	0.149	
	taud	1.927	2.151	2.228	2.060	2.132	2.452	2.456	2.494	2.506	2.258	1.925	1.920	
	Ebn at Noon	141	223	268	266	270	281	272	266	252	206	128	64	
	Edh at Noon	8	18	26	40	41	31	30	26	21	16	8	3	
All-Sky Solar Radiation	RadAvg	56	299	868	1611	2027	1818	1716	1219	673	239	80	20	
	RadStd	5	20	39	69	123	140	133	106	75	37	13	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page