

NORTH COWICHAN, BC, Canada

WMO: 719270

Lat: 48.8242N

Lon: 123.7189W

Elev: 147

StdP: 14.62

Time Zone: -8.00 (NAP)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	20.3	23.5	11.7	10.0	25.7	18.0	13.7	29.8	9.9	43.1	8.4	43.4	0.6	0	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	86.8	64.8	83.2	63.9	79.6	62.8	66.5	82.3	65.1	79.8	63.7	77.2	4.4	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	80.9	69.5	59.4	76.0	69.0	58.0	72.3	67.9	31.1	82.1	30.0	80.5	29.0	77.3	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.5	7.4	6.6	DB	13.3	92.1	5.5	2.9	9.3	94.1	6.1	95.8	3.0	97.5	-1.0	99.6
			WB	13.1	68.8	5.6	1.8	9.0	70.1	5.7	71.1	2.6	72.1	-1.5	73.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	38.1	38.9	42.6	47.3	55.1	59.8	65.2	65.4	59.2	49.9	42.5	36.9	(6)
	DBStd	11.38	5.36	5.55	4.95	4.79	5.53	5.13	4.53	4.52	4.72	4.58	5.95	6.08	(7)
	HDD50	1735	370	311	234	107	16	1	0	0	1	56	232	407	(8)
	HDD65	5570	834	730	694	532	308	172	52	51	184	467	674	872	(9)
	CDD50	1785	0	1	4	25	175	295	472	476	276	54	7	0	(10)
	CDD65	147	0	0	0	0	1	16	59	62	9	0	0	0	(11)
	CDH74	2362	0	0	0	8	100	281	872	887	214	0	0	0	(12)
	CDH80	692	0	0	0	0	12	85	263	285	47	0	0	0	(13)
(14) Wind	WSAvg	2.1	1.7	2.0	2.4	2.8	2.5	2.7	2.5	2.2	1.9	1.8	1.8	1.6	(14)
(15) Precipitation	PrecAvg	45.1	7.4	4.2	4.2	2.6	1.9	1.5	0.9	1.3	1.5	4.5	7.4	7.5	(15)
	PrecMax	57.8	13.4	12.5	8.8	4.3	3.4	2.9	1.9	4.8	4.2	11.5	15.3	11.8	(16)
	PrecMin	33.4	1.6	0.9	1.1	0.6	0.4	0.4	0.1	0.2	0.2	0.7	2.5	3.7	(17)
	PrecStd	7.0	2.8	2.5	1.7	1.1	0.8	0.6	0.5	1.1	1.3	2.3	3.4	2.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	55.2	64.8	73.6	81.7	87.7	90.8	90.7	85.6	69.8	59.3	52.9	(19)
		MCWB	48.9	47.5	54.8	55.9	61.0	63.9	66.4	65.5	64.6	56.8	53.2	49.0	(20)
	2%	DB	50.0	52.2	58.4	65.2	76.8	81.9	86.5	86.9	80.0	65.4	55.8	49.1	(21)
		MCWB	47.1	46.8	49.3	52.0	59.0	62.9	64.8	64.8	61.7	54.5	51.9	46.6	(22)
	5%	DB	47.5	49.6	54.5	61.0	72.6	76.0	82.5	83.2	75.3	61.6	53.3	47.0	(23)
		MCWB	45.1	45.4	46.6	49.9	57.6	60.7	63.8	64.7	60.4	53.6	49.6	45.1	(24)
	10%	DB	45.5	47.6	51.3	57.2	68.3	71.8	78.8	78.9	70.7	58.6	51.2	45.3	(25)
		MCWB	43.6	44.3	46.0	48.0	56.2	59.1	63.0	63.2	58.8	52.7	48.7	43.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	50.7	53.8	56.8	62.4	67.9	69.0	67.8	66.5	60.1	55.6	50.1	(27)
		MCDB	52.0	52.6	62.5	69.1	77.1	80.5	87.2	84.0	79.9	66.2	57.2	52.3	(28)
	2%	WB	47.8	48.4	50.3	53.6	60.3	64.0	66.4	66.3	64.2	57.2	52.7	47.2	(29)
		MCDB	49.5	50.3	54.1	62.9	74.0	78.6	82.7	82.5	75.3	61.0	54.7	48.3	(30)
	5%	WB	45.4	46.5	48.2	51.2	58.3	61.7	64.9	65.0	61.8	55.0	50.9	45.5	(31)
		MCDB	47.0	49.0	51.8	58.5	69.4	73.3	79.8	79.8	71.8	59.2	52.6	46.6	(32)
	10%	WB	43.9	44.7	46.3	49.4	56.5	59.8	63.4	63.7	60.0	53.4	49.0	43.8	(33)
		MCDB	45.3	47.1	49.9	55.1	66.1	70.1	77.0	77.2	68.2	57.5	50.9	44.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	13.3	15.4	17.4	19.9	19.6	22.9	23.1	20.7	16.4	13.1	10.9	(35)
		MCDBR	12.3	16.6	21.5	26.0	30.1	28.7	30.9	32.2	31.1	22.6	14.9	11.1	(36)
	5% WB	MCWBR	9.3	10.8	11.9	13.5	14.2	12.2	12.2	13.0	14.5	13.4	10.3	8.7	(37)
		MCWBR	11.2	12.3	14.7	20.9	24.4	24.9	27.7	27.4	25.0	17.2	11.5	9.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.316	0.310	0.328	0.358	0.373	0.357	0.346	0.349	0.334	0.330	0.316	0.308	(40)
		taud	2.528	2.571	2.531	2.433	2.410	2.467	2.541	2.529	2.570	2.562	2.544	2.518	(41)
	Ebn at Noon		240	272	283	283	282	286	288	283	278	259	238	227	(42)
		Edh at Noon	19	23	27	33	36	34	31	30	26	23	18	17	(43)
(44) All-Sky Solar Radiation	RadAvg		283	561	858	1319	1697	1841	2011	1699	1209	666	337	227	(44)
	RadStd		41	80	108	129	141	190	155	124	102	84	57	32	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (70 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page