

POOL'S ISLAND, NL, Canada

WMO: 719310

Lat: 49.1127N

Lon: 53.5825W

Elev: 19

StdP: 101.09

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.7	-14.6	-20.8	0.6	-15.7	-18.8	0.7	-14.0	20.8	-1.6	19.1	-1.6	6.8	280	0.885

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	24.4	18.1	22.3	17.6	20.6	16.9	19.7	22.4	18.6	21.0	17.5	19.8	8.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.5	21.2	17.6	12.6	19.9	16.6	11.8	18.7	56.4	22.4	52.8	21.1	49.5	19.8	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 17.6	15.6	13.5	DB	-19.3	28.1	3.1	1.7	-21.5	29.4	-23.3	30.4	-25.0	31.4	-27.3	32.6	(4)
(5)			WB	-19.7	21.4	3.2	1.0	-22.0	22.1	-23.9	22.7	-25.7	23.3	-28.0	24.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.6	-5.1	-5.5	-3.2	1.1	5.2	9.6	15.2	15.9	12.5	7.6	2.9	-1.5	(6)
(7)		DBStd	8.19	4.41	4.66	4.19	2.88	3.38	3.97	3.72	2.92	3.24	3.15	3.36	3.76	(7)
(8)		HDD10.0	2465	467	435	409	268	156	56	4	1	12	89	213	356	(8)
(9)		HDD18.3	5034	725	668	667	518	408	264	111	87	177	333	462	614	(9)
(10)		CDD10.0	499	0	0	0	0	7	43	165	182	87	14	1	0	(10)
(11)		CDD18.3	25	0	0	0	0	0	1	12	11	1	0	0	0	(11)
(12)		CDH23.3	107	0	0	0	0	1	15	50	37	4	0	0	0	(12)
(13)		CDH26.7	13	0	0	0	0	0	2	7	4	0	0	0	0	(13)
(14)	Wind	WSAvg	6.8	7.9	7.6	7.5	7.0	6.4	6.0	5.6	5.7	6.4	6.8	7.3	7.7	(14)
(15)	Precipitation	PrecAvg	1151	91	82	85	88	82	77	91	98	115	111	106	112	(15)
(16)		PrecMax	1312	173	125	142	215	131	141	165	137	203	195	177	166	(16)
(17)		PrecMin	1054	49	41	37	44	32	33	45	36	37	57	68	72	(17)
(18)		PrecStd	90	39	21	26	43	27	29	30	29	39	39	29	30	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	6.2	7.5	12.8	20.8	25.5	27.4	26.9	23.6	18.9	14.1	10.3	(19)
(20)			MCWB	7.5	5.5	5.5	8.0	14.2	17.6	19.6	19.5	18.3	14.8	12.4	9.3	(20)
(21)		2%	DB	4.9	3.9	5.0	8.8	16.0	21.1	24.6	24.1	20.7	15.7	11.2	6.5	(21)
(22)			MCWB	4.6	3.2	3.6	6.1	11.4	16.0	18.4	18.1	16.7	13.7	10.3	5.8	(22)
(23)		5%	DB	2.5	2.0	3.1	6.5	12.8	18.0	22.4	22.0	18.9	13.8	9.6	4.6	(23)
(24)			MCWB	1.8	1.5	2.1	4.5	9.4	14.5	17.7	17.9	15.7	11.8	8.6	4.0	(24)
(25)		10%	DB	0.8	0.8	1.6	4.8	10.3	15.7	20.5	20.2	17.3	12.2	7.8	3.2	(25)
(26)			MCWB	0.3	0.3	0.8	3.3	8.1	12.9	17.1	17.1	14.9	10.8	7.0	2.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.3	5.6	6.0	9.4	15.2	19.3	21.5	20.9	19.5	16.2	12.6	9.2	(27)
(28)			MCDB	7.7	6.0	6.7	10.9	19.3	23.3	25.7	23.7	21.9	17.3	13.8	9.9	(28)
(29)		2%	WB	4.4	3.4	3.9	6.6	12.0	16.9	19.9	19.6	17.9	14.1	10.5	6.0	(29)
(30)			MCDB	4.7	3.8	4.7	8.5	14.8	20.1	22.7	22.3	19.6	15.4	11.0	6.4	(30)
(31)		5%	WB	1.9	1.6	2.2	4.8	10.0	15.0	18.6	18.6	16.5	12.3	8.8	4.0	(31)
(32)			MCDB	2.3	1.9	3.0	6.1	12.5	17.7	21.0	20.9	18.1	13.2	9.4	4.4	(32)
(33)		10%	WB	0.4	0.3	1.0	3.5	8.2	13.0	17.4	17.5	15.3	11.0	7.0	2.7	(33)
(34)			MCDB	0.7	0.7	1.5	4.6	10.2	15.5	19.9	19.6	16.9	12.0	7.6	3.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.7	7.0	6.3	5.2	6.5	6.8	7.0	6.0	6.3	5.4	5.1	5.5	(35)
(36)			MCDBR	9.6	7.7	7.7	8.5	11.8	11.8	10.5	9.3	9.0	8.0	7.4	7.4	(36)
(37)			MCWBR	9.5	7.8	7.0	6.3	7.8	7.3	5.8	5.1	5.8	6.4	7.2	7.7	(37)
(38)		5% WB	MCDBR	9.2	7.5	7.1	7.8	10.8	11.2	9.3	8.1	7.7	7.4	7.4	7.2	(38)
(39)			MCWBR	9.5	7.6	6.8	6.4	7.9	7.6	6.1	5.3	5.9	6.6	7.4	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.300	0.332	0.362	0.373	0.399	0.416	0.395	0.368	0.344	0.317	0.308	(40)	
(41)		taud	2.297	2.358	2.269	2.324	2.399	2.355	2.356	2.413	2.471	2.480	2.462	2.303	(41)	
(42)		Ebn at Noon	737	852	875	885	887	863	841	843	833	792	734	677	(42)	
(43)		Edh at Noon	72	85	110	116	113	119	117	106	91	76	62	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.86	1.62	2.80	4.02	4.77	5.11	5.21	4.39	3.34	1.98	1.08	0.68	(44)	
(45)		RadStd	0.07	0.17	0.29	0.42	0.43	0.43	0.53	0.32	0.23	0.23	0.12	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page