

FORT SMITH, NT, Canada

WMO: 719340

Lat: 60.026N

Lon: 111.929W

Elev: 205

StdP: 98.88

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.0	-35.5	-40.4	0.1	-36.4	-38.2	0.1	-34.5	7.4	-17.0	6.5	-17.8	0.8	300	0.661

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	28.2	17.1	26.5	16.2	24.8	15.4	18.4	25.5	17.5	24.0	16.6	22.8	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	11.7	20.3	14.9	10.9	19.4	14.0	10.2	18.7	53.0	25.6	50.0	24.2	47.3	23.0	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.3	5.6	-40.6	31.3	2.1	1.5	-42.1	32.4	-43.3	33.3	-44.5	34.1	-46.0	35.2		
(5)			-39.6	20.7	1.6	1.7	-40.7	21.9	-41.6	22.8	-42.5	23.8	-43.6	25.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.3	-21.8	-18.7	-11.8	-0.8	8.2	15.1	17.4	15.0	9.1	0.8	-10.2	-18.4	(6)
(7)		DBStd	15.22	8.42	7.56	8.80	7.03	5.60	4.07	3.22	3.69	4.46	4.68	6.69	8.35	(7)
(8)		HDD10.0	4749	987	804	677	326	98	7	0	4	69	287	607	882	(8)
(9)		HDD18.3	7208	1246	1038	936	573	316	111	57	113	278	543	857	1140	(9)
(10)		CDD10.0	637	0	0	0	2	43	159	229	161	41	2	0	0	(10)
(11)		CDD18.3	54	0	0	0	0	2	13	28	11	1	0	0	0	(11)
(12)		CDH23.3	693	0	0	0	0	41	188	308	144	12	0	0	0	(12)
(13)		CDH26.7	129	0	0	0	0	4	31	62	31	1	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.0	2.2	2.4	2.6	2.7	2.4	2.3	2.3	2.6	2.4	2.3	2.1	(14)
(15)	Precipitation	PrecAvg	365	20	14	15	14	30	46	59	54	38	30	23	20	(15)
(16)		PrecMax	556	43	34	36	46	70	140	155	144	80	109	52	43	(16)
(17)		PrecMin	233	1	1	1	0	2	10	8	7	1	4	2	4	(17)
(18)		PrecStd	69	11	8	8	11	18	32	28	28	18	19	11	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.1	1.7	10.2	18.8	27.0	29.6	30.5	30.2	25.1	16.6	6.3	0.3	(19)
(20)			MCWB	-2.0	-0.1	4.1	9.2	14.3	17.1	18.5	18.7	15.9	10.3	2.7	-0.9	(20)
(21)		2%	DB	-4.2	-2.3	6.5	15.2	24.3	27.3	28.4	26.8	21.6	12.3	1.6	-2.8	(21)
(22)			MCWB	-4.8	-3.2	2.1	7.0	12.5	15.9	17.5	16.8	14.1	7.7	0.5	-3.4	(22)
(23)		5%	DB	-7.6	-5.4	3.6	12.3	21.1	25.5	26.7	24.7	18.7	9.6	0.3	-5.1	(23)
(24)			MCWB	-8.1	-6.2	0.4	5.8	11.2	15.0	16.9	15.9	12.6	6.0	-0.4	-5.6	(24)
(25)		10%	DB	-10.4	-7.9	0.8	9.6	18.1	23.7	24.9	22.5	16.5	7.1	-1.5	-7.2	(25)
(26)			MCWB	-10.9	-8.6	-1.3	4.2	9.8	14.4	16.3	15.2	11.5	4.8	-2.1	-7.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.9	0.2	4.2	9.8	15.1	18.7	20.1	19.6	16.5	11.4	2.8	-0.7	(27)
(28)			MCDWB	-1.4	1.9	9.5	17.5	26.0	26.3	26.2	27.6	23.4	15.7	5.7	0.1	(28)
(29)		2%	WB	-4.6	-3.3	2.2	7.5	13.2	17.4	18.8	17.9	14.7	7.9	0.7	-3.4	(29)
(30)			MCDWB	-4.1	-2.4	6.1	14.1	22.1	24.5	26.0	24.3	20.1	11.7	1.5	-2.7	(30)
(31)		5%	WB	-7.9	-6.1	0.5	6.0	11.8	16.2	17.8	16.8	13.4	6.3	-0.3	-5.6	(31)
(32)			MCDWB	-7.5	-5.4	3.3	12.0	19.8	23.0	24.3	22.8	17.7	9.2	0.4	-5.1	(32)
(33)		10%	WB	-10.7	-8.6	-1.3	4.4	10.3	15.2	17.0	15.9	12.1	4.8	-2.1	-7.6	(33)
(34)			MCDWB	-10.3	-7.9	0.9	9.4	17.5	21.7	23.3	21.2	15.9	7.0	-1.5	-7.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	10.1	12.2	11.9	12.3	12.1	11.5	11.0	9.9	6.8	6.2	7.3	(35)
(36)			MCDBR	9.5	11.8	13.1	14.6	16.4	15.1	14.4	14.8	13.9	11.1	6.3	8.1	(36)
(37)			MCWBR	9.2	10.8	9.4	8.5	8.0	6.8	6.5	6.9	7.7	7.1	5.2	7.7	(37)
(38)		5% WB	MCDWR	9.6	11.6	12.8	13.9	14.7	12.6	12.5	12.7	12.2	10.2	6.1	7.9	(38)
(39)			MCWBR	9.3	10.7	9.4	8.2	7.6	6.2	6.3	6.6	7.1	6.7	5.2	7.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.211	0.245	0.267	0.317	0.338	0.360	0.393	0.355	0.314	0.278	0.218	0.171	(40)	
(41)		taud	2.143	2.276	2.284	2.311	2.434	2.389	2.350	2.445	2.569	2.548	2.240	2.052	(41)	
(42)		Ebn at Noon	601	787	877	884	890	871	828	838	827	753	594	516	(42)	
(43)		Edh at Noon	40	64	88	105	101	107	110	92	69	51	36	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.45	1.37	3.09	4.94	5.76	6.11	5.47	4.32	2.75	1.25	0.41	0.23	(44)	
(45)		RadStd	0.04	0.07	0.15	0.29	0.53	0.49	0.33	0.22	0.24	0.12	0.06	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page