

MACKENZIE, BC, Canada

WMO: 719440

Lat: 55.299N

Lon: 123.133W

Elev: 690

StdP: 93.30

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -29.8	(c) -25.6	(d) -34.6	(e) 0.2	(f) -28.5	(g) -30.6	(h) 0.2	(i) -24.5	(j) 8.4	(k) -1.0	(l) 7.5	(m) -2.6	(n) 1.3	(o) 0	(p) 0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	27.7	15.9	25.6	15.1	23.6	14.1	17.0	25.2	16.0	23.5	15.0	21.8	2.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	10.8	18.8	13.1	10.2	17.7	12.2	9.6	17.0	50.1	25.4	47.1	23.5	44.3	21.9	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.3	5.5	-34.0	31.1	5.6	1.8	-38.0	32.4	-41.3	33.4	-44.5	34.5	-48.6	35.8		
			-33.7	18.6	5.3	0.9	-37.6	19.2	-40.7	19.8	-43.6	20.2	-47.5	20.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-9.5	-7.7	-3.3	3.2	9.3	13.5	15.8	14.7	9.8	3.4	-3.7	-8.3	(6)
(7)		DBStd	10.46	9.05	7.01	6.37	3.63	3.83	3.03	2.84	3.15	3.47	3.63	5.53	7.19	(7)
(8)		HDD10.0	3010	603	495	413	206	59	4	0	2	44	206	410	567	(8)
(9)		HDD18.3	5557	862	728	671	455	280	148	89	120	255	463	660	826	(9)
(10)		CDD10.0	517	0	0	0	1	38	110	179	147	39	2	0	0	(10)
(11)		CDD18.3	21	0	0	0	0	1	3	11	7	0	0	0	0	(11)
(12)		CDH23.3	485	0	0	0	0	21	82	218	153	12	0	0	0	(12)
(13)		CDH26.7	108	0	0	0	0	2	12	59	33	1	0	0	0	(13)
(14)	Wind	WSAvg	2.2	2.2	2.0	2.3	2.3	2.2	2.2	2.0	2.1	2.2	2.2	2.1	(14)	
(15)	Precipitation	PrecAvg	686	78	57	47	25	45	64	65	51	65	69	74	(15)	
(16)		PrecMax	837	137	136	94	86	127	126	132	94	98	108	125	131	(16)
(17)		PrecMin	498	26	22	10	2	13	12	14	9	8	31	9	26	(17)
(18)		PrecStd	89	30	32	24	18	28	32	37	29	25	21	28	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	5.8	10.5	18.9	26.0	28.3	31.5	29.8	25.0	15.9	8.3	4.1	(19)
(20)			MCWB	2.6	2.1	4.4	9.3	13.0	15.5	17.2	16.8	14.7	10.2	5.7	1.8	(20)
(21)		2%	DB	3.5	3.7	7.9	14.7	22.8	25.7	28.1	27.2	21.9	12.8	5.2	2.4	(21)
(22)			MCWB	1.9	1.4	3.1	6.9	11.3	14.4	16.2	16.3	13.8	8.4	3.5	1.1	(22)
(23)		5%	DB	2.3	2.5	6.1	11.9	20.4	23.5	25.7	24.8	19.0	10.6	3.6	1.3	(23)
(24)			MCWB	1.1	0.7	2.1	5.3	10.6	13.4	15.4	15.3	12.5	7.3	2.1	0.4	(24)
(25)		10%	DB	1.2	1.3	4.5	9.9	18.0	21.1	23.3	22.3	16.3	8.8	2.4	0.3	(25)
(26)			MCWB	0.3	-0.1	1.4	4.1	9.9	12.5	14.6	14.4	11.0	6.2	1.3	-0.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.4	3.0	5.0	9.8	14.3	16.8	18.2	18.3	15.7	11.4	5.7	2.5	(27)
(28)			MCDWB	4.7	4.4	8.7	17.9	22.6	25.1	28.0	26.7	22.8	14.6	7.6	3.4	(28)
(29)		2%	WB	2.2	1.8	3.7	7.4	12.6	15.5	17.1	16.9	14.1	9.4	3.8	1.4	(29)
(30)			MCDWB	3.1	3.2	6.8	13.6	20.3	23.1	25.7	25.1	20.2	11.9	4.9	2.1	(30)
(31)		5%	WB	1.3	1.0	2.7	5.8	11.4	14.2	16.1	15.9	12.9	7.8	2.5	0.6	(31)
(32)			MCDWB	2.2	2.2	5.4	10.7	18.7	21.3	23.8	23.3	18.0	10.0	3.4	1.3	(32)
(33)		10%	WB	0.4	0.0	1.7	4.7	10.2	13.2	15.1	14.9	11.7	6.4	1.4	-0.3	(33)
(34)			MCDWB	1.3	1.2	4.2	8.9	16.8	19.6	21.9	21.3	15.5	8.4	2.2	0.4	(34)
(35)	Mean Daily Temperature Range	MDBR		6.6	8.9	10.1	11.0	12.9	12.2	12.4	12.6	11.0	7.4	5.4	5.9	(35)
(36)		5% DB	MCDBR	5.7	8.1	11.3	15.4	18.2	17.3	18.0	17.6	16.3	11.1	5.8	5.1	(36)
(37)			MCWBR	4.8	6.2	7.3	8.6	8.4	7.3	7.4	7.7	8.6	7.2	4.5	4.6	(37)
(38)		5% WB	MCDBR	5.4	7.1	10.2	13.7	15.5	14.6	15.5	15.9	14.4	9.7	5.4	5.1	(38)
(39)			MCWBR	4.7	5.6	7.0	8.1	7.5	6.6	6.8	7.2	7.9	6.8	4.5	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.237	0.259	0.274	0.311	0.336	0.346	0.340	0.337	0.303	0.289	0.261	0.222	(40)
(41)		taud		2.303	2.306	2.296	2.277	2.445	2.452	2.505	2.518	2.612	2.593	2.335	2.270	(41)
(42)		Ebn at Noon		727	837	907	913	908	899	899	881	877	808	680	658	(42)
(43)		Edh at Noon		51	74	96	114	103	104	97	90	72	58	50	41	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.59	1.48	2.75	4.49	5.36	5.68	5.46	4.63	3.01	1.56	0.64	0.43	(44)
(45)		RadStd		0.06	0.17	0.31	0.26	0.38	0.55	0.49	0.33	0.26	0.18	0.08	0.05	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+85	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page