

CAPE PARRY, NT, Canada

WMO: 719480

Lat: 70.167N

Lon: 124.717W

Elev: 87

StdP: 100.29

Time Zone: -7.00 (NAM)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-36.9	-35.2	-40.0	0.1	-36.4	-39.2	0.1	-35.7	19.1	-22.8	18.0	-23.8	4.1	250	1.150

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	16.0	12.1	13.3	10.6	11.2	9.2	12.1	15.1	10.5	12.7	9.1	10.7	4.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	7.7	13.4	8.9	7.2	11.9	7.8	6.6	10.3	34.5	15.0	30.7	12.9	27.5	10.8	17.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.7	13.5	-38.2	19.7	2.2	3.0	-39.8	21.8	-41.1	23.6	-42.3	25.3	-43.9	27.4		
(5)			-37.4	13.9	1.5	2.1	-38.5	15.4	-39.4	16.7	-40.2	17.9	-41.3	19.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.5	-25.6	-26.0	-24.1	-16.2	-6.2	2.1	6.3	5.9	1.5	-5.5	-16.7	-22.5
	DBStd	13.11	5.96	6.29	6.15	5.82	4.77	3.39	3.84	3.56	3.15	4.05	5.98	5.88
	HDD10.0	7503	1104	1007	1056	787	503	238	129	137	254	481	802	1006
	HDD18.3	10521	1363	1240	1314	1037	761	487	374	386	504	739	1052	1264
	CDD10.0	23	0	0	0	0	0	1	13	9	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.2	6.3	6.5	6.0	6.5	6.8	6.3	5.4	5.6	6.5	6.8	6.2	6.1
Precipitation	PrecAvg	192	8	8	9	8	10	14	30	38	27	19	12	8
	PrecMax	276	27	24	22	24	30	31	57	109	56	40	35	17
	PrecMin	126	1	1	0	1	1	2	5	16	7	6	2	2
	PrecStd	38	5	5	5	5	7	8	13	18	13	9	7	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.3	-7.2	-6.3	0.2	6.5	16.3	20.0	18.9	11.2	3.2	-1.7	-6.2
		MCWB	-7.8	-7.8	-6.6	-0.9	4.7	10.8	14.0	14.1	8.8	2.5	-2.3	-6.7
	2%	DB	-11.3	-11.1	-10.1	-3.4	2.8	11.5	16.9	15.2	8.5	1.2	-4.8	-8.8
		MCWB	-11.7	-11.5	-10.6	-4.2	1.8	8.3	12.2	12.2	6.8	0.6	-5.3	-9.1
	5%	DB	-14.6	-13.6	-12.6	-5.7	0.9	9.2	14.3	12.8	7.0	0.1	-6.9	-11.2
		MCWB	-15.0	-14.0	-13.1	-6.3	0.2	6.9	10.9	10.9	5.8	-0.5	-7.4	-11.6
	10%	DB	-17.0	-16.6	-15.1	-8.2	-0.4	7.0	11.9	10.7	5.6	-0.9	-8.6	-13.9
		MCWB	-17.4	-17.1	-15.5	-8.7	-0.9	5.4	9.5	9.4	4.6	-1.5	-9.2	-14.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.3	-6.5	-5.2	-0.1	2.6	10.0	14.2	14.3	9.0	2.6	-4.7	-5.4
		MCDB	-8.0	-6.1	-4.9	1.1	3.3	13.8	19.1	18.3	11.0	3.1	-4.4	-5.1
	2%	WB	-10.5	-10.2	-8.2	-4.4	0.7	8.1	12.4	12.3	6.8	1.5	-7.2	-8.6
		MCDB	-10.1	-9.8	-7.9	-3.7	1.2	10.6	16.3	14.9	7.9	1.9	-6.8	-8.4
	5%	WB	-14.5	-12.5	-11.1	-6.9	-0.2	6.7	10.9	10.7	5.6	0.3	-9.6	-10.6
		MCDB	-14.2	-12.1	-10.7	-6.3	0.3	8.8	13.7	12.4	6.6	0.8	-9.1	-10.3
	10%	WB	-17.1	-15.6	-13.4	-9.0	-1.4	5.4	9.5	9.3	4.7	-0.9	-12.0	-13.4
		MCDB	-16.7	-15.2	-13.0	-8.5	-1.0	7.0	11.5	10.2	5.4	-0.5	-11.6	-13.1
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.3	5.6	6.0	4.4	4.6	5.3	4.1	2.8	3.0	4.5	4.7
		MCDBR	8.2	8.5	7.4	7.0	5.7	9.6	10.0	7.8	5.3	2.9	4.6	6.9
		MCWBR	8.3	9.3	7.3	7.9	5.0	6.3	6.5	6.3	4.5	2.7	5.1	6.8
	5% WB	MCDBR	8.4	9.7	7.5	8.7	5.1	8.3	9.4	8.7	4.9	3.2	4.9	7.0
		MCWBR	8.4	9.6	7.4	8.4	4.7	6.2	6.4	6.2	4.0	3.0	4.9	6.9
Clear-Sky Solar Irradiance	taub	N/A	0.192	0.238	0.293	0.328	0.344	0.340	0.327	0.294	0.224	N/A	N/A	
	taud	N/A	2.022	2.166	2.073	2.088	2.282	2.444	2.531	2.538	2.180	N/A	N/A	
	Ebn at Noon	0	557	785	829	841	843	838	810	740	499	0	0	
	Edh at Noon	0	38	72	112	126	108	90	73	54	32	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.36	1.97	4.41	6.04	6.43	5.32	3.20	1.56	0.42	0.00	0.00	
	RadStd	0.00	0.04	0.07	0.19	0.47	0.59	0.57	0.36	0.15	0.06	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+1.05	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.56	+1.18	+1.54	N/A	N/A	N/A	-221	-215	N/A	N/A

Nomenclature: See separate page