

FARO, YT, Canada

WMO: 719490

Lat: 62.210N

Lon: 133.385W

Elev: 2351

StdP: 13.49

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-45.6	-39.1	-46.3	0.4	-38.0	-42.0	0.5	-33.4	19.5	16.4	17.5	13.4	1.6	130	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	78.4	57.6	74.8	56.1	71.3	54.6	59.6	73.6	57.9	70.6	56.4	68.0	5.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.6	69.1	61.2	52.7	64.5	60.2	51.1	60.6	59.3	27.1	73.9	26.0	70.9	24.9	68.1	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.3	14.0	12.2	-48.0	83.7	5.8	3.7	-52.2	86.3	-55.6	88.5	-58.8	90.6	-63.0	93.3		
			-43.7	62.7	4.7	3.2	-47.1	64.9	-49.9	66.8	-52.6	68.6	-56.0	70.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	-4.8	4.2	15.3	33.0	46.2	56.1	58.8	54.6	44.1	29.2	6.3	-1.7
	DBStd	25.74	19.81	16.11	14.32	8.56	7.18	5.35	4.34	5.72	6.30	9.31	15.29	17.27
	HDD50	8507	1700	1282	1077	510	163	7	1	17	193	644	1311	1602
	HDD65	13307	2165	1702	1542	959	583	272	195	325	627	1109	1761	2067
	CDD50	687	0	0	0	0	45	190	275	161	16	0	0	0
	CDD65	14	0	0	0	0	0	6	4	4	0	0	0	0
	CDH74	395	0	0	0	0	25	133	120	116	1	0	0	0
	CDH80	68	0	0	0	0	3	27	17	21	0	0	0	0
Wind	WSAvg	4.5	3.9	4.4	5.2	5.2	5.0	4.5	4.3	4.0	4.3	4.8	4.2	4.2
Precipitation	PrecAvg	19.1	1.6	1.0	0.9	0.6	1.1	1.8	2.2	2.4	2.3	2.0	1.8	1.5
	PrecMax	25.4	2.9	2.1	2.6	1.3	1.9	2.7	3.9	4.3	4.0	3.8	3.5	2.8
	PrecMin	11.7	0.5	0.2	0.2	0.0	0.4	0.4	0.9	1.1	0.8	1.0	0.6	0.7
	PrecStd	2.8	0.6	0.4	0.6	0.3	0.4	0.5	0.7	0.9	0.7	0.6	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	38.9	49.1	61.7	77.3	83.2	82.0	83.0	68.7	53.8	42.3	41.6
		MCWB	32.6	33.0	38.2	45.6	53.5	59.0	58.7	60.3	52.9	45.8	35.5	36.2
	2%	DB	31.5	33.1	42.6	54.5	71.4	77.8	77.1	77.1	62.1	48.0	34.1	31.7
		MCWB	28.9	29.0	34.3	41.0	50.8	56.6	57.9	58.5	49.8	40.9	30.8	28.9
	5%	DB	26.5	28.8	38.4	50.2	66.4	73.0	74.0	72.1	58.5	44.3	29.4	27.2
		MCWB	24.5	25.8	31.5	38.5	48.8	54.7	56.6	56.0	47.9	38.2	27.3	25.3
	10%	DB	20.0	24.7	34.6	46.8	61.9	69.0	70.7	67.4	55.5	40.9	25.2	21.7
		MCWB	18.7	22.3	28.9	36.6	46.6	52.9	55.5	54.1	46.1	36.5	23.6	20.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.4	33.5	39.4	46.0	54.7	62.3	61.9	62.0	54.9	47.0	36.3	35.6
		MCDB	37.1	38.3	48.0	60.0	73.4	78.7	75.8	79.9	65.2	52.6	41.2	42.2
	2%	WB	29.0	29.3	34.8	41.7	51.7	58.2	59.6	59.2	51.3	41.8	31.3	28.9
		MCDB	31.6	32.8	41.9	52.7	68.4	73.0	72.0	74.5	59.7	46.8	34.2	31.5
	5%	WB	24.9	25.9	31.8	39.2	49.5	56.1	58.2	57.1	48.8	39.0	27.3	25.2
		MCDB	27.0	28.8	37.7	49.2	64.8	69.8	69.9	70.0	56.5	43.5	29.4	27.3
	10%	WB	19.5	22.3	29.1	37.1	47.4	54.3	56.8	55.1	47.2	36.7	23.5	20.3
		MCDB	20.9	24.7	34.4	46.0	60.3	66.6	67.8	64.9	54.1	40.5	25.2	21.6
Mean Daily Temperature Range	5% DB	MDBR	13.4	17.3	22.5	20.8	22.0	20.8	19.7	19.6	17.7	12.6	12.7	13.3
		MCDBR	17.3	17.0	20.2	24.7	29.9	28.6	27.4	29.2	23.2	16.3	15.1	17.2
		MCWBR	15.0	13.8	13.6	14.2	13.8	12.0	11.6	13.0	12.6	10.3	12.8	15.2
	5% WB	MCDBR	17.2	16.4	18.7	22.5	27.4	24.3	22.9	25.1	20.6	14.7	15.2	17.1
		MCWBR	15.0	13.5	12.7	13.3	12.9	11.3	10.9	11.8	11.5	9.8	13.1	15.0
Clear-Sky Solar Irradiance	taub	0.207	0.239	0.260	0.327	0.367	0.379	0.380	0.363	0.308	0.269	0.196	0.175	
	taud	2.030	2.265	2.259	2.103	2.245	2.308	2.328	2.397	2.535	2.387	2.049	1.916	
	Ebn at Noon	154	239	274	270	269	267	264	259	258	223	157	101	
	Edh at Noon	11	18	27	40	38	36	35	30	22	16	10	6	
All-Sky Solar Radiation	RadAvg	83	334	902	1525	1748	1651	1542	1201	750	341	116	41	
	RadStd	7	38	63	94	79	112	107	102	89	37	14	2	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	+2.99	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page