

FARO, YT, Canada

WMO: 719490

Lat: 62.210N

Lon: 133.385W

Elev: 717

StdP: 93.01

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -43.1	(c) -39.5	(d) -43.5	(e) 0.1	(f) -38.9	(g) -41.1	(h) 0.1	(i) -36.3	(j) 8.7	(k) -8.6	(l) 7.8	(m) -10.3	(n) 0.7	(o) 130	(p) 0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	25.8	14.2	23.8	13.4	21.8	12.6	15.3	23.1	14.4	21.5	13.5	20.0	2.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	9.9	16.2	11.5	9.2	15.7	10.6	8.7	15.2	45.2	23.3	42.5	21.6	40.1	20.1	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.3	(b) 6.3	(c) 5.4	(e) -44.5	(f) 28.7	(g) 3.2	(h) 2.1	(i) -46.8	(j) 30.2	(k) -48.6	(l) 31.4	(m) -50.4	(n) 32.5	(o) -52.8	(p) 34.0		
(a) 7.3	(b) 6.3	(c) 5.4	(e) -42.1	(f) 17.0	(g) 2.6	(h) 1.8	(i) -44.0	(j) 18.3	(k) -45.5	(l) 19.3	(m) -47.0	(n) 20.3	(o) -48.9	(p) 21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.9	-20.5	-15.4	-9.3	0.6	7.9	13.4	14.9	12.6	6.7	-1.5	-14.3	-18.7
	DBStd	14.30	11.01	8.95	7.96	4.75	3.99	2.97	2.41	3.18	3.50	5.17	8.50	9.60
	HDD10.0	4726	944	712	598	283	91	4	1	9	107	358	728	890
	HDD18.3	7393	1203	946	857	533	324	151	108	181	348	616	978	1148
	CDD10.0	382	0	0	0	0	25	106	153	89	9	0	0	0
	CDD18.3	8	0	0	0	0	0	3	2	2	0	0	0	0
	CDH23.3	219	0	0	0	0	14	74	67	64	1	0	0	0
	CDH26.7	38	0	0	0	0	2	15	9	12	0	0	0	0
Wind	WSAvg	2.0	1.7	2.0	2.3	2.3	2.3	2.0	1.9	1.8	1.9	2.2	1.9	1.9
Precipitation	PrecAvg	486	41	26	24	16	27	45	57	60	59	51	45	37
	PrecMax	646	74	53	67	34	48	69	100	110	101	96	90	71
	PrecMin	297	12	6	6	1	9	11	22	28	20	25	15	17
	PrecStd	70	16	11	14	8	10	13	19	23	17	15	18	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.0	3.8	9.5	16.5	25.2	28.4	27.8	28.3	20.4	12.1	5.7	5.3
		MCWB	0.4	0.5	3.5	7.6	12.0	15.0	14.8	15.7	11.6	7.7	1.9	2.3
	2%	DB	-0.3	0.6	5.9	12.5	21.9	25.4	25.1	25.1	16.7	8.9	1.2	-0.1
		MCWB	-1.7	-1.7	1.3	5.0	10.4	13.7	14.4	14.7	9.9	4.9	-0.7	-1.7
	5%	DB	-3.0	-1.8	3.6	10.1	19.1	22.8	23.3	22.3	14.7	6.8	-1.5	-2.7
		MCWB	-4.2	-3.4	-0.3	3.6	9.4	12.6	13.7	13.3	8.8	3.4	-2.6	-3.7
	10%	DB	-6.7	-4.1	1.4	8.2	16.6	20.6	21.5	19.7	13.0	4.9	-3.8	-5.7
		MCWB	-7.4	-5.4	-1.7	2.5	8.1	11.6	13.1	12.3	7.9	2.5	-4.6	-6.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.8	0.8	4.1	7.8	12.6	16.8	16.6	16.6	12.7	8.3	2.4	2.0
		MCDB	2.9	3.5	8.9	15.5	23.0	25.9	24.3	26.6	18.4	11.4	5.1	5.6
	2%	WB	-1.7	-1.5	1.5	5.4	11.0	14.6	15.3	15.1	10.7	5.4	-0.4	-1.7
		MCDB	-0.2	0.5	5.5	11.5	20.2	22.8	22.2	23.6	15.4	8.2	1.2	-0.3
	5%	WB	-4.0	-3.4	-0.1	4.0	9.7	13.4	14.5	14.0	9.3	3.9	-2.6	-3.8
		MCDB	-2.8	-1.8	3.2	9.5	18.2	21.0	21.1	21.1	13.6	6.4	-1.5	-2.6
	10%	WB	-6.9	-5.4	-1.6	2.9	8.6	12.4	13.8	12.8	8.4	2.6	-4.7	-6.5
		MCDB	-6.2	-4.1	1.3	7.8	15.7	19.2	19.9	18.3	12.3	4.7	-3.8	-5.8
Mean Daily Temperature Range	5% DB	MDBR	7.4	9.6	12.5	11.6	12.2	11.5	10.9	10.9	9.8	7.0	7.0	7.4
		MCDBR	9.6	9.4	11.2	13.7	16.6	15.9	15.2	16.2	12.9	9.1	8.4	9.5
		MCWBR	8.3	7.7	7.6	7.9	7.7	6.7	6.4	7.2	7.0	5.7	7.1	8.4
	5% WB	MCDBR	9.5	9.1	10.4	12.5	15.2	13.5	12.7	13.9	11.5	8.2	8.4	9.5
		MCWBR	8.3	7.5	7.1	7.4	7.2	6.3	6.1	6.5	6.4	5.4	7.3	8.4
Clear-Sky Solar Irradiance	taub	0.207	0.239	0.260	0.327	0.367	0.379	0.380	0.363	0.308	0.269	0.196	0.175	
	taud	2.030	2.265	2.259	2.103	2.245	2.308	2.328	2.397	2.535	2.387	2.049	1.916	
	Ebn at Noon	485	755	865	851	847	843	831	816	813	704	496	318	
	Edh at Noon	34	58	86	125	119	115	110	94	68	52	32	20	
All-Sky Solar Radiation	RadAvg	0.26	1.05	2.84	4.81	5.51	5.21	4.86	3.79	2.36	1.07	0.37	0.13	
	RadStd	0.02	0.12	0.20	0.30	0.25	0.35	0.34	0.32	0.28	0.12	0.04	0.01	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	+1.66	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page