

BURNS LAKE DECKER LAKE, BC, Canada

WMO: 719520

Lat: 54.3833N

Lon: 125.9586W

Elev: 2340

StdP: 13.50

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -23.9	(c) -15.8	(d) -29.4	(e) 1.1	(f) -23.6	(g) -21.0	(h) 1.9	(i) -14.8	(j) 11.7	(k) 33.6	(l) 9.8	(m) 31.1	(n) 0.9	(o) 310	(p) 0.653

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.4	82.1	60.0	77.9	58.7	74.0	57.0	62.4	77.0	60.4	73.7	58.6	70.8	5.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.4	76.7	64.8	55.3	70.8	63.5	53.5	66.3	61.7	29.2	76.9	27.7	73.8	26.4	71.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.1	(b) 10.7	(c) 9.3	(e) -30.7	(f) 87.9	(g) 8.7	(h) 3.7	(i) -36.9	(j) 90.5	(k) -42.0	(l) 92.6	(m) -46.9	(n) 94.7	(o) -53.2	(p) 97.4		
(4) 12.1	(5) 10.7	(6) 9.3	(7) -31.1	(8) 65.8	(9) 8.7	(10) 2.4	(11) -37.4	(12) 67.6	(13) -42.5	(14) 69.0	(15) -47.4	(16) 70.3	(17) -53.7	(18) 72.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.1	15.0	18.6	27.3	37.1	46.3	52.6	56.2	54.7	47.3	37.2	25.2	14.8		
	DBStd	17.21	13.97	11.79	10.21	6.06	6.34	5.71	5.30	5.44	5.92	6.04	9.45	11.56		
	HDD50	5616	1086	879	703	388	149	35	9	16	120	398	743	1090		
	HDD65	10546	1551	1299	1168	837	580	374	276	321	530	862	1193	1555		
	CDD50	554	0	0	0	1	34	113	202	162	40	2	0	0		
	CDD65	7	0	0	0	0	0	2	4	1	0	0	0	0		
	CDH74	855	0	0	0	2	30	166	343	280	34	0	0	0		
	CDH80	215	0	0	0	0	2	47	100	63	3	0	0	0		
	WSAvg	2.9	2.0	2.3	3.3	3.8	3.9	3.7	3.5	3.0	2.8	2.7	2.3	2.0		
	PrecAvg	18.4	1.9	1.1	1.0	1.0	1.4	2.0	1.8	1.6	1.5	1.9	1.7	1.7		
(15) Precipitation	PrecMax	22.8	3.9	2.0	2.2	2.3	2.8	4.4	3.9	3.2	3.3	3.2	3.1	3.2		
	PrecMin	14.1	0.7	0.1	0.2	0.3	0.3	0.6	0.5	0.5	0.2	0.6	0.6	0.5		
	PrecStd	2.5	0.7	0.4	0.5	0.5	0.6	0.8	0.9	0.7	0.8	0.8	0.7	0.6		
	PrecStd	2.5	0.7	0.4	0.5	0.5	0.6	0.8	0.9	0.7	0.8	0.8	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	45.7	55.9	69.2	78.1	85.9	88.9	85.7	78.8	64.0	46.9	40.1		
		MCWB	38.3	38.7	43.4	49.9	55.4	63.0	62.5	61.3	58.2	51.7	42.2	36.6		
	2%	DB	38.7	41.2	49.0	60.2	72.6	78.5	82.3	81.3	72.7	56.1	42.2	36.2		
		MCWB	35.7	35.9	39.4	45.9	52.6	58.4	60.0	60.6	56.9	47.7	38.9	33.8		
	5%	DB	35.2	37.7	45.2	55.4	68.1	73.5	77.3	76.7	67.1	52.3	38.9	33.2		
		MCWB	33.7	33.5	37.2	42.8	50.6	56.2	59.1	59.2	54.3	45.6	36.6	32.0		
	10%	DB	32.2	34.5	42.1	51.2	63.5	69.0	72.7	72.0	62.0	48.9	36.3	30.7		
		MCWB	31.5	31.8	35.3	40.5	49.0	54.4	57.5	57.3	52.2	43.6	34.7	29.9		
	0.4%	WB	39.3	39.8	44.3	51.7	57.9	65.4	65.2	65.2	60.2	53.5	43.1	37.1		
		MCDB	42.4	44.5	54.3	66.8	70.2	80.4	80.0	80.1	73.3	59.1	45.9	39.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.0	36.3	40.2	46.9	54.2	60.3	62.4	62.1	57.7	49.5	39.4	34.1		
		MCDB	38.0	40.0	47.3	58.1	67.9	73.7	77.5	76.4	69.5	54.5	41.5	35.4		
	5%	WB	33.7	34.1	37.8	43.9	52.0	57.6	60.5	60.1	55.5	46.4	37.0	32.1		
		MCDB	35.1	36.9	44.0	53.0	64.5	70.0	73.5	73.6	65.4	51.2	38.5	33.2		
	10%	WB	31.4	32.2	35.9	41.5	50.2	55.5	58.6	58.1	53.2	43.9	34.8	29.8		
		MCDB	32.3	34.4	41.2	49.5	61.6	66.5	70.6	70.0	60.6	48.1	36.1	30.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.4	24.1	23.7	24.9	27.8	27.2	28.4	29.9	27.0	20.0	14.8	16.6		
		MCDBR	17.8	24.6	26.1	33.8	38.6	38.1	39.6	40.2	37.7	27.0	17.2	18.1		
		MCWBR	15.2	19.1	17.1	20.0	19.6	19.2	19.7	20.9	22.3	18.4	13.7	16.2		
	5% WB	MCDBR	16.0	22.0	23.6	29.6	32.2	33.0	34.4	35.0	32.9	24.8	15.1	17.6		
		MCWBR	13.7	17.4	16.0	18.1	17.2	17.1	18.1	19.1	20.1	17.6	12.3	15.8		
			(d) 17.4	(e) 24.1	(f) 23.7	(g) 24.9	(h) 27.8	(i) 27.2	(j) 28.4	(k) 29.9	(l) 27.0	(m) 20.0	(n) 14.8	(o) 16.6		
(40) Clear-Sky Solar Irradiance	taub		0.258	0.263	0.292	0.319	0.337	0.351	0.333	0.339	0.306	0.300	0.275	0.238		
	taud		2.281	2.346	2.314	2.380	2.458	2.445	2.540	2.520	2.608	2.566	2.367	2.302		
	Ebn at Noon		225	268	283	289	288	284	288	280	279	254	217	210		
	Edh at Noon		18	23	30	33	33	34	30	29	23	19	16	14		
(44) All-Sky Solar Radiation	RadAvg		206	487	880	1384	1654	1815	1766	1500	987	525	237	158		
	RadStd		25	60	74	74	137	159	172	72	92	63	32	18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+106	N/A

Nomenclature: See separate page