

BURNS LAKE DECKER LAKE, BC, Canada

WMO: 719520

Lat: 54.3833N

Lon: 125.9586W

Elev: 713

StdP: 93.05

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.1	-26.6	-34.1	0.2	-30.9	-29.4	0.3	-26.0	5.2	0.9	4.4	-0.5	0.4	310	0.653

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	27.9	15.5	25.5	14.8	23.3	13.9	16.9	25.0	15.8	23.2	14.8	21.6	2.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.1	11.0	18.2	12.9	10.1	17.5	11.9	9.5	16.5	49.9	24.9	46.6	23.2	43.5	21.7	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.8	4.2	-34.8	31.0	4.8	2.0	-38.3	32.5	-41.1	33.7	-43.8	34.8	-47.3	36.3		
			-35.1	18.8	4.8	1.3	-38.6	19.8	-41.4	20.5	-44.1	21.3	-47.6	22.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.3	-9.5	-7.4	-2.6	2.8	7.9	11.4	13.5	12.6	8.5	2.9	-3.8	-9.5	(6)
(7)		DBStd	9.56	7.76	6.55	5.67	3.37	3.52	3.17	2.94	3.02	3.29	3.36	5.25	6.42	(7)
(8)		HDD10.0	3120	603	488	391	216	83	19	5	9	67	221	413	606	(8)
(9)		HDD18.3	5859	862	722	649	465	322	208	153	178	294	479	663	864	(9)
(10)		CDD10.0	308	0	0	0	1	19	63	112	90	22	1	0	0	(10)
(11)		CDD18.3	4	0	0	0	0	0	1	2	1	0	0	0	0	(11)
(12)		CDH23.3	475	0	0	0	1	17	92	191	156	19	0	0	0	(12)
(13)		CDH26.7	119	0	0	0	0	1	26	56	35	2	0	0	0	(13)
(14)	Wind	WSAvg	1.3	0.9	1.0	1.5	1.7	1.7	1.6	1.4	1.2	1.2	1.0	0.9	(14)	
(15)	Precipitation	PrecAvg	468	47	28	26	25	35	50	46	40	37	49	43	42	(15)
(16)		PrecMax	580	99	52	57	58	71	111	99	81	83	82	79	82	(16)
(17)		PrecMin	359	17	3	6	8	8	14	12	5	15	16	13	13	(17)
(18)		PrecStd	64	18	10	12	13	16	21	22	17	20	20	18	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	7.6	13.3	20.7	25.6	29.9	31.6	29.8	26.0	17.8	8.3	4.5	(19)
(20)		MCWB	3.5	3.7	6.3	10.0	13.0	17.2	17.0	16.3	14.6	11.0	5.6	2.5	2.5	(20)
(21)		2%	DB	3.7	5.1	9.4	15.6	22.5	25.8	28.0	27.4	22.6	13.4	5.7	2.3	(21)
(22)		MCWB	2.1	2.1	4.1	7.7	11.4	14.7	15.5	15.9	13.8	8.7	3.8	1.0	1.0	(22)
(23)		5%	DB	1.8	3.2	7.3	13.0	20.1	23.1	25.2	24.8	19.5	11.3	3.9	0.7	(23)
(24)		MCWB	1.0	0.9	2.9	6.0	10.3	13.5	15.1	15.1	12.4	7.6	2.5	0.0	0.0	(24)
(25)		10%	DB	0.1	1.4	5.6	10.7	17.5	20.6	22.6	22.2	16.7	9.4	2.4	-0.7	(25)
(26)		MCWB	-0.3	-0.1	1.8	4.7	9.4	12.5	14.2	14.0	11.2	6.4	1.5	-1.2	-1.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	4.3	6.9	11.0	14.4	18.5	18.4	18.4	15.7	11.9	6.2	2.8	(27)
(28)		MCDWB	5.8	7.0	12.4	19.3	21.2	26.9	26.7	26.7	22.9	15.0	7.7	4.2	4.2	(28)
(29)		2%	WB	2.2	2.4	4.6	8.3	12.3	15.7	16.9	16.7	14.3	9.7	4.1	1.2	(29)
(30)		MCDWB	3.4	4.4	8.5	14.5	20.0	23.2	25.3	24.6	20.9	12.5	5.3	1.9	1.9	(30)
(31)		5%	WB	0.9	1.2	3.2	6.6	11.1	14.2	15.8	15.6	13.1	8.0	2.8	0.1	(31)
(32)		MCDWB	1.7	2.7	6.7	11.7	18.1	21.1	23.0	23.1	18.6	10.7	3.6	0.7	0.7	(32)
(33)		10%	WB	-0.3	0.1	2.2	5.3	10.1	13.0	14.8	14.5	11.8	6.6	1.6	-1.2	(33)
(34)		MCDWB	0.2	1.3	5.1	9.7	16.5	19.2	21.4	21.1	15.9	8.9	2.3	-0.8	-0.8	(34)
(35)	Mean Daily Temperature Range		MDBR	9.7	13.4	13.2	13.8	15.5	15.1	15.8	16.6	15.0	11.1	8.2	9.2	(35)
(36)		5% DB	MCDBR	9.9	13.7	14.5	18.8	21.4	21.2	22.0	22.3	21.0	15.0	9.6	10.1	(36)
(37)		MCWBR	8.4	10.6	9.5	11.1	10.9	10.6	11.0	11.6	12.4	10.2	7.6	9.0	9.0	(37)
(38)		5% WB	MCDBR	8.9	12.2	13.1	16.5	17.9	18.3	19.1	19.5	18.3	13.8	8.4	9.8	(38)
(39)	MCWBR	7.6	9.7	8.9	10.1	9.6	9.5	10.1	10.6	11.2	9.8	6.9	8.8	8.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.258	0.263	0.292	0.319	0.337	0.351	0.333	0.339	0.306	0.300	0.275	0.238	(40)	
(41)		taud	2.281	2.346	2.314	2.380	2.458	2.445	2.540	2.520	2.608	2.566	2.367	2.302	(41)	
(42)		Ebn at Noon	709	846	892	911	909	896	908	883	878	801	684	663	(42)	
(43)		Edh at Noon	56	74	96	105	103	106	94	91	73	61	52	44	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.65	1.53	2.77	4.36	5.21	5.72	5.57	4.73	3.11	1.65	0.75	0.50	(44)	
(45)		RadStd	0.08	0.19	0.23	0.23	0.43	0.50	0.54	0.23	0.29	0.20	0.10	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+61	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+59	N/A

Nomenclature: See separate page