

GORE BAY, ON, Canada

WMO: 719560

Lat: 45.8846N

Lon: 82.5743W

Elev: 619

StdP: 14.37

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.4	-6.5	-21.6	1.7	-11.8	-15.5	2.4	-5.5	29.7	24.4	26.7	25.4	6.4	30	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	81.5	68.8	78.8	67.4	76.5	66.3	71.9	77.8	70.1	75.5	68.5	73.6	10.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	112.3	75.3	68.2	106.0	73.2	66.6	100.1	71.4	36.1	78.2	34.5	75.6	33.1	73.6	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	22.8	20.4	-20.7	86.5	6.4	3.3	-25.4	88.8	-29.1	90.7	-32.7	92.6	-37.4	95.0
			-21.1	75.2	6.3	2.1	-25.6	76.8	-29.3	78.0	-32.9	79.2	-37.4	80.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.1	15.9	17.1	26.2	39.2	51.9	61.8	67.2	66.4	59.7	47.7	36.3	25.5	(6)
	DBStd	19.90	12.78	11.24	10.81	7.74	6.87	5.63	4.78	4.81	6.66	7.41	8.18	9.86	(7)
	HDD50	4417	1057	920	737	330	58	1	0	0	6	135	414	759	(8)
	HDD65	8252	1522	1340	1201	773	409	126	32	42	184	537	862	1224	(9)
	CDD50	1883	0	0	1	7	117	355	533	508	296	63	3	0	(10)
	CDD65	243	0	0	0	0	3	30	100	85	24	1	0	0	(11)
	CDH74	1131	0	0	0	0	23	175	514	345	73	1	0	0	(12)
	CDH80	147	0	0	0	0	1	19	79	42	6	0	0	0	(13)
(14) Wind	WSAvg	9.8	10.2	10.2	9.7	10.3	9.4	8.4	8.5	8.7	9.4	10.9	11.4	10.8	(14)
(15) Precipitation	PrecAvg	32.8	2.3	1.5	2.3	2.6	2.6	2.2	3.1	3.7	3.3	3.5	3.2		(15)
	PrecMax	43.6	4.3	3.0	5.1	4.8	5.9	5.6	7.9	7.0	8.5	7.7	7.0	6.3	(16)
	PrecMin	20.2	0.4	0.2	0.5	0.4	0.8	0.7	0.2	0.8	0.8	0.9	0.7	1.2	(17)
	PrecStd	5.2	0.9	0.7	1.1	1.0	1.4	1.3	1.3	1.5	1.6	1.6	1.5	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	42.1	55.5	66.0	77.0	82.4	86.0	84.3	80.2	69.3	57.3	49.0	(19)
		MCWB	42.2	39.9	48.9	52.7	64.3	68.6	70.4	71.3	69.0	62.1	52.5	47.9	(20)
	2%	DB	38.7	38.1	48.9	59.6	72.0	78.7	82.1	80.4	75.9	65.5	53.2	43.7	(21)
		MCWB	37.3	36.1	43.4	48.9	60.0	66.8	69.2	68.7	66.9	60.1	49.8	41.9	(22)
	5%	DB	35.8	35.6	44.3	55.1	68.1	75.5	79.2	77.6	72.8	62.3	50.3	40.8	(23)
		MCWB	34.4	33.9	39.8	46.0	57.6	64.6	67.4	67.2	65.5	58.0	47.6	39.2	(24)
	10%	DB	33.5	33.4	40.0	51.3	64.0	72.5	76.7	75.3	70.2	59.3	47.7	38.2	(25)
		MCWB	32.3	31.9	36.4	43.8	55.2	63.1	66.5	66.2	64.2	55.7	45.3	36.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.3	40.4	51.0	55.8	66.5	72.2	74.7	74.3	71.1	64.6	53.6	48.3	(27)
		MCDB	42.5	41.3	53.4	61.8	74.4	79.4	81.6	80.3	76.4	67.2	55.9	48.8	(28)
	2%	WB	37.4	36.4	44.5	51.1	62.8	69.5	72.0	71.8	69.0	61.3	50.6	42.5	(29)
		MCDB	38.2	37.7	47.5	56.9	68.9	75.3	78.3	77.0	73.4	64.5	52.5	43.4	(30)
	5%	WB	34.5	34.1	40.1	47.7	59.5	67.1	70.1	69.9	67.2	58.6	48.1	39.4	(31)
		MCDB	35.6	35.3	43.4	53.7	65.3	72.5	75.9	74.8	71.3	61.7	50.1	40.6	(32)
	10%	WB	32.3	32.0	36.6	44.5	56.5	64.8	68.2	68.2	65.3	56.1	45.5	36.6	(33)
		MCDB	33.6	33.3	39.6	49.7	62.1	70.0	73.9	72.8	69.4	59.1	47.5	38.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	16.2	16.1	16.3	17.8	17.4	16.2	15.4	14.6	12.3	10.4	10.9	(35)
		MCDBR	12.0	12.6	18.0	22.7	23.4	21.5	19.1	17.8	17.0	15.2	13.2	11.1	(36)
	5% WB	MCWBR	11.7	11.7	13.0	14.1	13.7	11.7	9.2	9.2	10.1	11.2	11.3	10.8	(37)
		MCWBR	12.2	13.0	16.0	20.2	19.7	17.9	16.1	15.0	14.9	14.1	12.2	11.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.288	0.296	0.313	0.353	0.370	0.396	0.400	0.389	0.364	0.345	0.310	0.286	(40)
		taud	2.411	2.355	2.391	2.339	2.402	2.348	2.367	2.392	2.446	2.467	2.511	2.473	(41)
	Ebn at Noon		260	280	292	287	285	277	274	272	270	259	251	249	(42)
		Edh at Noon	23	29	32	37	36	38	37	35	30	26	21	19	(43)
(44) All-Sky Solar Radiation	RadAvg		382	677	1152	1471	1764	1906	1910	1616	1250	742	399	281	(44)
	RadStd		43	73	106	141	164	153	84	92	112	79	52	28	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page