

GORE BAY, ON, Canada

WMO: 719560

Lat: 45.8846N

Lon: 82.5743W

Elev: 189

StdP: 99.08

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.7	-21.4	-29.8	0.2	-24.3	-26.4	0.3	-20.8	13.3	-4.2	12.0	-3.7	2.9	30	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	27.5	20.4	26.0	19.6	24.7	19.0	22.2	25.5	21.2	24.2	20.3	23.1	4.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	16.0	24.1	20.1	15.1	22.9	19.2	14.3	21.9	66.0	25.7	62.4	24.2	59.2	23.1	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.2	9.1	-29.3	30.3	3.6	1.8	-31.9	31.6	-34.0	32.6	-36.0	33.7	-38.6	35.0		
(5)			-29.5	24.0	3.5	1.2	-32.0	24.9	-34.1	25.6	-36.0	26.2	-38.6	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-8.9	-8.3	-3.2	4.0	11.1	16.6	19.1	15.4	8.7	2.4	-3.6	(6)	
(7)		DBStd	11.06	7.10	6.25	6.01	4.30	3.82	3.13	2.66	2.67	3.70	4.12	4.54	5.48	(7)
(8)		HDD10.0	2454	587	511	409	183	32	1	0	0	3	75	230	422	(8)
(9)		HDD18.3	4584	846	744	667	429	227	70	18	23	102	298	479	680	(9)
(10)		CDD10.0	1046	0	0	1	4	65	197	296	282	164	35	2	0	(10)
(11)		CDD18.3	135	0	0	0	0	2	17	56	47	13	1	0	0	(11)
(12)		CDH23.3	628	0	0	0	0	13	97	286	192	41	1	0	0	(12)
(13)		CDH26.7	82	0	0	0	0	1	11	44	23	3	0	0	0	(13)
(14)	Wind	WSAvg	4.4	4.6	4.6	4.3	4.6	4.2	3.7	3.8	3.9	4.2	4.9	5.1	4.8	(14)
(15)	Precipitation	PrecAvg	834	59	37	59	65	66	65	57	79	94	84	90	81	(15)
(16)		PrecMax	1107	108	76	129	122	150	141	201	179	216	195	179	161	(16)
(17)		PrecMin	513	11	6	13	11	20	19	6	20	21	22	18	30	(17)
(18)		PrecStd	133	23	18	29	25	35	32	34	37	40	40	37	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	5.6	13.1	18.9	25.0	28.0	30.0	29.1	26.8	20.7	14.1	9.4	(19)
(20)			MCWB	5.7	4.4	9.4	11.5	18.0	20.3	21.3	21.8	20.5	16.7	11.4	8.8	(20)
(21)		2%	DB	3.7	3.4	9.4	15.3	22.2	25.9	27.8	26.9	24.4	18.6	11.8	6.5	(21)
(22)			MCWB	2.9	2.3	6.3	9.4	15.6	19.3	20.7	20.4	19.4	15.6	9.9	5.5	(22)
(23)		5%	DB	2.1	2.0	6.8	12.8	20.1	24.2	26.2	25.4	22.7	16.9	10.2	4.9	(23)
(24)			MCWB	1.3	1.0	4.3	7.8	14.2	18.1	19.7	19.6	18.6	14.5	8.7	4.0	(24)
(25)		10%	DB	0.8	0.8	4.4	10.7	17.8	22.5	24.8	24.1	21.2	15.2	8.7	3.4	(25)
(26)			MCWB	0.2	0.0	2.4	6.6	12.9	17.3	19.2	19.0	17.9	13.2	7.4	2.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	4.7	10.6	13.2	19.1	22.3	23.7	23.5	21.7	18.1	12.0	9.0	(27)
(28)			MCDWB	5.8	5.2	11.9	16.6	23.6	26.3	27.6	26.8	24.7	19.6	13.3	9.4	(28)
(29)		2%	WB	3.0	2.4	6.9	10.6	17.1	20.8	22.2	22.1	20.6	16.3	10.3	5.8	(29)
(30)			MCDWB	3.4	3.2	8.6	13.8	20.5	24.1	25.7	25.0	23.0	18.0	11.4	6.4	(30)
(31)		5%	WB	1.4	1.2	4.5	8.7	15.3	19.5	21.1	21.1	19.6	14.8	8.9	4.1	(31)
(32)			MCDWB	2.0	1.8	6.3	12.0	18.5	22.5	24.4	23.8	21.8	16.5	10.0	4.8	(32)
(33)		10%	WB	0.2	0.0	2.6	6.9	13.6	18.2	20.1	20.1	18.5	13.4	7.5	2.5	(33)
(34)			MCDWB	0.9	0.7	4.2	9.9	16.7	21.1	23.3	22.7	20.8	15.0	8.6	3.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	9.0	8.9	9.0	9.9	9.7	9.0	8.5	8.1	6.8	5.8	6.1	(35)
(36)			MCDBR	6.6	7.0	10.0	12.6	13.0	11.9	10.6	9.9	9.5	8.5	7.3	6.2	(36)
(37)			MCWBR	6.5	6.5	7.2	7.8	7.6	6.5	5.1	5.1	5.6	6.2	6.3	6.0	(37)
(38)		5% WB	MCDBR	6.8	7.2	8.9	11.2	11.0	10.0	9.0	8.3	7.9	6.8	6.1	6.1	(38)
(39)			MCWBR	6.7	7.0	7.0	8.1	7.3	6.3	5.3	5.3	5.7	6.4	6.3	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.288	0.296	0.313	0.353	0.370	0.396	0.400	0.389	0.364	0.345	0.310	0.286	(40)	
(41)		taud	2.411	2.355	2.391	2.339	2.402	2.348	2.367	2.392	2.446	2.467	2.511	2.473	(41)	
(42)		Ebn at Noon	820	884	919	904	897	872	863	859	852	817	791	786	(42)	
(43)		Edh at Noon	71	90	101	117	114	121	118	110	96	82	65	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.20	2.13	3.63	4.64	5.56	6.01	6.02	5.09	3.94	2.34	1.26	0.89	(44)	
(45)		RadStd	0.14	0.23	0.33	0.45	0.52	0.48	0.27	0.29	0.35	0.25	0.17	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page