

INUUVIK AP, NT, Canada

WMO: 719570

Lat: 68.304N

Lon: 133.481W

Elev: 222

StdP: 14.58

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-39.1	-35.3	-47.3	0.3	-38.7	-43.8	0.4	-34.9	25.1	0.1	20.1	0.0	1.6	80	0.815

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.4	78.8	61.2	74.9	59.4	71.3	57.9	63.0	74.9	61.0	72.0	59.0	69.1	8.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.1	72.7	67.3	55.9	67.0	65.3	53.9	62.2	63.6	28.6	74.8	27.2	72.3	25.9	69.3	70.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.9	15.2	13.4		-42.6	84.7	4.5	3.4	-45.9	87.1	-48.5	89.1	-51.1	91.0	-54.4	93.5
			DB	-42.5	66.2	4.2	2.4	-45.5	68.0	-48.0	69.4	-50.4	70.8	-53.5	72.6
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	-13.0	-10.1	-6.7	13.0	34.9	53.0	57.8	51.8	40.2	21.4	0.6	-9.3
	DBStd	28.50	14.49	14.05	13.68	13.99	12.42	9.16	8.10	8.49	8.14	9.45	11.43	12.26
	HDD50	11690	1954	1684	1757	1110	489	73	24	81	311	889	1481	1837
	HDD65	16604	2419	2104	2222	1560	933	371	245	419	745	1353	1931	2302
	CDD50	603	0	0	0	0	21	163	267	135	16	1	0	0
	CDD65	42	0	0	0	0	0	11	23	8	0	0	0	0
	CDH74	411	0	0	0	0	7	127	211	65	1	0	0	0
	CDH80	69	0	0	0	0	1	25	31	12	0	0	0	0
(14) Wind	WSAvg	6.1	4.8	5.0	5.7	6.6	7.4	7.7	7.1	6.7	6.5	5.7	4.9	4.7
(15) Precipitation	PrecAvg	10.2	0.6	0.4	0.5	0.5	0.7	0.9	1.5	1.8	1.1	1.1	0.6	0.6
	PrecMax	14.8	1.7	0.9	1.6	1.7	2.4	2.8	3.4	5.9	2.4	4.0	1.5	1.4
	PrecMin	5.0	0.0	0.0	0.0	0.1	0.0	0.0	0.3	0.3	0.1	0.1	0.0	0.0
	PrecStd	2.1	0.4	0.2	0.3	0.4	0.6	0.7	0.8	0.9	0.6	0.6	0.3	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.3	27.9	36.5	51.3	72.6	83.8	83.7	81.7	67.5	47.6	33.4	24.6
		MCWB	28.6	24.6	31.5	41.8	54.0	62.8	64.2	64.8	54.4	40.9	31.1	22.6
	2%	DB	22.8	21.7	26.5	43.6	66.1	77.4	79.4	74.2	61.2	39.6	26.2	18.6
		MCWB	21.2	19.3	23.0	37.1	50.9	59.0	61.6	61.5	50.8	36.3	24.7	17.0
	5%	DB	14.2	15.8	19.3	39.4	59.9	73.4	75.9	69.6	56.7	35.8	21.3	13.4
		MCWB	13.2	14.2	17.3	33.9	47.5	57.0	60.4	58.5	48.7	33.6	20.1	12.3
	10%	DB	6.7	10.3	13.3	34.4	54.0	69.4	72.5	65.6	52.2	32.9	16.6	8.0
		MCWB	5.7	9.1	11.6	30.2	44.4	55.0	59.1	56.5	46.4	31.2	15.5	7.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.8	24.9	31.4	41.8	54.7	64.1	65.9	66.0	55.0	41.8	31.2	22.6
		MCDB	31.7	27.9	36.0	50.8	69.9	79.6	79.3	79.8	64.6	45.7	33.1	24.3
	2%	WB	21.1	19.5	23.3	37.5	51.4	60.7	63.5	62.4	52.0	37.0	24.8	17.1
		MCDB	22.8	21.4	26.2	43.1	64.8	74.8	75.5	72.8	59.9	39.5	26.1	18.6
	5%	WB	13.2	14.1	17.1	34.1	48.1	58.2	61.7	59.7	49.2	33.7	20.0	12.4
		MCDB	14.2	15.7	19.2	39.1	59.2	71.0	72.8	67.7	55.3	35.5	21.2	13.4
	10%	WB	5.8	9.0	11.5	30.3	44.5	56.0	60.0	57.2	46.8	31.3	15.6	7.2
		MCDB	6.7	10.2	13.2	34.4	53.7	67.8	70.5	64.2	51.9	32.9	16.6	8.0
(35) Mean Daily Temperature Range	MDBR		12.0	13.5	16.1	16.7	16.4	19.8	17.4	15.0	11.9	9.3	11.1	11.4
	5% DB	MCDBR	16.8	17.0	20.1	17.8	25.5	24.1	22.6	20.5	19.0	11.2	12.8	15.6
		MCWBR	15.5	15.7	17.4	12.9	14.4	11.4	10.6	10.6	11.0	8.4	12.0	14.8
	5% WB	MCDBR	16.8	16.8	19.9	17.5	25.1	22.8	20.1	18.6	17.6	10.5	12.7	15.5
		MCWBR	15.6	15.6	17.2	12.6	14.5	11.6	10.5	10.3	10.7	8.0	12.0	14.7
(40) Clear-Sky Solar Irradiance	taub		0.159	0.216	0.252	0.305	0.348	0.343	0.366	0.337	0.295	0.237	0.158	N/A
	taud		1.911	2.130	2.223	2.164	2.285	2.450	2.420	2.510	2.557	2.252	1.922	N/A
	Ebn at Noon		39	193	253	265	266	272	260	257	243	180	32	0
	Edh at Noon		2	14	23	34	34	30	30	24	18	12	2	0
(44) All-Sky Solar Radiation	RadAvg		12	172	698	1433	1834	1946	1579	1087	592	193	29	0
	RadStd		1	11	33	53	142	153	150	110	54	23	3	0

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+1.84	+3.71	+3.60	N/A	N/A	N/A	-675	-679	N/A	N/A	
(47) Regional (9 neighbors)		+1.75	+3.20	+3.65	N/A	N/A	N/A	-769	-760	N/A	N/A	

Nomenclature: See separate page