

DEASE LAKE, BC, Canada

WMO: 719580

Lat: 58.422N

Lon: 130.031W

Elev: 2646

StdP: 13.34

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -33.4	(c) -26.9	(d) -40.8	(e) 0.6	(f) -33.0	(g) -34.7	(h) 0.8	(i) -27.2	(j) 13.7	(k) 12.9	(l) 12.1	(m) 6.1	(n) 4.1	(o) 50	(p) 0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.7	(c) 77.8	(d) 56.9	(e) 73.4	(f) 55.1	(g) 69.3	(h) 53.6	(i) 59.0	(j) 72.7	(k) 57.0	(l) 69.1	(m) 55.2	(n) 66.1	(o) 5.9	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.8	68.0	60.8	52.0	63.5	59.1	50.4	59.8	57.7	26.8	72.9	25.5	69.2	24.3	66.3	68.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.9	(b) 12.0	(c) 10.4	(e) -39.0	(f) 84.0	(g) 5.0	(h) 3.0	(i) -42.6	(j) 86.2	(k) -45.5	(l) 87.9	(m) -48.3	(n) 89.6	(o) -52.0	(p) 91.8		
(4) 13.9	(5) 12.0	(6) 10.4	(7) -38.5	(8) 62.9	(9) 5.1	(10) 2.2	(11) -42.1	(12) 64.5	(13) -45.1	(14) 65.7	(15) -47.9	(16) 67.0	(17) -51.6	(18) 68.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.3	3.6	10.4	19.8	33.8	44.6	52.3	55.5	53.4	45.0	33.6	16.5	6.0	
	DBStd	21.04	16.56	13.45	12.56	7.06	6.47	5.71	4.85	5.41	5.21	6.99	11.26	14.84	
	HDD50	7270	1437	1110	937	486	191	36	8	23	163	508	1006	1365	
	HDD65	12299	1902	1530	1402	936	631	384	296	360	599	973	1456	1830	
	CDD50	452	0	0	0	0	25	105	179	129	14	0	0	0	
	CDD65	5	0	0	0	0	0	2	2	1	0	0	0	0	
	CDH74	314	0	0	0	0	13	102	103	94	2	0	0	0	
	CDH80	51	0	0	0	0	2	20	17	12	0	0	0	0	
Wind	WSAvg	3.9	3.7	4.0	4.8	4.6	4.6	4.2	3.9	3.5	3.4	3.3	3.0	3.3	
Precipitation	PrecAvg	17.8	1.3	1.0	0.9	0.6	1.3	1.8	2.4	2.2	2.0	1.6	1.4	1.4	
	PrecMax	23.2	4.4	2.8	2.2	1.5	2.7	3.9	5.4	4.5	3.5	5.1	3.8	3.3	
	PrecMin	13.8	0.2	0.0	0.1	0.2	0.1	0.1	0.6	0.7	0.9	0.6	0.3	0.3	
	PrecStd	2.7	0.8	0.7	0.5	0.3	0.6	0.8	1.2	0.8	0.7	1.0	0.9	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.9	41.3	49.1	61.4	75.2	83.2	81.9	82.0	69.9	55.4	42.6	40.3	
		MCWB	33.2	34.7	37.7	44.1	51.4	58.1	59.4	59.7	53.6	46.5	36.7	34.8	
	2%	DB	32.4	34.8	43.2	54.0	69.7	76.6	76.5	76.5	62.6	49.4	36.6	33.9	
		MCWB	31.3	31.0	34.8	40.6	49.6	55.5	57.0	57.9	49.7	42.3	33.3	30.8	
	5%	DB	28.8	31.5	39.6	49.8	64.5	71.2	72.4	70.7	58.5	46.2	33.0	30.6	
		MCWB	28.0	29.3	32.7	38.4	47.8	53.6	55.6	55.8	48.6	40.2	31.4	29.2	
	10%	DB	24.4	28.1	36.4	46.3	59.9	66.2	68.0	65.6	55.0	43.1	30.6	26.3	
		MCWB	23.7	26.2	30.7	36.4	45.8	51.4	54.7	53.9	47.4	38.6	29.4	25.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.3	35.5	38.7	45.1	53.0	60.3	61.3	61.2	55.6	47.9	37.8	34.4
			MCDB	36.9	40.0	47.1	58.2	67.9	77.5	76.6	76.4	66.3	54.1	41.8	38.2
2%		WB	31.6	31.7	35.5	41.6	50.4	56.8	58.9	59.0	52.4	43.9	34.1	31.3	
		MCDB	33.0	34.2	42.2	52.2	66.6	71.8	71.5	73.3	59.7	48.0	36.1	32.6	
5%		WB	28.3	29.1	33.4	39.0	48.6	54.7	57.1	56.7	50.2	41.3	31.8	28.4	
		MCDB	29.2	31.1	38.9	48.0	62.7	68.2	68.6	68.0	56.3	45.0	33.1	30.3	
10%		WB	24.2	26.4	31.3	36.9	46.7	52.7	55.4	54.8	48.2	39.0	29.5	24.6	
		MCDB	24.9	28.1	35.6	45.1	58.4	63.8	66.0	63.9	53.2	42.6	30.7	25.8	
Mean Daily Temperature Range	5% DB	MDBR	14.2	19.8	22.9	20.9	23.7	22.6	20.7	20.9	18.6	14.1	13.5	13.7	
		MCDBR	15.7	20.2	22.1	26.1	32.7	32.2	30.7	31.4	25.5	18.7	14.2	15.1	
		MCWBR	14.1	16.2	14.8	14.7	16.2	15.2	14.5	15.7	14.4	12.1	11.7	12.8	
	5% WB	MCDBR	15.3	18.8	20.7	23.5	28.8	28.1	25.5	27.3	22.1	17.7	13.5	14.8	
		MCWBR	13.9	15.5	13.9	13.8	14.7	13.9	13.1	14.3	13.1	11.9	11.2	12.8	
Clear-Sky Solar Irradiance	taub		0.239	0.252	0.276	0.356	0.363	0.366	0.353	0.342	0.308	0.283	0.233	0.209	
	taud		2.132	2.277	2.232	1.991	2.187	2.358	2.434	2.492	2.570	2.443	2.164	2.063	
	Ebn at Noon		191	254	278	266	274	276	277	273	269	240	192	162	
	Edh at Noon		15	22	30	47	41	36	32	29	23	19	14	11	
All-Sky Solar Radiation	RadAvg		148	401	844	1391	1745	1662	1503	1251	785	411	179	101	
	RadStd		13	46	80	75	118	125	154	91	71	36	19	10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page